



Designation: E1548 – 09

## Standard Practice for Preparation of Aerospace Contamination Control Plans<sup>1</sup>

This standard is issued under the fixed designation E1548; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reappraisal.

### 1. Scope

1.1 This practice is intended to assist in the preparation of formal plans for contamination control, especially of aerospace critical surfaces. Requirements may be established at the systems level, either by the customer or the systems integrator, or at the subsystem level. Subsystem requirements may be imposed by the responsible subsystem supplier or they may be flowed down from the systems organization (4.7). The extent of detail and level of cleanliness required can vary with the particular application and type of hardware being built, but all aspects of contamination control must be included in a final plan. Therefore, each of the following elements must be considered for inclusion in a contamination control plan (CCP):

1.1.1 *Cleanliness requirements* for deliverable hardware addressing particulate, molecular, or biological contaminants or combination thereof. Specify contamination limits and any budget allocations.

1.1.2 *Implementation plans* to achieve, verify, and maintain the specified cleanliness requirements. Specify material and process controls, cleaning techniques, verification tests, protection and prevention plans, transportation controls, and corrective action for discrepancies.

1.1.3 *Environmental controls* including clean facilities to be used, facility maintenance, and monitoring schedule.

1.1.4 *Personnel and operational controls* including operating procedures, restrictions, training, motivation, and organizational responsibilities including the organization or individual for implementation and verification of the CCP.

1.2 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

<sup>1</sup> This practice is under the jurisdiction of ASTM Committee E21 on Space Simulation and Applications of Space Technology and is the direct responsibility of Subcommittee E21.05 on Contamination.

Current edition approved April 1, 2009. Published April 2009. Originally approved in 1993. Last previous edition approved in 2003 as F1548 – 03. DOI: 10.1520/E1548-09.

### 2. Referenced Documents

#### 2.1 ASTM Standards:<sup>2</sup>

E595 Test Method for Total Mass Loss and Collected Volatile Condensable Materials from Outgassing in a Vacuum Environment

E1216 Practice for Sampling for Particulate Contamination by Tape Lift

E1235 Test Method for Gravimetric Determination of Non-volatile Residue (NVR) in Environmentally Controlled Areas for Spacecraft

E1549 Specification for ESD Controlled Garments Required in Cleanrooms and Controlled Environments for Spacecraft for Non-Hazardous and Hazardous Operations

E1559 Test Method for Contamination Outgassing Characteristics of Spacecraft Materials

E2042 Practice for Cleaning and Maintaining Controlled Areas and Clean Rooms

E2217 Practice for Design and Construction of Aerospace Cleanrooms and Contamination Controlled Areas

F50 Practice for Continuous Sizing and Counting of Airborne Particles in Dust-Controlled Areas and Clean Rooms Using Instruments Capable of Detecting Single Sub-Micrometre and Larger Particles

F303 Practices for Sampling for Particles in Aerospace Fluids and Components

F312 Test Methods for Microscopical Sizing and Counting Particles from Aerospace Fluids on Membrane Filters

#### 2.2 Government Standards:

FED-STD-209E Airborne Particulate Cleanliness Classes in Cleanrooms and Clean Zones<sup>3,4</sup>

USAF Tech Order 00-25-203 Contamination Control of Aerospace Facilities, U.S. Air Force<sup>3</sup>

<sup>2</sup> For referenced ASTM standards, visit the ASTM website, [www.astm.org](http://www.astm.org), or contact ASTM Customer Service at [service@astm.org](mailto:service@astm.org). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

<sup>3</sup> Available from Standardization Documents Order Desk, Bldg. 4 Section D, 700 Robbins Ave., Philadelphia, PA 19111-5094, Attn: NPODS.

<sup>4</sup> FED-STD-209 has been superseded by ISO 14644-1 and -2. It may continue to be used if mutually agreed to by customer and supplier.

### 2.3 International Standards:<sup>5</sup>

**ISO 14644-1 Cleanrooms and Associated Controlled Environments, Classification of Air Cleanliness**

**ISO 14644-2 Cleanrooms and Associated Controlled Environments—Specifications for testing and monitoring to prove continued compliance with ISO 14644-1**

**ISO 15388 Space Systems—Contamination and Cleanliness Control**

### 2.4 IEST Standards:

**IEST-STD-CC1246D Product Cleanliness Levels and Contamination Control Program<sup>6</sup>**

NOTE 1—The Institute of Environmental Sciences has several Recommended Practices which may also be useful in the preparation of a CCP.

## 3. Terminology

### 3.1 Definitions:

3.1.1 *bidirectional reflectance distribution function (BRDF)*—the scattering properties of light reflected off surfaces, expressed as the ratio of differential outputs of radiance divided by differential inputs of radiance. Surface contaminants scatter the incident radiation in all directions and with variable intensities; BRDF is a method to quantify the spatial distribution of the scattered energy.

3.1.2 *biological contamination*—living material such as algae, bacteria, fungus, and so forth, which is capable of reproducing, thus being an increasing contaminant source.

3.1.3 *budget allocation*—the itemized summary of contamination accumulation for a given critical hardware item distributed over all phases from manufacture through end of performance lifetime.

3.1.4 *cleanroom*—an environmentally conditioned area where temperature, humidity, and airborne contaminants are controlled by design and operation. High Efficiency Particulate Air (HEPA) filters or better are usually required to achieve the air cleanliness level. Air particulate cleanliness is classified in accordance with ISO 14644-1.

3.1.4.1 *as-built cleanroom*—a cleanroom that is complete and ready for operation, with all services connected and functional, but without equipment or operating personnel in the cleanroom.

3.1.4.2 *at-rest cleanroom*—a cleanroom that is complete and ready for operation, with all services connected and functional, and with equipment installed and operable, as specified but without operating personnel in the cleanroom.

3.1.4.3 *operational cleanroom*—a cleanroom in normal operation, with all services functioning and with equipment and personnel, if applicable, present and performing their normal work functions in the cleanroom.

NOTE 2—For batch operations, specific conditions and requirements should be noted for monitoring and control.

<sup>5</sup> Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

<sup>6</sup> Available from Institute of Environmental Sciences and Technology (IEST), Arlington Place One, 2340 S. Arlington Heights Rd., Suite 100, Arlington Heights, IL 60005-4516, <http://www.iest.org>.

3.1.5 *clean zone*—a defined space in which the concentration of airborne particles is controlled to meet a specified airborne particulate cleanliness class.

3.1.6 *controlled area*—an area which does not require a high degree of temperature and humidity control but a semi-clean atmosphere is desired. Air conditioning is standard commercial design except that filtration is rated to 80-85 % for 1.0 micrometer ( $\mu\text{m}$ ) and larger particles to control airborne contaminants. These areas shall not exceed the airborne particle concentration of Class 8.5 (FED-STD-209E Class 300, 000) at 0.5  $\mu\text{m}$  and Class 8 (Class 100,000) at 5.0  $\mu\text{m}$  per ISO 14644-1 (FED-STD-209E). Reference USAF Tech Order 00-25-203.

3.1.7 *facility*—the total real property required to accomplish the environmental control and operation of cleanrooms, clean zones, and controlled areas as well as administrative and personnel support.

NOTE 3—This includes the cleanroom proper, air locks, change rooms, parts cleaning, storage, HVAC equipment, offices, and so forth.

3.1.8 *HVAC*—Heating, Ventilating, and Air Conditioning.

3.1.9 *image analysis*—the measurement of size, shape, number, position, orientation, brightness, and other parameters of small objects using the combination of an autofocusing microscope, an imaging sensor, and a dedicated computer system. Can be used to perform particle counts or measure particle dimensions automatically, with far greater accuracy than manual techniques.

3.1.10 *molecular contamination*—nonparticulate matter in the form of droplets or thin films which adversely affects component or system performance.

3.1.11 *nonvolatile residue (NVR)*—soluble material remaining after evaporation of a filtered volatile fluid or precipitate from a gas phase, usually reported in milligrams per unit area (or volume).

3.1.12 *particulate contamination*—small discrete mass of solid matter, usually measured in micrometers ( $\mu\text{m}$ ), which adversely affects component or system performance.

3.1.13 *precision cleaning*—cleaning of hardware surfaces by approved engineering methods to meet specific cleanliness criteria.

3.1.14 *visibly clean*—absence of particulate or molecular contaminants when viewed from a specified distance with normal (or corrected to normal) vision with a specified illumination level.

## 4. Contents of CCP

### 4.1 General Items and Information:

4.1.1 All CCPs shall include an introduction or scope specifying the contamination-sensitive component(s) or system(s) being addressed, a list of applicable documents, and a list of definitions including any acronyms and abbreviations used in the document.

4.1.2 The level of detail required and the nature and extent of controls needed depends upon a number of factors. The