



**SLOVENSKI STANDARD
SIST EN ISO 14644-4:2023**

01-marec-2023

**Nadomešča:
SIST EN ISO 14644-4:2002**

Čiste sobe in podobna nadzorovana okolja - 4. del: Načrtovanje, izdelava in začetek obratovanja (ISO 14644-4:2022)

Cleanrooms and associated controlled environments - Part 4: Design, construction and start-up (ISO 14644-4:2022)

Reinräume und zugehörige Reinraumbereiche - Teil 4: Planung, Ausführung und Erst-Inbetriebnahme (ISO 14644-4:2022)

Salles propres et environnements maîtrisés apparentés - Partie 4: Conception, construction et mise en service (ISO 14644-4:2022)

Ta slovenski standard je istoveten z: EN ISO 14644-4:2022

ICS:

13.040.35	Brezprašni prostori in povezana nadzorovana okolja	Cleanrooms and associated controlled environments
-----------	--	---

SIST EN ISO 14644-4:2023

en,de

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN ISO 14644-4

December 2022

ICS 13.040.35

Supersedes EN ISO 14644-4:2001

English Version

Cleanrooms and associated controlled environments - Part 4: Design, construction and start-up (ISO 14644-4:2022)

Salles propres et environnements maîtrisés apparentés
- Partie 4: Conception, construction et mise en service
(ISO 14644-4:2022)

Reinräume und zugehörige Reinraumbereiche - Teil 4:
Planung, Ausführung und Erst-Inbetriebnahme (ISO
14644-4:2022)

This European Standard was approved by CEN on 14 November 2022.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

<https://standards.iteh.ai/catalog/standards/sist/f9a4364e-c372-4fd4-80e6-19ce1da10996/sist-en-iso-14644-4-2023>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	3

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 14644-4:2023](https://standards.iteh.ai/catalog/standards/sist/f9a4364e-c372-4fd4-80e6-19ce1da10996/sist-en-iso-14644-4-2023)

<https://standards.iteh.ai/catalog/standards/sist/f9a4364e-c372-4fd4-80e6-19ce1da10996/sist-en-iso-14644-4-2023>

European foreword

This document (EN ISO 14644-4:2022) has been prepared by Technical Committee ISO/TC 209 "Cleanrooms and associated controlled environments" in collaboration with Technical Committee CEN/TC 243 "Cleanroom technology" the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2023, and conflicting national standards shall be withdrawn at the latest by June 2023.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 14644-4:2001.

Any feedback and questions on this document should be directed to the users' national standards body/national committee. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

Endorsement notice

The text of ISO 14644-4:2022 has been approved by CEN as EN ISO 14644-4:2022 without any modification.

INTERNATIONAL
STANDARD

ISO
14644-4

Second edition
2022-11

Cleanrooms and associated controlled environments —

**Part 4:
Design, construction and start-up**

Salles propres et environnements maîtrisés apparentés —

Partie 4: Conception, construction et mise en service

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN ISO 14644-4:2023](https://standards.iteh.ai/catalog/standards/sist/f9a4364e-c372-4fd4-80e6-19ce1da10996/sist-en-iso-14644-4-2023)

<https://standards.iteh.ai/catalog/standards/sist/f9a4364e-c372-4fd4-80e6-19ce1da10996/sist-en-iso-14644-4-2023>



Reference number
ISO 14644-4:2022(E)

© ISO 2022

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN ISO 14644-4:2023](https://standards.iteh.ai/catalog/standards/sist/f9a4364e-c372-4fd4-80e6-19ce1da10996/sist-en-iso-14644-4-2023)

<https://standards.iteh.ai/catalog/standards/sist/f9a4364e-c372-4fd4-80e6-19ce1da10996/sist-en-iso-14644-4-2023>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2022

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
3.1 General.....	2
3.2 Installation.....	5
4 Abbreviated terms	5
5 General	6
6 Requirements	7
6.1 Cleanroom requirements.....	7
6.2 Other requirements.....	9
6.3 Documentation.....	9
7 Design	9
7.1 General.....	9
7.2 Conceptual design.....	10
7.3 Basic design.....	10
7.4 Detailed design.....	11
7.5 Change management.....	11
8 Construction	12
8.1 General.....	12
8.2 Construction plan.....	12
8.2.1 General.....	12
8.2.2 Schedule.....	12
8.2.3 Quality plan.....	12
8.2.4 Clean build protocol.....	12
8.3 Construction verification.....	13
8.4 Documentation.....	13
9 Start-up	13
9.1 General.....	13
9.2 Commissioning.....	14
9.2.1 General.....	14
9.2.2 Setting to work.....	14
9.2.3 Functional and performance verifications.....	14
9.3 Training.....	14
9.4 Handover.....	14
9.5 Documentation.....	14
9.5.1 Commissioning documentation.....	14
9.5.2 Performance-monitoring instructions.....	15
9.5.3 Maintenance instructions.....	15
9.5.4 Maintenance record.....	15
9.5.5 Record of training.....	15
Annex A (informative) Guidance on requirements	16
Annex B (informative) Guidance on design	24
Annex C (informative) Guidance on construction	45
Annex D (informative) Guidance on start-up	51
Bibliography	56

ISO 14644-4:2022(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 209, *Cleanrooms and associated controlled environments*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 243, *Cleanroom technology*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 14644-4:2001), which has been technically revised.

The main changes are as follows:

- normative content has been extended;
- the process of gathering and defining requirements has been added;
- the scope has been extended from classified cleanrooms to include additional cleanliness attributes;
- the entire text has been revised or clarified to aid its application.

A list of all parts in the ISO 14644 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Cleanrooms and associated controlled environments provide for the control of airborne particulate contamination and, if relevant, other forms of contamination, to levels appropriate for accomplishing contamination-sensitive activities. Products and processes that benefit from the control of airborne contamination include those in such industries as aerospace, microelectronics, pharmaceuticals, medical devices, food and research and development laboratories and some applications in healthcare.

Cleanrooms and associated controlled environments are classified for air cleanliness by particle concentration (ISO 14644-1). Cleanliness attributes relating to chemicals, nanoscale particles and viable particles (microorganisms), as well as cleanliness of surfaces, can also be considered.

This document is one of the series of International Standards concerned with cleanrooms and associated controlled environments prepared by ISO/TC 209.

This document provides guidance for the design, construction and start-up of cleanrooms, both new and those undergoing modification or refurbishment. In this edition, a more structured approach is provided with separate normative sections on requirements, design, construction and start-up, supported by four corresponding informative annexes.

For this edition, key recommendations and considerations include:

- a) A structured approach with a logical sequential flow through the design, construction and start-up stages. There will normally be reviews and iterations of the requirements, contamination control concepts, layouts and other considerations. The final design should be reviewed against the requirements before construction commences and when construction is complete. The operation and performance are verified against the requirements during start-up.
- b) Inclusion of other cleanliness attributes. The ISO 14644 series has parts that deal with other cleanliness attributes, namely chemicals, nanoscale particles, macro-particles and, in ISO 14698, viable particles (microorganisms), as well as cleanliness of surfaces. These other attributes should be considered if relevant, bearing in mind that the primary requirement for a cleanroom or clean zone is that it meets a classification by airborne particle concentration according to ISO 14644-1.
- c) Importance of a contamination risk assessment. Assessments should be carried out to better understand the contamination risk and its impact on the process and product and to identify the critical control points (locations) in the cleanroom or clean zone.
- d) A clear statement of requirements, namely everything needed for input into the design, including the purpose of the cleanroom and the acceptance criteria for performance parameters. This is critical and should be documented prior to the start of the design process.
- e) Ventilation effectiveness. This revision focuses on the importance of ventilation effectiveness through control of air-flow patterns and clean-up recovery rates. Two measures are identified: air change effectiveness (ACE) and contaminant removal effectiveness (CRE).
- f) Using air supply rate for calculations of contaminant dilution and removal. This will make it possible to achieve energy-efficient cleanrooms while achieving the required level of air cleanliness.
- g) Energy efficiency and life cycle considerations. Energy efficiency in cleanrooms is very important and is covered by ISO 14644-16.
- h) A clean build protocol. This is included to minimize contamination during construction of the cleanroom.

Information directly relevant to cleanrooms and associated controlled environments is included in the informative annexes. Supporting information is given in the Bibliography.

Cleanrooms and associated controlled environments —

Part 4: Design, construction and start-up

1 Scope

This document specifies the process for creating a cleanroom from requirements through to its design, construction and start-up. It applies to new, refurbished and modified cleanroom installations. It does not prescribe specific technological or contractual means of achieving these requirements. It is intended for use by users, specifiers, designers, purchasers, suppliers, builders and performance verifiers of cleanroom installations. The primary cleanliness consideration is airborne particle concentration. Detailed checklists are provided for the requirements, design, construction and start-up, which include important performance parameters to be considered. Energy management design approaches are identified to support an energy-efficient cleanroom design. Construction guidance is provided, including requirements for start-up and verification. A basic element of this document is consideration of aspects, including maintenance, that will help to ensure continued satisfactory operation for the entire life cycle of the cleanroom.

NOTE Further guidance is given in [Annexes A to D](#). ISO 14644-1, ISO 14644-2, ISO 14644-8, ISO 14644-9, ISO 14644-10, ISO 14644-12 and ISO 14644-17 provide complementary information. ISO 14644-7 offers guidance on design, construction and requirements for separative devices (clean air hoods, glove boxes, isolators and mini-environments).

The following subjects are mentioned but not addressed in this document:

- specific operational activities, processes to be accommodated and process equipment in the cleanroom installation;
- fire and safety regulations;
- ongoing operation, cleaning and maintenance activities, which are covered by ISO 14644-5.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 14644-1, *Cleanrooms and associated controlled environments — Part 1: Classification of air cleanliness by particle concentration*

ISO 14644-16, *Cleanrooms and associated controlled environments — Part 16: Energy efficiency in cleanrooms and separative devices*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

ISO 14644-4:2022(E)

3.1 General

3.1.1

air change effectiveness

ACE

ratio between the recovery rate at a location or locations in a *cleanroom* (3.1.4) and the overall recovery rate of the cleanroom after a contamination event

Note 1 to entry: The recovery rate is defined and measured in accordance with ISO 14644-3.

[SOURCE: ISO 14644-16:2019, 3.2.7]

3.1.2

classification

method of assessing level of cleanliness against a specification for a cleanroom or clean zone

Note 1 to entry: Levels should be expressed in terms of an ISO Class, which represents maximum allowable concentrations of particles in a unit volume of air.

[SOURCE: ISO 14644-1:2015, 3.1.4]

3.1.3

cleanliness

condition not exceeding a specified level of contamination

[SOURCE: ISO 14644-15:2017, 3.5]

3.1.4

cleanroom

room within which the number concentration of airborne particles is controlled and classified, and which is designed, constructed and operated in a manner to control the introduction, generation and retention of particles inside the room

Note 1 to entry: The class of airborne particle concentration is specified.

Note 2 to entry: Levels of other cleanliness attributes, such as chemical, viable or nanoscale concentrations in the air, and also surface cleanliness in terms of particle, nanoscale, chemical and viable concentrations, might also be specified and controlled.

Note 3 to entry: Other relevant physical parameters might also be controlled as required, e.g. temperature, humidity, pressure, vibration and electrostatic.

[SOURCE: ISO 14644-1:2015, 3.1.1]

3.1.5

clean zone

defined space within which the number concentration of airborne particles is controlled and classified, and which is constructed and operated in a manner to control the introduction, generation and retention of contaminants inside the space

Note 1 to entry: The class of airborne particle concentration is specified.

Note 2 to entry: Levels of other cleanliness attributes, such as chemical, viable or nanoscale concentrations in the air, and also surface cleanliness in terms of particle, nanoscale, chemical and viable concentrations, might also be specified and controlled.

Note 3 to entry: Other relevant physical parameters might also be controlled as required, e.g. temperature, humidity, pressure, vibration and electrostatic.

Note 4 to entry: A clean zone(s) can be a defined space within a cleanroom or might be achieved by a separative device. Such a device can be located inside or outside a cleanroom.

[SOURCE: ISO 14644-1:2015, 3.1.2]

3.1.6**commissioning**

planned and documented series of inspections, adjustments, measurements, tests and verifications carried out systematically to set the installation into correct technical operation as specified

Note 1 to entry: The objective evidence needed for a verification can be the result of an inspection or of testing other forms of determination, such as performing alternative calculations or reviewing documents

3.1.7**contaminant**

particle, chemical or microorganism that adversely affects the product or process

3.1.8**contaminant removal effectiveness****CRE**

ratio of particle concentration in the air leaving the cleanroom to the average of particle concentration in the working plane of the cleanroom, when particles entering from filtered supply air are ignored

Note 1 to entry: If the air leaves the cleanroom at more than one point then the weighted average of the particle concentrations based on the relative flowrates can be used.

Note 2 to entry: The number and positioning of the sampling locations for determining the average particle concentration in the working plane of the cleanroom can be based on the method given in 14644-1.

Note 3 to entry: The local particle concentration is dependent on the airflow pattern in the cleanroom and may vary significantly in the cleanroom. CRE in a sub-area of interest in the cleanroom may be calculated by selecting a single sampling location considered to be representative of the characteristics of the sub-area of interest.

Note 4 to entry: Particles may be replaced by another airborne contaminant.

[SOURCE: ISO 14644-16:2019, 3.2.5, modified — Definition revised and notes to entry added].

3.1.9**customer**

person or organisation that could or does receive a product or a service that is intended for or required by this person or organisation

EXAMPLE Consumer, client, end-user, retailer, receiver of product or service from an internal process beneficiary and purchaser.

Note 1 to entry: A customer can be internal or external to the organization.

[SOURCE: ISO 9000:2015, 3.2.4]

3.1.10**non-unidirectional airflow****non-UDAF**

air distribution where the supply air entering the cleanroom or clean zone mixes with the internal air

[SOURCE: ISO 14644-1:2015, 3.2.8 modified — Definition revised.]

3.1.11**particle**

minute piece of matter with defined physical boundaries

[SOURCE: ISO 14644-1:2015, 3.2.1]

3.1.12**setting to work**

activities to bring a system from a static state into correct operation