

SLOVENSKI STANDARD
SIST EN 1440:2016+A1:2018/oprA2:2019
01-april-2019

Oprema in pribor za utekočinjeni naftni plin (UNP) - Premične, ponovno polnljive, varjene in trdo spajkane jeklenke iz jekla za UNP - Periodična kontrola - Dopolnilo A2

LPG equipment and accessories - Transportable refillable traditional welded and brazed steel Liquefied Petroleum Gas (LPG) cylinders - Periodic inspection

Flüssiggas-Geräte und Ausrüstungsteile - Ortsbewegliche, wiederbefüllbare, geschweißte und hartgelötete Flaschen aus Stahl für Flüssiggas (LPG) - Wiederkehrende Inspektion

Equipements pour GPL et leurs accessoires - Bouteilles de gaz de pétrole liquéfié (GPL) en acier soudé et brasé transportables et rechargeables - Contrôle périodique

Ta slovenski standard je istoveten z: EN 1440:2016+A1:2018/prA2:2019

ICS:

23.020.35 Plinske jeklenke Gas cylinders

SIST EN 1440:2016+A1:2018/oprA2:2019 en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/5d686be1-9223-4ad8-9867-33a6ff-c90f27/sist-en-1440-2016a1-2018-oprA2-2019>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
EN 1440:2016+A1:2018
prA2

March 2019

ICS 23.020.35

English Version

LPG equipment and accessories - Transportable refillable traditional welded and brazed steel Liquefied Petroleum Gas (LPG) cylinders - Periodic inspection

Equipements pour GPL et leurs accessoires - Bouteilles de gaz de pétrole liquéfié (GPL) en acier soudé et brasé transportables et rechargeables - Contrôle périodique

Flüssiggas-Geräte und Ausrüstungsteile - Ortsbewegliche, wiederbefüllbare, geschweißte und hartgelötete Flaschen aus Stahl für Flüssiggas (LPG) - Wiederkehrende Inspektion

This draft amendment is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 286.

This draft amendment A2, if approved, will modify the European Standard EN 1440:2016+A1:2018. If this draft becomes an amendment, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for inclusion of this amendment into the relevant national standard without any alteration.

This draft amendment was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN 1440:2016+A1:2018/prA2:2019 (E)

European foreword

This document (EN 1440:2016+A1:2018/prA2:2019) has been prepared by Technical Committee CEN/TC 286 "Liquefied petroleum gas equipment and accessories", the secretariat of which is held by NSAI.

This document is currently submitted to the CEN Enquiry.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade.

ITEH STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/5d686be1-9223-4ad8-9867-33a6ffc90f27/sist-en-1440-2016a1-2018-oprA2-2019>

1 Modification to Clause 3

Modify the following definition as follows:

3.5

minor repair

“activities that include cleaning and replacement of components accessible without any dismantling of the valve (e.g. outlet seal, excess flow device) and that do not affect the integrity of the pressure receptacle”

2 Modification to Clause 5.3.1

Modify the 2nd sentence of paragraph 1 as follows:

“Proof pressure testing, according to 5.3.3, may require the agreement of a competent authority.”

3 Modification to Clause 5.3.3.2.1

Modify bullet e) and g) as follows:

“e) The test pressure shall be held for the time necessary to inspect the cylinder and examine it for any leak and/or other defects, but not less than 5 s.”

“g) Cylinders that do not leak or show any permanent visible distortion after the pressure has been released shall be deemed to have passed this test. All other cylinders shall be set aside and examined by a competent person.”

4 Modification to Clause D.5

Change NOTE 1 to:

“NOTE 1 The text of this annex is based on the RID [1]/ADR[2] packing instruction P200 (12) which includes additional provisions and information and which takes precedence over any clause of this standard.”