INTERNATIONAL STANDARD

Third edition 2015-11-15

Ships and marine technology — Fireextinguishing systems for protection of galley cooking equipment

Navires et technologie maritime — Systèmes d'extinction d'incendie des équipements de cuisine

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>ISO 15371:2015</u> https://standards.iteh.ai/catalog/standards/sist/3874d3f8-f6d4-49fd-9daabf53d9a6164b/iso-15371-2015



Reference number ISO 15371:2015(E)

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>ISO 15371:2015</u> https://standards.iteh.ai/catalog/standards/sist/3874d3f8-f6d4-49fd-9daabf53d9a6164b/iso-15371-2015



© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office Ch. de Blandonnet 8 • CP 401 CH-1214 Vernier, Geneva, Switzerland Tel. +41 22 749 01 11 Fax +41 22 749 09 47 copyright@iso.org www.iso.org

Contents

Page

Forew	vord		v			
Intro	duction	1	vi			
1	Scope	2				
2	Term	s and definitions	1			
3	Components					
	3.1	General				
	3.2	Detectors				
	3.3	Discharge nozzles	5			
	3.4	Operating devices	5			
	3.5	Manual actuators	5			
	3.6	Shut-off devices	5			
	3.7	Pipe, fittings, tubing and hose	6			
	3.8	Extinguishing agent	6			
	3.9	Indicators	6			
4	Svster	m requirements				
	4.1	General				
	4.2	Use				
	4.3	Applications	6			
	4.4	System actuation	7			
	4.5	Supervisioneh STANDARD PREVIEW				
	4.6	System location				
	4.7	Discharge nozzles Standards.iten.al				
	4.8	Special requirements				
	4.9	Protection of common exhaust duct 2015	9			
5	Test method sps://standards.iteh.ai/catalog/standards/sist/3874d3f8-f6d4-49fd-9daa-					
0	5.1	Cooking appliance extinguishing tests ⁵³⁷¹⁻²⁰¹⁵	9			
	011	5.1.1 General	9			
		5.1.2 Deep fat frver	10			
		5.1.3 Griddle				
		5.1.4 Range top				
		5.1.5 Gas radiant char-broiler				
		5.1.6 Electric char-broiler				
		5.1.7 Lava, pumice or synthetic rock char-broiler				
		5.1.8 Natural charcoal broiler				
		5.1.9 Mesquite wood char-broiler				
		5.1.10 Upright broiler				
		5.1.11 Chain broiler				
		5.1.12 Wok				
	5.2	Splash tests				
		5.2.1 Deep fat fryer extinguishing splash tests				
		5.2.2 Deep fat fryer cooking temperature splash test				
		5.2.3 Range top extinguishing splash tests				
		5.2.4 Range top cooking temperature splash tests				
		5.2.5 Wok extinguishing splash test				
	F 2	5.2.6 Wok cooking temperature splash tests				
	5.3	F 2.1 Conord				
		5.3.1 General				
		5.3.2 H000				
		5.5.5 FILLEI ALLU ITALILE	19 20			
	51	J.J.T Dull				
	5.4	5.4.1 Dronaration				

ISO 15371:2015(E)

	5.4.2	General test procedures	
	5.4.3	Fuel ignition and extinguishing system unit operation	
	5.4.4	Plenum testing	
	5.4.5	Conditions of acceptability	23
6	Installation,	operation and maintenance instruction manual	
7	Owner's man	ual	

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>ISO 15371:2015</u> https://standards.iteh.ai/catalog/standards/sist/3874d3f8-f6d4-49fd-9daabf53d9a6164b/iso-15371-2015

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2. <u>www.iso.org/directives</u>

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received. www.iso.org/patents

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT), see the following URL: Foreword - Supplementary information

The committee responsible for this document is ISO/TC 8, *Ships and marine technology*, Subcommittee SC 1, *Lifesaving and fire protection*.

<u>ISO 15371:2015</u>

This third edition **cancels and replaces the second edition (ISO4 15371 2015**). <u>Subclauses 2.25</u>, <u>2.26</u>, <u>4.4.13</u>, and <u>5.1.1.2 b</u>) have been editorially revised to clarify requirements.

Introduction

While this International Standard provides the marine industry with a means for evaluating the effectiveness of fire-extinguishing systems for a variety of grease-laden cooking appliances that may be found in a galley, it is also referenced by the International Maritime Organization (IMO) International Convention for the Safety of Life at Sea (SOLAS), 1974, as amended, and provides organizations who are party to SOLAS with a means of ensuring conformance of deep-fat cooking equipment with the fire suppression requirements prescribed in SOLAS.

iTeh STANDARD PREVIEW (standards.iteh.ai)

<u>ISO 15371:2015</u> https://standards.iteh.ai/catalog/standards/sist/3874d3f8-f6d4-49fd-9daabf53d9a6164b/iso-15371-2015

Ships and marine technology — Fire-extinguishing systems for protection of galley cooking equipment

1 Scope

This International Standard applies to the design, testing, and operation of pre-engineered fire extinguishing systems to protect the galley hoods, ducts, fryers and other grease-laden appliances.

Pre-engineered fire-extinguishing system units are also required to comply with requirements for the construction and components performance as applicable to specific types, designs, sizes and arrangements. This International Standard also provides minimum requirements for the testing and evaluation of components.

A product that contains features, characteristics, components, materials or systems that are new or different from those covered by the requirements in this International Standard and that involve a risk of fire, electric shock, or injury to persons, shall be evaluated using the appropriate additional component and end product testing.

NOTE Only deep-fat cooking equipment, among the types of galley cooking equipment covered by this International Standard, are required by SOLAS chapter II-2 Regulation 10.6.4 to have fixed fire-extinguishing systems.

2 Terms and definitions (standards.iteh.ai)

For the purposes of this document, the following terms and definitions apply.

https://standards.iteh.ai/catalog/standards/sist/3874d3f8-f6d4-49fd-9daa-

bf53d9a6164b/iso-15371-2015

2.1 auxiliary equipment

equipment used in conjunction with the extinguishing system

EXAMPLE Auxiliary equipment can be used to shut down power, fuel or ventilation to the hazard area being protected or to initiate alarm or signalling devices.

2.2

cooking appliance

cooking device that has, or is capable of having, a surface of liquid grease or one in which cooking with grease is involved

EXAMPLE Deep fat fryer, griddle, range, chain-broiler, electric char-broiler, charcoal broiler, mesquite broiler, gas radiant char broiler, wok, tilt skillet/braising pan and similar appliances.

Note 1 to entry: The protected area is limited to the cooking area of the appliance only.

2.3 cooking grease grease

vegetable shortening incorporating an antifoaming agent

2.4

cylinder

valve assembly

container that incorporates a valve and that provides storage for the extinguishing agent and expellant gas until the valve is actuated

Note 1 to entry: For cartridge-operated units, this assembly includes the extinguishing-agent storage container and cartridge mechanism.

2.5

deep fat fryer

commercially available electric cooking appliance in which cooking greases in depth are used

2.6

discharge nozzle

device that is used to distribute the extinguishing agent over or into a specific area

2.7

discharge rate

ratio of the quantity of the extinguishing agent discharged from a nozzle to the discharge time measured to within ± 1 s, expressed in kg/s

2.8

discharge time

time interval between the first appearance of the extinguishing agent at the nozzle and the time at which the discharge becomes predominantly gaseous or ceases

2.9

duct

duct system

continuous enclosed passageway for the transmission of air and cooking vapours

2.10

expellent gas

nitrogen air or other gas used to facilitate the discharge of the extinguishing agent

2.11 extinguishing system unit

(standards.iteh.ai)

identified components that can be assembled into a system for the discharge of an extinguishing agent through fixed piping and nozzles for the purpose of extinguishing fires

https://standards.iteh.ai/catalog/standards/sist/3874d3f8-f6d4-49fd-9daa bf53d9a6164b/iso-15371-2015

2.12 gas cartridge

container that provides storage for an expellant gas only

2.13

grease filter

component of a grease vapour removal system that deflects the air and vapours passing through it in such a manner as to result in the grease vapours concentrating, condensing, or both, for the purpose of grease collection

2.14

hood

device provided as part of an exhaust system to direct and capture grease vapours and exhaust gases from a cooking appliance

2.15

indicator

mechanical or electrical device that shows when an extinguishing system or one of its critical components is ready to operate or has already operated

2.16

inspection

visual examination of the system or portion thereof to verify that it appears to be in operating condition and is free of physical damage

2.17

low quality fatty beef steak

beef steak containing 20 % to 30 % fat or gristle, well marbled and uniform in size

2.18

maintenance

work, including, but not limited to, repair, replacement and service, performed to ensure that the equipment operates properly

2.19

manual means of actuation

means of system actuation in which a system is discharged by manual means

2.20

manufacturer's installation and maintenance manual

document containing the design, installation and maintenance instructions which is prepared and approved as a complimentary part of the extinguishing system

2.21

multiple-vat deep fat fryer

multiple electric fryers that are mechanically joined together

Note 1 to entry: Each vat incorporates a separately controlled heating source.

2.22

operable pressure

pressure developed in a fully charged container conditioned at 21 °C for at least 24 h

2.23

operable pressure range or standard pressure range corresponding to the pressures in the storage container at the specified minimum and

pressure range corresponding to the pressures in the storage container at the specified minimum and maximum temperatures for which the extinguishing system is intended to be operable

ISO 15371:2015

2.24 operating devices

mechanical, electrical of pneumatic devices involved in the operation of a system bf53d9a6164b/iso-15371-2015

2.25

operation

(automatic) operation without human intervention

Note 1 to entry: Methods of automatic operation include, but are not limited to, heat, rate of temperature rise, smoke or pressure change.

2.26

operation

(manual) operation of a system or its components through human action

2.27

owner's manual

pamphlet containing the manufacturer's recommendations for proper inspection and operation, which is prepared and approved as a complimentary part of the extinguishing system

2.28

plenum

volume of enclosed space between the grease filters and the portion of the hood above the grease filters in a hood and duct system

2.29

pre-engineered system

system that is tested in accordance with the limitations prescribed by the manufacturer for the maximum and minimum pipe lengths, accessories, number of fittings, number and types of nozzles, nozzle placement, types of fire risk and the maximum dimensions, volumes and areas of the appliances, hoods and ducts to be protected

Note 1 to entry: The hazards protected by these systems are specifically limited as to type and size by testing on actual fires.

Note 2 to entry: The limitations on hazards that are permitted to be protected by these systems and piping and nozzle configurations are those contained in the manufacturer's installation and maintenance manual.

2.30

pressure vessel

pressure cylinder

container that provides storage for the extinguishing agent and expellant gas

2.31

product

fire extinguishing system or any part thereof covered by the requirements of this International Standard

2.32

shut-off device

device that operates simultaneously with the extinguishing system to shut off fuel and power to the appliances protected by the system and other appliances required to be shut off upon operation of the system

(standards.iteh.ai)

2.33

signal status indication communicated by electrical or other means

https://standards.iteh.ai/catalog/standards/sist/3874d3f8-f6d4-49fd-9daabf53d9a6164b/iso-15371-2015

2.34

split-vat deep fat fryer

electric fryer that incorporates a divided partition which splits the fryer in sections

Note 1 to entry: Each split-vat fryer incorporates a separately controlled heating source.

2.35

tilt skillets

cooking devices which are intended to braise, simmer, sauté, or fry foods

2.36

braising pans

cooking devices which are intended to braise, simmer, sauté, or fry foods

3 Components

3.1 General

Only system components referenced or permitted in the manufacturer's installation and maintenance manual or alternative components that have been approved for use with the specific extinguishing system shall be used.

3.2 Detectors

Detectors shall be approved devices that are capable of detecting fire.

3.3 Discharge nozzles

3.3.1 Discharge nozzles shall be approved for their intended use.

3.3.2 Nozzles shall be provided with an internal strainer or a separate approved strainer located immediately up-stream of the nozzle.

Nozzles shall be constructed of brass, stainless-steel, or other corrosion-resistant materials, or 3.3.3 be protected inside and out against corrosion.

3.3.4 Nozzles shall be made of non-combustible materials and shall withstand the expected fire exposure without deformation.

3.3.5 Nozzles shall be permanently marked for identification.

3.3.6 All discharge nozzles shall be provided with caps or other suitable devices to prevent the entrance of grease vapours, moisture, or other foreign materials into the piping.

3.3.7 The caps or other protection devices shall blow off, open or blow out upon agent discharge.

3.4 Operating devices

RD PREV

Operating devices shall be designed for the service they will encounter and shall not be rendered 3.4.1 inoperative by, or be susceptible to accidental operation 1, ai)

3.4.2 Operating devices shall be designed to function properly through a temperature range from 0 °C to 49 °C, or marked to indicate the temperature limitations d3f8-f6d4-49fd-9daa-

bf53d9a6164b/iso-15371-2015

3.5 Manual actuators

3.5.1 Manual actuators shall not require a force of more than 178 N.

3.5.2 Manual actuators shall not require a movement of more than 356 mm to secure operation.

3.5.3 All manual actuators shall be provided with operating instructions. These instructions may include the use of pictographs, and shall have lettering at least 6 mm in height.

3.5.4 All remote manual operating devices shall be marked to identify the hazard against which they protect.

3.6 Shut-off devices

3.6.1 On activation of any cooking equipment or hood/duct fire extinguishing system, all sources of fuel and electric power that produce heat to all equipment protected by the system shall be shut off automatically.

3.6.2 Gas appliances not requiring protection but located under the same ventilation equipment shall also be shut off.

3.6.3 Exhaust fans and dampers are not required to be shut off on system actuation if the fireextinguishing system has been tested under both zero and high-velocity flow conditions.

3.6.4 If the expellant gas is used to pneumatically operate the shut-off devices, the gas shall be sourced prior to its entry into the agent storage cylinder.

3.6.5 Shut-off devices shall require manual resetting prior to fuel or power being restored.

3.7 Pipe, fittings, tubing and hose

3.7.1 Pipe and associated fittings shall be of non-combustible material having physical and chemical characteristics compatible with the extinguishing agent.

3.7.2 The pressure rating of the pipe, fittings and connection joints shall withstand the maximum expected pressure in the piping system.

3.7.3 Pipe, tubing, hose and fitting materials and types shall be in accordance with the manufacturer's installation and maintenance manual.

3.8 Extinguishing agent

3.8.1 The agent used shall be identified for the particular system in the operation and maintenance manual as recommended by the manufacturer of the system.

3.8.2 Agents from different manufacturers shall not be mixed **REVIEW**

3.9 Indicators

(standards.iteh.ai)

3.9.1 Systems shall be provided with an audible or <u>wisual5</u> indicator to show that the system is in a ready condition or is in need of recharging ai/catalog/standards/sist/3874d3f8-f6d4-49fd-9daabf53d9a6164b/iso-15371-2015

4 System requirements

4.1 General

4.1.1 Fire-extinguishing systems shall meet the requirements of <u>5.4</u>.

4.2 Use

4.2.1 Equipment that can be protected against hazard includes:

- a) cooking hoods, plenums, ducts, and filters with their associated cooking appliances, including deep fat fryers, ranges, broilers, griddles and similar grease-laden appliances;
- b) special grease removal devices;
- c) energy recovery devices installed in the exhaust system.

4.3 Applications

4.3.1 The manufacturer's installation and maintenance manual shall be consulted for the system's limitations and applications for which the approved system is considered satisfactory protection.

4.3.2 Each protected cooking appliance, individual hood and branch exhaust duct directly connected to the hood, shall be protected by a system or systems designed for simultaneous operation.