
**Ships and marine technology — Fire-
extinguishing systems for protection
of galley cooking equipment**

*Navires et technologie maritime — Systèmes d'extinction d'incendie
des équipements de cuisine*

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 15371:2015](https://standards.iteh.ai/catalog/standards/iso/3874d3f8-f6d4-49fd-9daa-bf53d9a6164b/iso-15371-2015)

<https://standards.iteh.ai/catalog/standards/iso/3874d3f8-f6d4-49fd-9daa-bf53d9a6164b/iso-15371-2015>



iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 15371:2015](https://standards.iteh.ai/catalog/standards/iso/3874d3f8-f6d4-49fd-9daa-bf53d9a6164b/iso-15371-2015)

<https://standards.iteh.ai/catalog/standards/iso/3874d3f8-f6d4-49fd-9daa-bf53d9a6164b/iso-15371-2015>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

	Page
Foreword	v
Introduction	vi
1 Scope	1
2 Terms and definitions	1
3 Components	4
3.1 General	4
3.2 Detectors	4
3.3 Discharge nozzles	5
3.4 Operating devices	5
3.5 Manual actuators	5
3.6 Shut-off devices	5
3.7 Pipe, fittings, tubing and hose	6
3.8 Extinguishing agent	6
3.9 Indicators	6
4 System requirements	6
4.1 General	6
4.2 Use	6
4.3 Applications	6
4.4 System actuation	7
4.5 Supervision	8
4.6 System location	8
4.7 Discharge nozzles	8
4.8 Special requirements	8
4.9 Protection of common exhaust duct	9
5 Test methods	9
5.1 Cooking appliance extinguishing tests	9
5.1.1 General	9
5.1.2 Deep fat fryer	10
5.1.3 Griddle	11
5.1.4 Range top	12
5.1.5 Gas radiant char-broiler	12
5.1.6 Electric char-broiler	13
5.1.7 Lava, pumice or synthetic rock char-broiler	13
5.1.8 Natural charcoal broiler	13
5.1.9 Mesquite wood char-broiler	14
5.1.10 Upright broiler	14
5.1.11 Chain broiler	14
5.1.12 Wok	15
5.2 Splash tests	15
5.2.1 Deep fat fryer extinguishing splash tests	15
5.2.2 Deep fat fryer cooking temperature splash test	16
5.2.3 Range top extinguishing splash tests	17
5.2.4 Range top cooking temperature splash tests	17
5.2.5 Wok extinguishing splash test	18
5.2.6 Wok cooking temperature splash tests	18
5.3 Hood and duct (full scale) extinguishing test	19
5.3.1 General	19
5.3.2 Hood	19
5.3.3 Filter and frame	19
5.3.4 Duct	20
5.4 Extinguishing system unit test	21
5.4.1 Preparation	21

5.4.2	General test procedures.....	22
5.4.3	Fuel ignition and extinguishing system unit operation.....	23
5.4.4	Plenum testing.....	23
5.4.5	Conditions of acceptability.....	23
6	Installation, operation and maintenance instruction manual.....	23
7	Owner's manual.....	25
8	Test report.....	26

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 15371:2015](https://standards.iteh.ai/catalog/standards/iso/3874d3f8-f6d4-49fd-9daa-bf53d9a6164b/iso-15371-2015)

<https://standards.iteh.ai/catalog/standards/iso/3874d3f8-f6d4-49fd-9daa-bf53d9a6164b/iso-15371-2015>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2. www.iso.org/directives

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received. www.iso.org/patents

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT), see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 8, *Ships and marine technology*, Subcommittee SC 1, *Lifesaving and fire protection*.

This third edition cancels and replaces the second edition (ISO 15371:2015). [Subclauses 2.25](#), [2.26](#), [4.4.13](#), and [5.1.1.2 b\)](#) have been editorially revised to clarify requirements.

[ISO 15371:2015](#)

<https://standards.iteh.ai/catalog/standards/iso/3874d3f8-f6d4-49fd-9daa-bf53d9a6164b/iso-15371-2015>

Introduction

While this International Standard provides the marine industry with a means for evaluating the effectiveness of fire-extinguishing systems for a variety of grease-laden cooking appliances that may be found in a galley, it is also referenced by the International Maritime Organization (IMO) International Convention for the Safety of Life at Sea (SOLAS), 1974, as amended, and provides organizations who are party to SOLAS with a means of ensuring conformance of deep-fat cooking equipment with the fire suppression requirements prescribed in SOLAS.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 15371:2015](https://standards.iteh.ai/catalog/standards/iso/3874d3f8-f6d4-49fd-9daa-bf53d9a6164b/iso-15371-2015)

<https://standards.iteh.ai/catalog/standards/iso/3874d3f8-f6d4-49fd-9daa-bf53d9a6164b/iso-15371-2015>

Ships and marine technology — Fire-extinguishing systems for protection of galley cooking equipment

1 Scope

This International Standard applies to the design, testing, and operation of pre-engineered fire extinguishing systems to protect the galley hoods, ducts, fryers and other grease-laden appliances.

Pre-engineered fire-extinguishing system units are also required to comply with requirements for the construction and components performance as applicable to specific types, designs, sizes and arrangements. This International Standard also provides minimum requirements for the testing and evaluation of components.

A product that contains features, characteristics, components, materials or systems that are new or different from those covered by the requirements in this International Standard and that involve a risk of fire, electric shock, or injury to persons, shall be evaluated using the appropriate additional component and end product testing.

NOTE Only deep-fat cooking equipment, among the types of galley cooking equipment covered by this International Standard, are required by SOLAS chapter II-2 Regulation 10.6.4 to have fixed fire-extinguishing systems.

2 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

2.1

auxiliary equipment

equipment used in conjunction with the extinguishing system

EXAMPLE Auxiliary equipment can be used to shut down power, fuel or ventilation to the hazard area being protected or to initiate alarm or signalling devices.

2.2

cooking appliance

cooking device that has, or is capable of having, a surface of liquid grease or one in which cooking with grease is involved

EXAMPLE Deep fat fryer, griddle, range, chain-broiler, electric char-broiler, charcoal broiler, mesquite broiler, gas radiant char broiler, wok, tilt skillet/braising pan and similar appliances.

Note 1 to entry: The protected area is limited to the cooking area of the appliance only.

2.3

cooking grease

grease

vegetable shortening incorporating an antifoaming agent

2.4

cylinder

valve assembly

container that incorporates a valve and that provides storage for the extinguishing agent and expellant gas until the valve is actuated

Note 1 to entry: For cartridge-operated units, this assembly includes the extinguishing-agent storage container and cartridge mechanism.

- 2.5 deep fat fryer**
commercially available electric cooking appliance in which cooking greases in depth are used
- 2.6 discharge nozzle**
device that is used to distribute the extinguishing agent over or into a specific area
- 2.7 discharge rate**
ratio of the quantity of the extinguishing agent discharged from a nozzle to the discharge time measured to within ± 1 s, expressed in kg/s
- 2.8 discharge time**
time interval between the first appearance of the extinguishing agent at the nozzle and the time at which the discharge becomes predominantly gaseous or ceases
- 2.9 duct**
duct system
continuous enclosed passageway for the transmission of air and cooking vapours
- 2.10 expellant gas**
nitrogen air or other gas used to facilitate the discharge of the extinguishing agent
- 2.11 extinguishing system unit**
identified components that can be assembled into a system for the discharge of an extinguishing agent through fixed piping and nozzles for the purpose of extinguishing fires
- 2.12 gas cartridge**
container that provides storage for an expellant gas only
- 2.13 grease filter**
component of a grease vapour removal system that deflects the air and vapours passing through it in such a manner as to result in the grease vapours concentrating, condensing, or both, for the purpose of grease collection
- 2.14 hood**
device provided as part of an exhaust system to direct and capture grease vapours and exhaust gases from a cooking appliance
- 2.15 indicator**
mechanical or electrical device that shows when an extinguishing system or one of its critical components is ready to operate or has already operated
- 2.16 inspection**
visual examination of the system or portion thereof to verify that it appears to be in operating condition and is free of physical damage
- 2.17 low quality fatty beef steak**
beef steak containing 20 % to 30 % fat or gristle, well marbled and uniform in size

2.18**maintenance**

work, including, but not limited to, repair, replacement and service, performed to ensure that the equipment operates properly

2.19**manual means of actuation**

means of system actuation in which a system is discharged by manual means

2.20**manufacturer's installation and maintenance manual**

document containing the design, installation and maintenance instructions which is prepared and approved as a complimentary part of the extinguishing system

2.21**multiple-vat deep fat fryer**

multiple electric fryers that are mechanically joined together

Note 1 to entry: Each vat incorporates a separately controlled heating source.

2.22**operable pressure**

pressure developed in a fully charged container conditioned at 21 °C for at least 24 h

2.23**operable pressure range**

pressure range corresponding to the pressures in the storage container at the specified minimum and maximum temperatures for which the extinguishing system is intended to be operable

2.24**operating devices**

mechanical, electrical or pneumatic devices involved in the operation of a system

2.25**operation**

(automatic) operation without human intervention

Note 1 to entry: Methods of automatic operation include, but are not limited to, heat, rate of temperature rise, smoke or pressure change.

2.26**operation**

(manual) operation of a system or its components through human action

2.27**owner's manual**

pamphlet containing the manufacturer's recommendations for proper inspection and operation, which is prepared and approved as a complimentary part of the extinguishing system

2.28**plenum**

volume of enclosed space between the grease filters and the portion of the hood above the grease filters in a hood and duct system

2.29

pre-engineered system

system that is tested in accordance with the limitations prescribed by the manufacturer for the maximum and minimum pipe lengths, accessories, number of fittings, number and types of nozzles, nozzle placement, types of fire risk and the maximum dimensions, volumes and areas of the appliances, hoods and ducts to be protected

Note 1 to entry: The hazards protected by these systems are specifically limited as to type and size by testing on actual fires.

Note 2 to entry: The limitations on hazards that are permitted to be protected by these systems and piping and nozzle configurations are those contained in the manufacturer's installation and maintenance manual.

2.30

pressure vessel

pressure cylinder

container that provides storage for the extinguishing agent and expellant gas

2.31

product

fire extinguishing system or any part thereof covered by the requirements of this International Standard

2.32

shut-off device

device that operates simultaneously with the extinguishing system to shut off fuel and power to the appliances protected by the system and other appliances required to be shut off upon operation of the system

2.33

signal

status indication communicated by electrical or other means

2.34

split-vat deep fat fryer

electric fryer that incorporates a divided partition which splits the fryer in sections

Note 1 to entry: Each split-vat fryer incorporates a separately controlled heating source.

2.35

tilt skillets

cooking devices which are intended to braise, simmer, sauté, or fry foods

2.36

braising pans

cooking devices which are intended to braise, simmer, sauté, or fry foods

3 Components

3.1 General

Only system components referenced or permitted in the manufacturer's installation and maintenance manual or alternative components that have been approved for use with the specific extinguishing system shall be used.

3.2 Detectors

Detectors shall be approved devices that are capable of detecting fire.

3.3 Discharge nozzles

3.3.1 Discharge nozzles shall be approved for their intended use.

3.3.2 Nozzles shall be provided with an internal strainer or a separate approved strainer located immediately up-stream of the nozzle.

3.3.3 Nozzles shall be constructed of brass, stainless-steel, or other corrosion-resistant materials, or be protected inside and out against corrosion.

3.3.4 Nozzles shall be made of non-combustible materials and shall withstand the expected fire exposure without deformation.

3.3.5 Nozzles shall be permanently marked for identification.

3.3.6 All discharge nozzles shall be provided with caps or other suitable devices to prevent the entrance of grease vapours, moisture, or other foreign materials into the piping.

3.3.7 The caps or other protection devices shall blow off, open or blow out upon agent discharge.

3.4 Operating devices

3.4.1 Operating devices shall be designed for the service they will encounter and shall not be rendered inoperative by, or be susceptible to, accidental operation.

3.4.2 Operating devices shall be designed to function properly through a temperature range from 0 °C to 49 °C, or marked to indicate the temperature limitations.

3.5 Manual actuators

3.5.1 Manual actuators shall not require a force of more than 178 N.

3.5.2 Manual actuators shall not require a movement of more than 356 mm to secure operation.

3.5.3 All manual actuators shall be provided with operating instructions. These instructions may include the use of pictographs, and shall have lettering at least 6 mm in height.

3.5.4 All remote manual operating devices shall be marked to identify the hazard against which they protect.

3.6 Shut-off devices

3.6.1 On activation of any cooking equipment or hood/duct fire extinguishing system, all sources of fuel and electric power that produce heat to all equipment protected by the system shall be shut off automatically.

3.6.2 Gas appliances not requiring protection but located under the same ventilation equipment shall also be shut off.

3.6.3 Exhaust fans and dampers are not required to be shut off on system actuation if the fire-extinguishing system has been tested under both zero and high-velocity flow conditions.