

ISO/TC 43/SC 2

Secretariat: DIN

Voting begins on:
2020-04-09

Voting terminates on:
2020-06-04

Acoustics — Determination and application of measurement uncertainties in building acoustics —

Part 2: Sound absorption

Acoustique — Détermination et application des incertitudes de mesure dans l'acoustique des bâtiments —

Partie 2: Absorption acoustique

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

ISO/CEN PARALLEL PROCESSING



Reference number
ISO/FDIS 12999-2:2020(E)

© ISO 2020

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Full standard:
<https://standards.iteh.ai/catalog/standards/sist/a7f7f069-2856-4048-a167-083368fb32b4/iso-fdis-12999-2>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword.....	iv
Introduction.....	v
1 Scope.....	1
2 Normative references.....	1
3 Terms and definitions.....	1
4 General approach.....	3
5 Standard uncertainties in one-third octave bands.....	3
6 Standard uncertainties for the practical sound absorption coefficient.....	4
7 Standard uncertainties of single number values.....	5
8 Reporting uncertainties.....	5
Bibliography.....	8

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/a7f7f069-2856-4048-a167-083368fb32b4/iso-fdis-12999-2>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 126, *Acoustic properties of building elements and of buildings*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

A list of all parts in the ISO 12999 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

An assessment of uncertainties that is comprehensible and close to reality is indispensable for reporting and applying measured sound absorption. Uncertainties should preferably be determined following the principles of ISO/IEC Guide 98-3.

ISO/IEC Guide 98-3 specifies a detailed procedure for the uncertainty evaluation that is based upon a complete mathematical model of the measurement procedure. At the current knowledge, it is impossible to formulate these models for sound absorption measurements according to ISO 354 and evaluations according to ISO 11654 or similar. To come to uncertainties all the same, the concept of reproducibility and repeatability is applied in this document. This concept offers the possibility to state the uncertainty of a method and of measurements carried out according to the method, based on the results of inter-laboratory measurements.

Observed uncertainties are probably caused by different laboratory designs. When the method of ISO 354 for measuring sound absorption is modified, other uncertainties than the ones given in this document can be applicable.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/a7f7f069-2856-4048-a167-083368fb32b4/iso-fdis-12999-2>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Full standard:
<https://standards.iteh.ai/catalog/standards/sist/a7f7f069-2856-4048-a167-083368fb32b4/iso-fdis-12999-2>

Acoustics — Determination and application of measurement uncertainties in building acoustics —

Part 2: Sound absorption

1 Scope

This document specifies how to calculate:

- the uncertainty of sound absorption coefficients and equivalent sound absorption areas measured according to ISO 354:2003;
- the uncertainty of the practical and weighted sound absorption coefficients determined according to ISO 11654;
- the object sound absorption coefficient according to ISO 20189; and
- the uncertainty of the single number rating determined according to EN 1793-1.

Furthermore, the use of uncertainties in reporting measured or weighted sound absorption coefficients is explained.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1

measurand

quantity intended to be measured

EXAMPLE The sound absorption coefficient of a particular test specimen measured according to ISO 354.

[SOURCE: ISO/IEC Guide 99:2007, 2.3, modified — The Notes to entry have been deleted and the example has been added.]

3.2

measurement result

value attributed to a *measurand* (3.1), obtained by following the complete set of instructions given in a measurement procedure

Note 1 to entry: The measurement result is the sound absorption coefficient in one-third octave bands according to the procedure of ISO 354 or a (single number) value according to a rating procedure of EN 1793-1 or ISO 11654.

[SOURCE: ISO 12999-1:2014, 3.2, modified — Note 1 to entry has been changed.]

3.3 uncertainty

parameter, associated with the result of a measurement, that characterizes the dispersion of the values that can reasonably be attributed to the *measurand* (3.1)

[SOURCE: ISO/IEC Guide 98-3:2008, 2.2.3, modified — In the term, "(of measurement)" has been removed, and the Notes have been deleted.]

3.4 standard uncertainty

u
uncertainty (3.3) of the result of a measurement expressed as a standard deviation

Note 1 to entry: The standard uncertainty, u , is the *reproducibility standard deviation* (3.8), σ_R , when evaluating the uncertainty of a measurement under *reproducibility conditions* (3.7).

Note 2 to entry: The standard uncertainty, u , is the *repeatability standard deviation* (3.10), σ_r , when evaluating the uncertainty of a measurement under *repeatability conditions* (3.9).

[SOURCE: ISO/IEC Guide 98-3:2008, 2.3.1, modified — The symbol " u " and the Notes to entry have been added.]

3.5 expanded uncertainty

U
quantity defining an interval about the result of a measurement that may be expected to encompass a large fraction of the distribution of values that can reasonably be attributed to the *measurand* (3.1)

[SOURCE: ISO/IEC Guide 98-3:2008, 2.3.5, modified — The symbol " U " has been added and the Notes have been deleted.]

3.6 coverage factor

k
numerical factor used as a multiplier of the combined *standard uncertainty* (3.4) in order to obtain an *expanded uncertainty* (3.5)

[SOURCE: ISO/IEC Guide 98-3:2008, 2.3.6, modified — The symbol " k " has been added and the Note has been deleted.]

3.7 reproducibility condition of measurement reproducibility condition

condition of measurement that includes different laboratories, operators, measuring systems, and replicate measurements on the same or similar objects

[SOURCE: ISO/IEC Guide 99:2007, 2.24, modified — The Notes have been deleted. In the definition, "out of a set of conditions" has been removed and "locations" has been replaced by "laboratories".]

3.8 reproducibility standard deviation

σ_R
standard deviation of *measurement results* (3.2) obtained under *reproducibility conditions* (3.7)

[SOURCE: ISO 5725-1:1994, 3.19, modified — The Notes have been deleted. In the definition, "test" has been replaced by "measurement".]

3.9 repeatability condition of measurement repeatability condition

condition of measurement that includes the same measurement procedure, same operators, same measuring system, same location (laboratory or usual building), and replicate measurements on the same object over a short period of time

[SOURCE: ISO/IEC Guide 99:2007, 2.20, modified — The Notes have been deleted. In the definition, “out of a set of conditions” and “same operating conditions” have been removed and “(laboratory or usual building)” has been added after “location”.]

3.10 repeatability standard deviation

σ_r
standard deviation of *measurement results* (3.2) obtained under *repeatability conditions* (3.9)

[SOURCE: ISO 5725-1:1994, 3.15, modified — The Notes have been deleted. In the definition, “test” has been replaced by “measurement”.]

4 General approach

If uncertainty data are available for specific specimens, test setups or measurement/evaluation standards, e.g. from an inter-laboratory test, these data shall be used. If no such data are available, the uncertainties given in [Clauses 5, 6 and 7](#) shall be used. In [Clauses 5, 6 and 7](#), standard uncertainties, u , are estimated by reproducibility standard deviations, σ_R , or by repeatability standard deviations, σ_r . The numbers given are derived from inter-laboratory measurements according to ISO 5725-1 and ISO 5725-2 with different types of test specimens including suspended ceilings, mineral wool, foams^{[1][2][3]}.

5 Standard uncertainties in one-third octave bands

The reproducibility standard deviation of sound absorption coefficients measured according to ISO 354 in one-third octave bands shall be calculated using [Formula \(1\)](#):

$$\sigma_R = m\alpha_s + n \quad (1)$$

where

α_s is the sound absorption coefficient measured in accordance with ISO 354;

m, n are frequency-dependent numerical constants given in [Table 1](#).

Table 1 — Values m and n to be used in [Formula \(1\)](#)

One-third octave midband frequency Hz	m	n
63	0,450	0,015
80	0,330	0,015
100	0,240	0,015
125	0,180	0,015
160	0,140	0,015
200	0,110	0,015
250	0,090	0,015
315	0,075	0,015
400	0,060	0,015