



~~Designation: D 3868-04~~ **Designation: D 3868 – 09**

Standard Test Method for Fluoride Ions in Brackish Water, Seawater, and Brines¹

This standard is issued under the fixed designation D 3868; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope*

1.1 This test method² covers the determination of soluble fluoride ions in brackish water, seawater and brines by use of a fluoride selective electrode.

1.2 Samples containing from 1.0 to 25 mg/L can be analyzed by this test method.

1.3

1.3 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*³

D 1129 Terminology Relating to Water

D 1193

D 1193 Specification for Reagent Water

D 2777 Practice for Determination of Precision and Bias of Applicable Test Methods of Committee D19 on Water

D 3370 Practices for Sampling Water from Closed Conduits

D 5847

D 5847 Practice for Writing Quality Control Specifications for Standard Test Methods for Water Analysis

3. Terminology

3.1 *Definitions:* —For definitions of terms used in this test method, refer to Terminology D 1129.

4. Summary of Test Method

4.1 A fluoride selective electrode, reference electrode, and millivoltmeter are used to determine fluoride in brine samples by a standard addition method.

4.2 The fluoride selective electrode consists of a lanthanum fluoride crystal that develops an electrode potential corresponding to the level of fluoride ion in solution.

5. Significance and Use

5.1 Identification of a brackish water, seawater, or brine is determined by comparison of the concentrations of their dissolved constituents. The results are used to evaluate the origin of the water, determine if it is a possible pollutant, or if it is related to a potential source of a valuable mineral. For example, in geochemical studies some correlation data indicate that fluoride is an indirect indicator of the presence of lithium.

6. Interferences

6.1 Metal ions such as aluminum and iron (III) interfere with the fluoride determination by forming complexes with fluoride

¹ This test method is under the jurisdiction of ASTM Committee D19 on Water and is the direct responsibility of Subcommittee D19.05 on Inorganic Constituents in Water.

Current edition approved March 1, 2004; May 15, 2009. Published April 2004; May 2009. Originally approved in 1979. Last previous edition approved in 1999 as D 3868-95 (1999); D 3868 – 04.

² Additional information is contained in the following references: Hoke, S. H., Fletcher, G. E., and Collins, A. G., “Fluoride and Iodide Selective Electrodes Applied to Oilfield Brine Analysis,” U.S. Department of Energy, Report of Investigations, BETC/RI-78/7.

Rix, C. J., Bond, A. M., and Smith, J. D., “District Determination of Fluoride in Sea Water with a Fluoride Selective Ion Electrode by a Method of Standard Additions,” *Analytical Chemistry*, Vol 48, 1976, p. 1236.

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard’s Document Summary page on the ASTM website.

*A Summary of Changes section appears at the end of this standard.

ions. The buffer solution contains a complexing agent that preferentially complexes these metal ions. This solution also contains a pH buffer to reduce electrode interference from hydroxide ions and to prevent the formation of HF. Sodium chloride is added as ionic strength adjustor. Increasing amounts of aluminum, iron (III), and borate ions were added to 1.5 mg/L fluoride solutions and were found not to interfere up to 5, 350, and 250 mg/L (as boron), respectively.

7. Apparatus

7.1 *Millivoltmeter* (accurate to ± 0.1 mV), specific ion meter.

NOTE 1—A specific ion meter that directly reads concentration may be used.

7.2 *Fluoride Selective Electrode*, reference electrode.

7.3 *Microlitre Pipets*.

8. Reagents

8.1 *Purity of Reagents*—Reagent grade chemicals shall be used in all tests. Unless otherwise indicated, it is intended that all reagents shall conform to the specification of the Committee on Analytical Reagents of the American Chemical Society, where such specifications are available.⁴ Other grades may be used, provided it is first ascertained that the reagent is of sufficiently high purity to permit its use without lessening the accuracy of the determination.

8.2 *Purity of Water*—Unless otherwise indicated, reference to water shall be understood to mean reagent water conforming to Specification D 1193, Type I. Other reagent water types may be used provided it is first ascertained that the water is of sufficiently high purity to permit its use without adversely affecting the precision and bias of the test method. Type III water was specified at the time of round robin testing of this test method.

8.3 *Buffer Solution*⁵—Dissolve 58 g of NaCl, 4 g of CDTA complexing agent (cyclohexylene dinitrilo tetraacetic acid), and 57 mL of glacial acetic acid in 500 mL of water. Slowly add NaOH solution (200 g/L) to adjust the pH of the solution to 5.0 to 5.5 while cooling in a water bath. Transfer solution to a 1-L volumetric flask and dilute to the mark with water.

8.4 *Fluoride Solution, Standard* (1 mL = 2 mg F⁻)—Dissolve 4.420 g of NaF in water and dilute to 1 L and store in a polyethylene bottle. This solution will contain 2000 mg of F⁻/L. Alternatively, certified fluoride stock solutions are commercially available through chemical supply vendors and may be used.

9. Sampling

9.1 Collect the sample in accordance with Practices D 3370.

10. Procedure

10.1 Pipet an aliquot of a brine sample containing 0.01 to 0.03 mg of fluoride into a 125-mL polyethylene beaker and if necessary add water to make the total volume equal 40 mL. Add 40 mL of buffer solution. Place electrodes in the solution to a depth of 30 mm. Stir solution for 5 min or until equilibrium is reached. Stop the stirrer and record the potential. Add 20 μ L of the standard fluoride solution, stir solution for 3 min, and record the second potential under quiet conditions. Repeat the above step for the second addition.

11. Calculation

11.1 Calculate the slope of the electrode as follows:

$$\text{Slope} = \frac{E_B - E_A}{\log [B] - \log [A]} \quad (1)$$

where:

A and B = two fluoride solutions of known concentration, mg/L,

E_A = electrode potential of Solution A mV, and

E_B = electrode potential of Solution B, mV.

NOTE 2—The slope of the electrode should meet the manufacturer's specifications.

11.2 Calculate the concentration of fluoride in the sample as follows:²

$$A = \text{mg/L} = \frac{X_f}{\text{antilog} \left(\frac{\Delta E}{\text{slope}} \right) - 1} \times 1000 \quad (2)$$

⁴ *Reagent Chemicals, American Chemical Society Specifications*, American Chemical Society, Washington, DC. For suggestions on the testing of reagents not listed by the American Chemical Society, see *Analar Standards for Laboratory Chemicals*, BDH Ltd., Poole, Dorset, U.K., and the *United States Pharmacopeia and National Formulary*, U.S. Pharmaceutical Convention, Inc. (USPC), Rockville, MD.

⁵ Also available as TISAB II from Orion Research Inc.