

SLOVENSKI STANDARD oSIST prEN ISO 11146-2:2020

01-julij-2020

Laserji in laserska oprema - Preskusne metode za širine laserskega žarka, kota divergence in faktorja širjenja žarkov - 2. del: Osnovni astigmatični žarki (ISO/DIS 11146-2:2020)

Lasers and laser-related equipment - Test methods for laser beam widths, divergence angles and beam propagation ratios - Part 2: General astigmatic beams (ISO/DIS 11146-2:2020)

Laser und Laseranlagen - Prüfverfahren für Laserstrahlabmessungen, Divergenzwinkel und Beugungsmaßzahlen - Teil 2: Allgemein astigmatische Strahlen (ISO/DIS 11146-2:2020)

oSIST prEN ISO 11146-2:2020

Lasers et équipements associés aux lasers - Méthodes d'essai des largeurs du faisceau, angles de divergence et facteurs de limite de diffraction - Partie 2: Faisceaux astigmatiques générau (ISO/DIS 11146-2:2020)

Ta slovenski standard je istoveten z: prEN ISO 11146-2

ICS:

31.260

Optoelektronika, laserska oprema

Optoelectronics. Laser equipment

oSIST prEN ISO 11146-2:2020

2003-01.Slovenski inštitut za standardizacijo. Razmnoževanje celote ali delov tega standarda ni dovoljeno.

en

iTeh STANDARD PREVIEW (standards.iteh.ai)

oSIST prEN ISO 11146-2:2020 https://standards.iteh.ai/catalog/standards/sist/8a792e63-2651-404d-8508cdbbb2f0aaa1/osist-pren-iso-11146-2-2020

DRAFT INTERNATIONAL STANDARD ISO/DIS 11146-2

ISO/TC 172/SC 9

Voting begins on: **2020-04-21**

Secretariat: **DIN**

Voting terminates on: **2020-07-14**

Lasers and laser-related equipment — Test methods for laser beam widths, divergence angles and beam propagation ratios —

Part 2: **General astigmatic beams**

Lasers et équipements associés aux lasers — Méthodes d'essai des largeurs du faisceau, angles de divergence et facteurs de limite de diffraction —

Partie 2: Faisceaux astigmatiques généraux

ICS: 31.260

iTeh STANDARD PREVIEW (standards.iteh.ai)

oSIST prEN ISO 11146-2:2020 https://standards.iteh.ai/catalog/standards/sist/8a792e63-2651-404d-8508cdbbb2f0aaa1/osist-pren-iso-11146-2-2020

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION. This document is circulated as received from the committee secretariat.

ISO/CEN PARALLEL PROCESSING



Reference number ISO/DIS 11146-2:2020(E)

iTeh STANDARD PREVIEW (standards.iteh.ai)

oSIST prEN ISO 11146-2:2020 https://standards.iteh.ai/catalog/standards/sist/8a792e63-2651-404d-8508cdbbb2f0aaa1/osist-pren-iso-11146-2-2020



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office CP 401 • Ch. de Blandonnet 8 CH-1214 Vernier, Geneva Phone: +41 22 749 01 11 Fax: +41 22 749 09 47 Email: copyright@iso.org Website: www.iso.org

Published in Switzerland

Page

Contents

Fore	word	iv
Intro	oduction	v
1	Scope	1
2	Normative references	1
3	Terms and definitions	
4	Coordinate system	5
5	Test principles5.1General5.2Spatial second order moments of the Wigner distribution5.3Second order moments of the Wigner distribution5.4Derived quantities	5 5 5
6	Measurement arrangement and test equipment6.1General6.2Preparation6.3Control of environment6.4Detector system6.5Beam-forming optics and optical attenuators	
7	Measurement of the second order momentsPREVIEW7.1General7.2Measurement of the second order moments of power density distributions7.3Measurement of all second order moments of the Wigner distribution	7
8	Determination of effective beam propagation ratio	
9	Determination of intrinsic astigmatismds/sist/8a792e63-2651-404d-8508-	
10	cdbbb2f0aaa1/osist-pren-iso-11146-2-2020 Determination of the twist parameter	
11	Test report	
Bibli	ography	

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 172, *Optics and photonics,* Subcommittee SC 9, *Laser and electro-optical systems.* <u>oSIST prEN ISO 11146-2:2020</u> https://standards.iteh.ai/catalog/standards/sist/8a792e63-2651-404d-8508-

This second edition cancels and replaces the first edition (ISO2020146-2:2005), which has been technically revised.

The main changes compared to the previous edition are as follows:

— The terms and definitions were harmonized with the new ISO 11145.

A list of all parts in the ISO 11146 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at <u>www.iso.org/members.html</u>.

Introduction

The propagation properties of laser beams can be characterized by ten independent parameters when applying the method of second order moments (see ISO/TR 11146-3). Most laser beams need few parameters for a complete description due to their higher symmetry. Lasers emit beams which are stigmatic or simple astigmatic due to their resonator design.

Part 1 of ISO 11146 describes the measurement methods for stigmatic and simple astigmatic beams while this document deals with the measurement procedures for general astigmatic beams. This document is applicable to beams of unknown type. Beam characterization, based on the method of second order moments as described in Part 1 and this document, is only valid within the paraxial approximation.

The theoretical description of beam characterization and propagation as well as the classification of laser beams is given in ISO/TR 11146-3, which is an informative Technical Report. The procedures for background subtraction and offset correction are also given in ISO/TR 11146-3.

In ISO 11146, the second order moments of the power (energy) density distribution function are used for the determination of beam widths. If problems are experienced in the direct measurements of these quantities, other indirect methods of measurement of second order moments may be used as long as comparable results are achievable.

In ISO/TR 11146-3, three alternative methods for beam width measurement and their correlation with the method used in this document are described. These methods are:

- variable aperture intend; STANDARD PREVIEW
- moving knife-edge method; (standards.iteh.ai)
- moving slit method.
 <u>oSIST prEN ISO 11146-2:2020</u>

https://standards.iteh.ai/catalog/standards/sist/8a792e63-2651-404d-8508-The problem of the dependence of the measuring result on the truncation limits of the integration area was investigated and evaluated by an international interlaboratory experiment carried out in 1997. The results of this interlaboratory testing were taken into consideration in this document.

iTeh STANDARD PREVIEW (standards.iteh.ai)

oSIST prEN ISO 11146-2:2020 https://standards.iteh.ai/catalog/standards/sist/8a792e63-2651-404d-8508cdbbb2f0aaa1/osist-pren-iso-11146-2-2020

Lasers and laser-related equipment — Test methods for laser beam widths, divergence angles and beam propagation ratios —

Part 2: **General astigmatic beams**

1 Scope

This document specifies methods for measuring beam widths (diameter), divergence angles and beam propagation ratios of laser beams. This document is applicable to general astigmatic beams or unknown types of beams. For stigmatic and simple astigmatic beams, ISO 11146-1 is applicable.

Within this document, the description of laser beams is accomplished by means of the second order moments of the Wigner distribution rather than physical quantities such as beam widths and divergence angles. However these physical quantities are closely related to the second order moments of the Wigner distribution. In ISO/TR 11146-3, formulae are given to calculate all relevant physical quantities from the measured second order moments. **PREVIEW**

Normative references (standards.iteh.ai) 2

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 11145, Optics and photonics — Lasers and laser-related equipment — Vocabulary and symbols

ISO/DIS 11146-1:2020, Lasers and laser-related equipment — Test methods for laser beam widths, divergence angles and beam propagation ratios — Part 1: Stigmatic and simple astigmatic beams

EN 61040:1992, Power and energy measuring detectors, instruments and equipment for laser radiation

Terms and definitions 3

For the purposes of this document, the terms and definitions given in ISO 11145, ISO 11146-1, EN 61040:1992 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <u>https://www.iso.org/obp</u>
- IEC Electropedia: available at <u>http://www.electropedia.org/</u>

Note 1 to entry The *x*-, *y*- and *z*-axes in the following definitions refer to the laboratory system (as described in <u>Clause 4</u>). Here and throughout this document the term "power density distribution" refers to continuous wave sources. It might be replaced by "energy density distribution" in case of pulsed sources.

3.1 generalized beam diameter $d_{\rm g}$

 m^{5} easure of the extent of the power density distribution of a beam in a cross-section at an axial location z, derived from the centred second order moments by

$$d_{\rm g} = 2\sqrt{2}\sqrt{\left\langle x^2 \right\rangle + \left\langle y^2 \right\rangle} \tag{1}$$

Note 1 to entry: Note 1to entry: This definition is similar to the beam diameter defined in ISO 11145 or ISO 11146-1. But in this context the definition is not restricted to circular power density distributions.

3.2

generalized beam waist location

*z*_{0,g}

position where the generalized beam diameter reaches its minimum value along the axis of propagation

3.3

generalized Rayleigh length

Z_{R,g}

distance along the beam axis from the generalized beam waist where the generalized beam diameter is a factor of $\sqrt{2}$ larger than the generalized beam waist diameter

3.4

Wigner distribution

phase space distribution representing a laser beam in a transverse plane at location z

Note 1 to entry: The Wigner distribution is a function of two spatial and two angular coordinates, giving the amount of beam power propagating through the point (x, y) in the direction (Θ_x, Θ_y) .

3.5

oSIST prEN ISO 11146-2:2020

subset of the first order moments, which can be directly obtained from measured power density distribution by

$$\langle x \rangle(z) = \frac{\int_{-\infty}^{\infty} \int_{-\infty}^{\infty} E(x, y, z) x \, dx \, dy}{\int_{-\infty}^{\infty} \int_{-\infty}^{\infty} \int_{-\infty}^{\infty} E(x, y, z) dx \, dy}$$
(2)

and

$$\langle y \rangle(z) = \frac{\int_{-\infty}^{\infty} \int_{-\infty}^{\infty} E(x, y, z) y \, dx \, dy}{\int_{-\infty}^{\infty} \int_{-\infty}^{\infty} E(x, y, z) dx \, dy}$$
(3)

where E(x,y,z) is the power density distribution at the specific plane z = constant

3.6 second order moments of the Wigner distribution $\langle x^2 \rangle$, $\langle y^2 \rangle$, $\langle xy \rangle$, $\langle \Theta_x^2 \rangle$, $\langle \Theta_y^2 \rangle$, $\langle \Theta_x \Theta_y \rangle$, $\langle x\Theta_x \rangle$, $\langle x\Theta_y \rangle$, $\langle y\Theta_x \rangle$, $\langle y\Theta_y \rangle$

ten second order moments of the Wigner distribution of the beam at location z

Note 1 to entry: The ten second order moments contain information on the following physical beam properties: beam size and orientation, divergence angles and their orientation, radii of curvature of the phase paraboloid and their orientation and the twist parameter. Details on these relations are given in ISO/TR 11146-3.

Note 2 to entry: In ISO 11146-1, the three spatial second order moments are defined as σ_x^2 , σ_y^2 and σ_{xy}^2 . In this document and ISO/TR 11146-3, the angular brackets are used to emphasize the coordinates of the moments. This means that $\sigma_x^2 = \langle x^2 \rangle$, $\sigma_y^2 = \langle y^2 \rangle$ and $\sigma_{xy}^2 = \langle xy \rangle$.

Note 3 to entry: Three angular moments $\langle \Theta_x^2 \rangle$, $\langle \Theta_y^2 \rangle$ and $\langle \Theta_x \Theta_y \rangle$ are independent of *z*. The other seven second order moments are, in general, functions of *z*.

3.7 spatial second order moments of the Wigner distribution

 $\langle x^2 \rangle, \langle y^2 \rangle, \langle xy \rangle$

subset of the second order moments, which can be directly obtained from measured power density distribution by

$$\langle x^{2} \rangle(z) = \frac{\int_{-\infty}^{\infty} \int_{-\infty}^{\infty} E(x, y, z) (x - \langle x \rangle)^{2} dx \, dy \text{DARD PREVIEW}}{\int_{-\infty}^{\infty} \int_{-\infty}^{\infty} E(x, y, z) dx \, dy}$$
(4)
$$\langle x^{2} \rangle(z) = \frac{\int_{-\infty}^{\infty} \int_{-\infty}^{\infty} E(x, y, z) dx \, dy}{\int_{-\infty}^{\infty} \int_{-\infty}^{\infty} E(x, y, z) dx \, dy} z i (z + z) (z + z)$$

and

$$\langle xy \rangle(z) = \frac{\int_{-\infty}^{\infty} \int_{-\infty}^{\infty} E(x, y, z)(x - \langle x \rangle)(y - \langle y \rangle) dx dy}{\int_{-\infty}^{\infty} \int_{-\infty}^{\infty} \int_{-\infty}^{\infty} E(x, y, z) dx dy}$$
(6)

3.8 beam matrix

symmetric and positive definite 4×4 matrix containing all ten second order moments of the Wigner distribution and its elements and given by

$$\boldsymbol{P} = \begin{bmatrix} \left\langle x^{2} \right\rangle & \left\langle xy \right\rangle & \left\langle x\Theta_{x} \right\rangle & \left\langle x\Theta_{y} \right\rangle \\ \left\langle xy \right\rangle & \left\langle y^{2} \right\rangle & \left\langle y\Theta_{x} \right\rangle & \left\langle y\Theta_{y} \right\rangle \\ \left\langle x\Theta_{x} \right\rangle & \left\langle y\Theta_{x} \right\rangle & \left\langle \Theta_{x}^{2} \right\rangle & \left\langle \Theta_{x}\Theta_{y} \right\rangle \\ \left\langle x\Theta_{y} \right\rangle & \left\langle y\Theta_{y} \right\rangle & \left\langle \Theta_{x}\Theta_{y} \right\rangle & \left\langle \Theta_{y}^{2} \right\rangle \end{bmatrix}$$
(7)