



SLOVENSKI STANDARD
SIST EN 891:2023

01-maj-2023

Nadomešča:
SIST EN 891:2005

Kemikalije, ki se uporabljajo za pripravo pitne vode - Železov (III) klorid sulfat

Chemicals used for treatment of water intended for human consumption - Iron (III) chloride sulfate

Produkte zur Aufbereitung von Wasser für den menschlichen Gebrauch - Eisen (III)chloridsulfat

Produits chimiques utilisés pour le traitement de l'eau destinée à la consommation humaine - Chlorosulfate de fer (III)

Ta slovenski standard je istoveten z: EN 891:2023

ICS:

13.060.20	Pitna voda	Drinking water
71.100.80	Kemikalije za čiščenje vode	Chemicals for purification of water

SIST EN 891:2023

en,fr,de

EUROPEAN STANDARD

EN 891

NORME EUROPÉENNE

EUROPÄISCHE NORM

February 2023

ICS 71.100.80

Supersedes EN 891:2004

English Version

Chemicals used for treatment of water intended for human consumption - Iron (III) chloride sulfate

Produits chimiques utilisés pour le traitement de l'eau destinée à la consommation humaine - Chlorosulfate de fer (III)

Produkte zur Aufbereitung von Wasser für den menschlichen Gebrauch - Eisen(III)chloridsulfat

This European Standard was approved by CEN on 25 December 2022.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.

<https://standards.iteh.ai/catalog/standards/sist/e5165418-0d60-487d-8f96-921e5bbdbbca/sist-en-891-2023>



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	4
Introduction	5
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions	6
4 Description	6
4.1 Identification	6
4.1.1 Chemical name	6
4.1.2 Synonym or common names	6
4.1.3 Relative molecular mass.....	6
4.1.4 Empirical formula	6
4.1.5 Chemical formula	6
4.1.6 CAS Registry Number	7
4.1.7 EINECS reference	7
4.2 Commercial form.....	7
4.3 Physical properties.....	7
4.3.1 Appearance.....	7
4.3.2 Density	7
4.3.3 Solubility (in water)	7
4.3.4 Vapour pressure	7
4.3.5 Boiling point at 100 kPa	7
4.3.6 Freezing point.....	7
4.3.7 Specific heat	7
4.3.8 Viscosity (dynamic).....	7
4.3.9 Critical temperature	7
4.3.10 Critical pressure	7
4.3.11 Physical hardness	8
4.4 Chemical properties.....	8
5 Purity criteria	8
5.1 General.....	8
5.2 Composition of commercial product.....	8
5.3 The grade of the product	8
5.4 The type of the product.....	9
6 Test methods	9
6.1 Sampling.....	9
6.2 Analyses.....	9
7 Labelling - Transportation - Storage	9
7.1 Means of delivery	9
7.2 Risk and safety labelling according to the EU Directives.....	9
7.3 Transportation regulations and labelling.....	10
7.4 Marking.....	11
7.5 Storage	11
7.5.1 Long term stability.....	11
7.5.2 Storage incompatibilities	11

Annex A (informative) General information on iron (III) chloride sulfate	12
A.1 Origin	12
A.1.1 Raw materials	12
A.1.2 Manufacturing process	12
A.2 Quality of commercial product	12
A.3 Use	14
A.3.1 Function	14
A.3.2 Form in which it is used	14
A.3.3 Treatment dose	14
A.3.4 Means of application	14
A.3.5 Secondary effects	14
A.3.6 Removal of excess product	14
Annex B (normative) General rules relating to safety	15
B.1 Rules for safe handling and use	15
B.2 Emergency procedures	15
B.2.1 First aid	15
B.2.2 Spillage	15
B.2.3 Fire	15
Bibliography	16

[SIST EN 891:2023](https://standards.iteh.ai/catalog/standards/sist/e5165418-0d60-487d-8f96-921e5bbdbbca/sist-en-891-2023)

<https://standards.iteh.ai/catalog/standards/sist/e5165418-0d60-487d-8f96-921e5bbdbbca/sist-en-891-2023>

EN 891:2023 (E)**European foreword**

This document (EN 891:2023) has been prepared by Technical Committee CEN/TC 164 “Water supply”, the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2023, and conflicting national standards shall be withdrawn at the latest by August 2023.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 891:2004.

EN 891:2023 includes the following significant technical changes with respect to EN 891:2004:

- removal of the analytical methods from this standard and addition of reference to EN 17215 as analytical method standard;
- update of the information of risk and safety labelling of the product to comply with the new regulations (see 7.2 and [2]);
- update of the information related to Drinking Water Directive.

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

Introduction

In respect of potential adverse effects on the quality of water intended for human consumption, caused by the product covered by this document:

- a) this document provides no information as to whether the product may be used without restriction in any of the Member States of the EU or EFTA;
- b) it should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or the characteristics of this product remain in force.

NOTE Conformity with this document does not confer or imply acceptance or approval of the product in any of the Member States of the EU or EFTA. The use of the product covered by this document is subject to regulation or control by National Authorities.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 891:2023](https://standards.iteh.ai/catalog/standards/sist/e5165418-0d60-487d-8f96-921e5bbdbbca/sist-en-891-2023)

<https://standards.iteh.ai/catalog/standards/sist/e5165418-0d60-487d-8f96-921e5bbdbbca/sist-en-891-2023>

1 Scope

This document is applicable to iron (III) chloride sulfate used for treatment of water intended for human consumption. It describes the characteristics of iron (III) chloride sulfate and specifies the requirements and the corresponding analytical methods for iron (III) chloride sulfate and gives information on its use in water treatment. It also determines the rules relating to safe handling and use of iron (III) chloride sulfate.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 17215, *Chemicals used for treatment of water intended for human consumption — Iron-based coagulants — Analytical methods*

3 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

4 Description

4.1 Identification

4.1.1 Chemical name

Iron (III) chloride sulfate solution.

4.1.2 Synonym or common names

Ferric chloride sulfate, ferric chloro sulfate, chlorinated copperas.

4.1.3 Relative molecular mass

187,36 g/mol.

4.1.4 Empirical formula

FeClSO_4 .

4.1.5 Chemical formula

FeClSO_4 .

4.1.6 CAS Registry Number¹⁾

12410-14-9.

4.1.7 EINECS reference²⁾

235-649-0.

4.2 Commercial form

Iron (III) chloride sulfate is available as a solution.

4.3 Physical properties

4.3.1 Appearance

Iron (III) chloride sulfate is a dark brown solution.

4.3.2 Density

The density of iron (III) chloride sulfate solution is approximately 1,5 g/cm³ at 20 °C.

4.3.3 Solubility (in water)

Iron (III) chloride sulfate is dilutable (see A.3.2).

4.3.4 Vapour pressure

Not applicable.

4.3.5 Boiling point at 100 kPa³⁾

102 °C.

4.3.6 Freezing point

The freezing point of an aqueous solution is lower than -10 °C.

4.3.7 Specific heat

Not known.

4.3.8 Viscosity (dynamic)

For the iron (III) chloride sulfate the viscosity is approximately 70 mPa·s at 10 °C.

4.3.9 Critical temperature

Not applicable.

4.3.10 Critical pressure

Not applicable.

¹⁾ Chemical Abstracts Service Registry Number.

²⁾ European Inventory of Existing Commercial Chemical Substances.

³⁾ 100 kPa = 1 bar.

EN 891:2023 (E)

4.3.11 Physical hardness

Not applicable.

4.4 Chemical properties

The solutions of iron (III) chloride sulfate are acidic and corrosive.

5 Purity criteria

5.1 General

This document specifies the minimum purity requirements for iron (III) chloride sulfate used for the treatment of water intended for human consumption. Limits are given for impurities commonly present in the product. Depending on the raw material and the manufacturing process other impurities can be present and, if so, this shall be notified to the user and when necessary to relevant authorities.

NOTE Users of this product can check the national regulations in order to clarify whether it is of appropriate purity for treatment of water intended for human consumption, taking into account raw water quality, required dosage, contents of other impurities and additives used in the product not stated in this product standard.

Limits have been given for impurities and chemical parameters where these are likely to be present in significant quantities from the current production process and raw materials. If the production process or raw materials lead to significant quantities of impurities, by-products, or additives being present, this shall be notified to the user.

5.2 Composition of commercial product

The product typically contains not less than a mass fraction of 37 % of FeClSO_4 (i.e. not less than a mass fraction of 11 % of Fe) and shall be within ± 3 % of the manufacturer's declared values.

The solution will typically contain 0 % to 1 % (mass fraction) free acid.

5.3 The grade of the product

The product shall conform to the requirements specified in Table 1.

The concentration limits refer to Fe (III).

Table 1 — Limit values for the grades 1, 2 and 3

Limit values in mass fraction of Fe (III) content in %

Parameter		Limit		
		Grade 1	Grade 2	Grade 3
Manganese	max.	0,5	1	2
Iron (II) ^a	max.	2,5	2,5	2,5
Insoluble matters ^b	max.	0,2	0,2	0,2

^a Fe (II) has a lower coagulant efficiency compared to Fe (III). Also hydrolysis of Fe (II) starts at pH value 8, and therefore Fe (II) can remain into the water at lower pH values.

^b An excess of insoluble matters indicates the presence of foreign matter. Iron is a component of the product will usually be removed in the treatment process.