
Horology — Procedure for evaluating the accuracy of quartz watches

*Horlogerie — Procédure d'évaluation de la précision des montres à
quartz*

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO 10553:2018](https://standards.iteh.ai/catalog/standards/sist/c735d4d4-9805-4b5f-ac17-a5a2e908a940/iso-10553-2018)

[https://standards.iteh.ai/catalog/standards/sist/c735d4d4-9805-4b5f-ac17-
a5a2e908a940/iso-10553-2018](https://standards.iteh.ai/catalog/standards/sist/c735d4d4-9805-4b5f-ac17-a5a2e908a940/iso-10553-2018)



iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 10553:2018

<https://standards.iteh.ai/catalog/standards/sist/c735d4d4-9805-4b5f-ac17-a5a2e908a940/iso-10553-2018>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2018

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	iv
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Symbols and units	1
5 Practical factors affecting accuracy	2
5.1 General	2
5.2 Accuracy	2
5.3 Influence of temperature on accuracy	2
5.4 Accidents or abnormal environment	2
6 Types of measurement	2
7 Test methods	3
7.1 General test conditions	3
7.2 Ageing test programme	3
7.3 Temperature simulation test programme	4
7.4 Uncertainty of measurement	5
8 Calculation of accuracy	6
8.1 General	6
8.2 Calculation of the effect of ageing on accuracy	6
9 Relationship between the calculated accuracy and the accuracy classification indicated	8
10 Indication of the accuracy classification	8
11 Reliability	8
Annex A (normative) Statistical evaluation of accuracy	9
Annex B (informative) Evaluation of coefficients α and c from the differences of rates	12
Annex C (informative) Reliability	14
Bibliography	15

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html. (standards.itech.ai)

This document was prepared by Technical Committee ISO/TC 114, *Horology*, Subcommittee SC 11, *Indication of accuracy*.
ISO 10553:2018

<https://standards.itech.ai/catalog/standards/sist/c735d4d4-9805-4b5f-ac17-5e438e4f1633/iso-10553-2018-edition-1>

This second edition cancels and replaces the first edition (ISO 10553:2003), which has been technically revised with the following changes:

- Addition of ISO 16269-6:2014 and deletion of ISO 3207:1975 in [Clause 2](#);
- Deletion of the **indicated accuracy classification** definition;
- Adaptation of the Normal and Abnormal distributions ([A.4.1](#) and [A.4.2](#)) according to ISO 16269-6:2014;
- Addition of keys after [Figures B.1](#) and [B.2](#).

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Horology — Procedure for evaluating the accuracy of quartz watches

1 Scope

This document specifies the procedure for evaluating the accuracy of quartz watches, individually and by lots (see [Annex A](#) which presents the methods for statistical evaluation of accuracy by lot), and the relationship between the accuracy tested and the accuracy classification given by the manufacturer.

It applies to quartz watches having accompanying documents on which the accuracy classification is indicated.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3158, *Timekeeping instruments — Symbolization of control positions*

ISO 16269-6:2014, *Statistical interpretation of data — Part 6: Determination of statistical tolerance intervals*

3 Terms and definitions

ISO 10553:2018

<https://standards.iteh.ai/catalog/standards/sist/c735d4d4-9805-4b5f-ac17->

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1

quartz watch with accuracy indication

quartz watch, the accuracy classification of which is indicated in its accompanying documents, such as operating instructions, prospectus and, labels

3.2

display

accuracy classification indications showing the hours and minutes and having at least one component displaying the seconds to enable the state to be checked

Note 1 to entry: The accuracy classification is expressed in seconds.

4 Symbols and units

The symbols and units for ageing, temperature simulation and accuracy are given in [Table 1](#).

Table 1 — Symbols and units of measurement

Symbol	Unit	Term
Ageing		
α	d ⁻¹	coefficient of the logarithmic function applied
c	s/d	coefficient of the logarithmic function applied
t_d	d	time interval
M_B	s/d	average daily rate for the first three days of the ageing test (stage II)
M_M	s/d	average daily rate for the middle three days of the ageing test (stage V)
M_E	s/d	average daily rate for the last three days of the ageing test (stage VIII)
V_V	s	variation in state over one year due to ageing
Temperature simulation		
M_P	s/d	average daily rate in simulation of spring
M_S	s/d	average daily rate in simulation of summer
M_A	s/d	average daily rate in simulation of autumn
M_W	s/d	average daily rate in simulation of winter
V_T	s	variation in state over one year due to seasonal changes in temperature
Accuracy		
M_m	s/m	monthly rate
M_y	s/a	annual rate

iTech STANDARD PREVIEW

5 Practical factors affecting accuracy (standards.iteh.ai)

5.1 General

ISO 10553:2018

<https://standards.iteh.ai/catalog/standards/sist/c735d4d4-9805-4b5f-ac17-3a122062405c/iso-10553-2018>

The main factors affecting the operating accuracy of quartz watches are temperature and ageing. Accordingly, these two factors are taken into account when evaluating the accuracy. The influence of other factors, such as mechanical impacts, magnetic fields, humidity and supply voltage is low.

5.2 Accuracy

The accuracy of quartz watches depends upon temperature variations due to the climatic conditions in the places of use.

5.3 Influence of temperature on accuracy

Watches are subject to the influence of the ambient temperature, which is variable according to the seasons and geographical location of the wearer.

It is not possible to specify absolutely temperatures simulating seasonal variations in all locations. The effects of temperature on accuracy are calculated arbitrarily at levels corresponding to the average seasonal temperature in temperate climates.

5.4 Accidents or abnormal environment

Accidents which quartz watches may suffer such as dropping, exposure to a strong magnetic field or extremely high or low temperatures are not covered by this document.

6 Types of measurement

To evaluate the accuracy of quartz watches in accordance with the procedure described in [Clause 7](#), the condition of the component which displays the seconds shall be measured (this measuring procedure

has the advantage of taking the oscillator variance into consideration and of checking the display kinematic chain).

7 Test methods

7.1 General test conditions

7.1.1 The average daily rate is obtained by calculating the difference between two successive states divided by the number of days of observation according to the test programmes described in 7.2 and 7.3.

7.1.2 The position of the timepieces throughout all the test programmes shall be with the dial facing upwards (CH), in accordance with ISO 3158.

7.1.3 In order to eliminate any residual influence of temperature in the initial ageing test, the ageing test shall be performed first followed by the temperature simulation test.

7.1.4 The number of samples from each batch should be greater than or equal to 30. The confidence interval of standard deviation requires a minimum lot size.

7.2 Ageing test programme

The test specified in Table 2 shall only apply to watches having an indicated accuracy included between ± 3 s/a and ± 30 s/a.

ITEH STANDARD PREVIEW
(standards.iteh.ai)
ISO 10553:2018
<https://standards.iteh.ai/catalog/standards/sist/c735d4d4-9805-4b5f-ac17-a5a2e908a940/iso-10553-2018>

Table 2 — Ageing test

Stage	Test	Days	Symbol		Test conditions					
			States	Rate s/d	Temperature °C	Relative humidity %				
I	Stabilization (3 d)	1	←E _{V3}		23 ± 0,5	50 ± 5				
		2								
		3								
II	Average daily rate (3 d)	4					←E _{V6}	$M_B = \frac{E_{V6} - E_{V3}}{t_{dB}}$	23 ± 0,5	50 ± 5
		5								
		6								
III	Rest (24 d)	7	←E _{V33}		23 ± 5	50 ± 20				
		etc.								
		30								
IV	Stabilization (3 d)	31					←E _{V36}		23 ± 0,5	50 ± 5
		32								
		33								
V	Average daily rate (3 d)	34	←E _{V36}	$M_M = \frac{E_{V36} - E_{V33}}{t_{dM}}$	23 ± 0,5	50 ± 5				
		35								
		36								
VI	Rest (24 d)	37					←E _{V63}		23 ± 5	50 ± 20
		etc.								
		60								
VII	Stabilization (3 d)	61	←E _{V66}		23 ± 0,5	50 ± 5				
		62								
		63								
VIII	Average daily rate (3 d)	64					←E _{V66}	$M_E = \frac{E_{V66} - E_{V63}}{t_{dE}}$	23 ± 0,5	50 ± 5
		65								
		66								

NOTE t_d represents the period between the measurements of two states, equivalent to about 3 d; it is rounded to the nearest 1/1 440th of a day.

The following measurements shall be taken if the actual temperature variations during stages II, V and VIII influence the ageing measurements.

- a) Measure the temperature characteristics of the watch at 23 °C.
- b) Correct the daily rates measured during stages II, V and VIII on the basis of actual temperatures and temperature characteristics given in [Table 2](#) for each phase.

7.3 Temperature simulation test programme

The temperature simulation test programme is given in [Table 3](#).

The temperature gradient shall be greater than 0,5 °C/min.

Table 3 — Temperature simulation test

Stage	Test	Days	Symbol		Test conditions	
			State s	Rate s/d	Temperature °C	Relative humidity %
I	Stabilization (1 d)	1	←E _{T1}		25 ± 0,5	≤60
II	Simulation (3 d)	2				
		3	$M_P = \frac{E_{T4} - E_{T1}}{t_{dP}}$	25 ± 0,5		
4	←E _{T4}					
III		Simulation (3 d)	5	$M_S = \frac{E_{T7} - E_{T4}}{t_{dS}}$	35 ± 0,5	
			6			
	7					
IV	Simulation (3 d)	8	←E _{T7}	$M_A = \frac{E_{T10} - E_{T7}}{t_{dA}}$	25 ± 0,5	
		9				
		10				
V	Simulation (3 d)	11	←E _{T10}	$M_W = \frac{E_{T13} - E_{T10}}{t_{dW}}$	15 ± 0,5	
		12				
		13				
						←E _{T13}

NOTE t_d represents the period between the measurements of two states, equivalent to about 3 d; it is rounded to the nearest 1/1 440th of a day.

7.4 Uncertainty of measurement

The methods used for the measurement of state shall satisfy the following criteria concerning an uncertainty of measurement as specified in Table 4.

Table 4 — Criteria for uncertainty of measurement

Accuracy classification indicated	
Monthly accuracy s/d	Annual accuracy s/d
<10 ⁻²	<10 ⁻³

8 Calculation of accuracy

8.1 General

The accuracy calculated shall be expressed in terms of monthly rates (monthly difference) or annual rates (annual difference).

The units are seconds per month (s/m) or seconds per year (s/a).

A month shall be taken as 30 d, and a year as 360 d.

8.2 Calculation of the effect of ageing on accuracy

For $|M_E - M_B| < 5 \times 10^{-3}$ s/d, V_V shall be considered as equal to 0 s.

a (d^{-1}) shall be calculated using [Formula \(1\)](#):

$$\frac{M_M - M_B}{M_E - M_B} = \frac{\ln(1+30a)}{\ln(1+60a)} \quad (1)$$

where

M_M is the average daily rate, expressed in seconds per day (s/d), for the middle three days of the ageing test (stage V);

M_B is the average daily rate, expressed in seconds per day (s/d), for the first three days of the ageing test (stage II);

M_E is the average daily rate, expressed in seconds per day (s/d), for the last three days of the ageing test (stage VIII);

α is the coefficient of the logarithmic function applied, expressed in 1 per day (d^{-1}).

See [Annex B](#) for an alternative definition of the coefficient value a .

c (s/d) shall be calculated using [Formula \(2\)](#):

$$c = \frac{M_E - M_B}{\ln(1+60\alpha)} \quad (2)$$

where

c is the coefficient of the logarithmic function applied, expressed in seconds per day (s/d);

M_B is the average daily rate, expressed in seconds per day (s/d), for the first three days of the ageing test (stage II);

M_E is the average daily rate, expressed in seconds per day (s/d), for the last three days of the ageing test (stage VIII);

α is the coefficient of the logarithmic function applied, expressed in 1 per day (d^{-1}).

See [Annex B](#) for an alternative definition of the coefficient value c .

V_V (s) shall be calculated using [Formula \(3\)](#):

$$V_V = \int_0^{360} c \ln(1+\alpha t) dt \quad (3)$$

where

V_V is the variation in state, expressed in seconds (s), over one year due to ageing;

c is the coefficient of the logarithmic function applied, expressed in seconds per day (s/d);

α is the coefficient of the logarithmic function applied, expressed in 1 per day (d⁻¹).

The effect of seasonal changes in temperature on accuracy, V_T (s), shall be calculated using [Formula \(4\)](#):

$$V_T = \frac{M_P + M_S + M_A + M_W}{4} \times 360 \quad (4)$$

where

V_T is the variation in state, expressed in seconds (s), over one year due to seasonal changes in temperature;

M_P is the average daily rate, expressed in seconds per day (s/d), in simulation of spring;

M_S is the average daily rate, expressed in seconds per day (s/d), in simulation of summer;

M_A is the average daily rate, expressed in seconds per day (s/d), in simulation of autumn;

M_W is the average daily rate, expressed in seconds per day (s/d), in simulation of winter.

The monthly rate, M_m (s/m) (monthly accuracy), shall be calculated using [Formula \(5\)](#):

$$M_m = |V_T| / 12 \quad (5)$$

ISO 10553:2018
<https://standards.iteh.ai/catalog/standards/sist/c735d4d4-9805-4b5f-ac17-a5a2e908a940/iso-10553-2018>

where

M_m is the monthly rate, expressed in seconds per month (s/m);

V_T is the variation in state, expressed in seconds (s), over one year due to seasonal changes in temperature.

The annual rate, M_y (s/a), (annual accuracy), shall be calculated using [Formula \(6\)](#):

$$M_y = |V_V + V_T| \quad (6)$$

where

M_y is the annual rate, expressed in seconds per year (s/a);

V_V is the variation in state, expressed in seconds (s), over one year due to ageing;

V_T is the variation in state, expressed in seconds (s), over one year due to seasonal changes in temperature.