



SLOVENSKI STANDARD

oSIST prEN 16205:2019

01-oktober-2019

Laboratorijsko merjenje hrupa pri hoji po podu

Laboratory measurement of walking noise on floors

Messung von Gehschall auf Fußböden im Prüfstand

Mesurage en laboratoire du bruit des pas sur les planchers

Ta slovenski standard je istoveten z: prEN 16205

[SIST EN 16205:2021](https://standards.iteh.ai/catalog/standards/sist/3a6e623a-5426-4248-bd20-a2ad15501217/sist-en-16205-2019)

<https://standards.iteh.ai/catalog/standards/sist/3a6e623a-5426-4248-bd20-a2ad15501217/sist-en-16205-2019>

ICS:

17.140.01	Akustična merjenja in blaženje hrupa na splošno	Acoustic measurements and noise abatement in general
91.060.30	Stropi. Tla. Stopnice	Ceilings. Floors. Stairs
91.120.20	Akustika v stavbah. Zvočna izolacija	Acoustics in building. Sound insulation

oSIST prEN 16205:2019

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 16205:2021

<https://standards.iteh.ai/catalog/standards/sist/3a6e623a-5426-4248-bd20-a2ad15501217/sist-en-16205-2021>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 16205

August 2019

ICS 91.120.20

Will supersede EN 16205:2013+A1:2018

English Version

Laboratory measurement of walking noise on floors

Mesurage en laboratoire du bruit des pas sur les
planchers

Messung von Gehschall auf Fußböden im Prüfstand

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 126.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	3
Introduction	4
1 Scope.....	5
2 Normative references.....	5
3 Terms and definitions	5
4 Principle	7
5 Test arrangement.....	7
5.1 Test facilities.....	7
5.2 Equipment	7
5.3 Mounting of the specimens.....	8
6 Test procedure.....	8
7 Evaluation of results	9
8 Precision.....	9
9 Expression of results.....	10
10 Test report.....	10
Annex A (informative) Presentation of the walking noise spectrum with uncertainty bars (example).....	11
Annex B (normative) Reference spectrum for laboratory bare floors	12
Annex C (informative) Fixing the pads below the tapping machine.....	13
Annex D (informative) Background of the measuring method.....	14
Annex E (informative) Calculation of perceived walking loudness on floor coverings installed floating.....	16
E.1 General.....	16
E.2 Data measured	16
E.3 Calculations.....	16
E.3.1 Sound spectrum $L_{i,loud}$	16
E.3.2 Loudness RWS	17
E.4 Test report.....	17
Bibliography.....	18

European foreword

This document (prEN 16205:2019) has been prepared by Technical Committee CEN/TC 126 “Acoustic properties of building elements and of buildings”, the secretariat of which is held by AFNOR.

This document is currently submitted to the CEN Enquiry.

This document will supersede EN 16205:2013+A1:2018.

In comparison with the previous edition, the following technical modifications have been made:

- amendment of the Annex E to include the room correction.

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 16205:2021

<https://standards.iteh.ai/catalog/standards/sist/3a6e623a-5426-4248-bd20-a2ad15501217/sist-en-16205-2021>

Introduction

This document sets up a laboratory measurement method to determine noise radiated from a floor covering on a standard concrete floor when excited by a standard tapping machine. The noise is measured in the room where the floor covering and the excitation are located. There is no restriction concerning the type of floor covering unless that the required small pads of the flooring could not be assembled. Using the standard tapping machine according to EN ISO 10140, (all parts) means that a more general excitation compared to walking alone is regarded – in the same way as it is accepted for impact sound improvement measurements of floor coverings. The results are expressed in terms of the normalized A-weighted average sound pressure level in the walking room. The results provide information about the noise radiated. A more sophisticated psychoacoustic evaluation did not seem to be appropriate in view of the fact that this measurement stands for a large range of sources with different acoustical behaviour (even if only different types of walking were regarded). A subjective classification of the quality of the floor coverings is not intended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 16205:2021](https://standards.iteh.ai/catalog/standards/sist/3a6e623a-5426-4248-bd20-a2ad15501217/sist-en-16205-2021)

<https://standards.iteh.ai/catalog/standards/sist/3a6e623a-5426-4248-bd20-a2ad15501217/sist-en-16205-2021>

1 Scope

This document specifies a laboratory measurement method to determine noise radiated from a floor covering on a standard concrete floor when excited by a standard tapping machine.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 10140-1, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 1: Application rules for specific products (ISO 10140-1)*

EN ISO 10140-2, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 2: Measurement of airborne sound insulation (ISO 10140-2)*

EN ISO 10140-3, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 3: Measurement of impact sound insulation (ISO 10140-3)*

EN ISO 10140-4:2010, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 4: Measurement procedures and requirements (ISO 10140-4:2010)*

EN ISO 10140-5, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 5: Requirements for test facilities and equipment (ISO 10140-5)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN ISO 10140 (all parts) and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <http://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1

sufficiently large specimen

specimen whose radiated sound power does not increase any longer with size, or which covers the total area of the floor

Note 1 to entry: In case of uncertainty, the testing laboratory will decide, which size is sufficient.

3.2

pads

pieces of the flooring under test, which are as large as the hitting areas of the tapping machine hammers

Note 1 to entry: Quadratic pads should be the smallest possible including the whole hitting area.

3.3

walking sound pressure level (in third-octave band i)

$L_{n,walk,i}$

normalised impact sound pressure level in the upper (walking) room with a standardised contribution of the concrete bare floor underneath the floor covering under test

Note 1 to entry: It is calculated according to Formula (1):

prEN 16205:2019 (E)

$$L_{n,walk,i} = \begin{cases} L_{i,ref,b} + L_{i,Fl,c} - L_{i,Fl,b} & \text{if } L_{i,with} < \left(L_{i,pads} + 10 \cdot \log \left(\frac{T_{i,upper,with}}{T_{i,upper,pads}} \right) \right) \\ 10 \log_{10} \left(\frac{0,16 \cdot V_{upper}}{A_0} \left(\frac{10^{\frac{L_{i,with}}{10}}}{T_{i,upper,with}} - \frac{10^{\frac{L_{i,pads}}{10}}}{T_{i,upper,pads}} \right) + 10 \frac{L_{i,ref,b} + L_{i,Fl,c} - L_{i,Fl,b}}{10} \right) & \text{else} \end{cases} \quad (1)$$

where

- $L_{i,with}$ is the impact sound pressure level measured in the upper room, when a sufficiently large specimen is lying on the test floor;
- $L_{i,pads}$ is the impact sound pressure level measured in the upper room, when only pads of the flooring material are lying on the test floor below the tapping machine hammers;
- $L_{i,Fl,b}$ is the impact sound pressure level measured in the lower room, when the tapping machine acts on the bare floor in the upper room;
- $L_{i,Fl,c}$ is the impact sound pressure level measured in the lower room, when the tapping machine acts on the sufficiently large specimen in the upper room;
- $L_{i,ref,b}$ is the reference values for the bare floor as given in Annex B;
- V_{upper} is the volume of the upper room, in cubic metres;
- $T_{i,upper,with}$ is the reverberation time in the upper room with sufficiently large floor covering installed, in seconds;
- $T_{i,upper,pads}$ is the reverberation time in the upper room with pads installed, in seconds;
- A_0 10 m².

Note 2 to entry: This definition presumes, that the reverberation time in the lower room does not change between the measurements of $L_{i,Fl,c}$ and $L_{i,Fl,b}$.

Note 3 to entry: This can be achieved by leaving the lower room unchanged.

3.4

A-weighted walking sound pressure level

$L_{n,walk,A}$

A-weighted sound pressure level, calculated from $L_{n,walk,i}$ according to Formula (2) with C_i according to EN 61672-1:

$$L_{n,walk,A} = 10 \cdot \lg \sum_{i=1}^{21} 10^{(L_{n,walk,i} + C_i)/10} \quad (2)$$

3.5

Radiated walking sound

RWS

subjective perceived loudness radiated from a floor when a person with hard heel is walking on it

3.6

loudness

perceived strength of steady-state sound calculated according to Zwicker

Note 1 to entry: Its unit is sone. Loudness is a linear measure; hence a redoubling of the sone value results in a redoubling of the perceived loudness. Loudness is based on the concept of critical bands.

3.7

critical band

loudness-model for human hearing system processes perceived sound in sub-bands called critical bands

Note 1 to entry: Critical bandwidth differs within the frequency range.

Note 2 to entry: The critical band produces the critical band scale. Its unit is Bark.

4 Principle

A floor test facility, according to EN ISO 10140-1 through 5, for impact and airborne sound measurements is used. It consists of two medium-sized and medium damped rooms above each other, separated by a standard homogeneous concrete floor. As a walking noise source, a standard tapping machine according to EN ISO 10140-1 through 5 is applied. Several average sound pressure level measurements in third-octave bands are made in the upper and lower rooms with the bare floor either uncovered or covered with pads or sufficiently large “full-size” specimens of the tested flooring. In the upper room, the reverberation times with large specimens and with merely pads present shall be determined.

The walking sound pressure level is then calculated according to Formula (1) from the sound power directly radiated from the floor covering into the upper room plus the sound power from the bare floor under the floor covering, which radiates back into the upper room. Finally, the A-weighted walking sound pressure level is calculated from the measured average sound pressure levels.

In Formula (1), the radiation from the bare floor through the floor covering is corrected for deviations of the actual laboratory floor from the reference spectrum in Annex B. Furthermore, the tapping machine self-noise theoretically cancels out and, therefore, is not needed explicitly. However, because of the uncertainty of the measured quantities, the resulting walking sound pressure level in the second line in Formula (1) may become very uncertain and even complex, in particular when a loud tapping machine is used and the flooring does not radiate much itself. Complex values are avoided by setting the inner bracket to zero as a minimum [first line in Formula (1)]. To detect unreliable results, the uncertainty of $L_{n,walk}$ shall be calculated for each third octave band and stated in the test report.

All details like test facility requirements, tapping machine characteristics, positioning of tapping machine and microphones, averaging etc. are kept as close as possible to the requirements of laboratory measurements of impact noise as given in EN ISO 10140.

5 Test arrangement

5.1 Test facilities

A room arrangement for impact and airborne sound pressure level measurements according to EN ISO 10140, (all parts) shall be used.

5.2 Equipment

See EN ISO 10140, (all parts).

prEN 16205:2019 (E)

5.3 Mounting of the specimens

The floor coverings or the corresponding pads shall be mounted according the instructions of EN ISO 10140, (all parts) and Annex C.

6 Test procedure

All specifications of EN ISO 10140, (all parts), concerning:

- generation of the sound field;
- measurement of impact sound pressure levels;
- measurement of reverberation time;
- correction for background noise; and
- additional measures to be regarded at low frequencies (EN ISO 10140-4:2010, Annex A)

shall be followed. The measurement shall run in third-octave bands from 50 Hz to 5 000 Hz.

Proceed as follows:

1	Apply the tapping machine on the bare floor in the upper room.	Measure $L_{i,Fl,b}$ in the lower room.	Ensure negligible air-borne sound transmission through the lab floor. Reverberation time in the lower room shall remain unchanged until the end of all measurements.
2	Let the tapping machine hammer on pads of the investigated flooring. (Support the feet with pieces of the flooring, too, to keep the falling height of the hammers.)	Measure reverberation time $T_{i,pads}$ and $L_{i,pads}$ in the upper room.	
3	Install a sufficiently large piece of the floor covering on the floor.	Measure reverberation time $T_{i,upper,with}$ and $L_{i,with}$ in the upper room.	
4		Determine $L_{i,Fl,c}$ in the lower room.	Ensure negligible air-borne sound transmission through the lab floor. Check that reverberation time in the lower room (or state of the room) is unchanged.

7 Evaluation of results

From the measured sound pressure levels, the following final results shall be evaluated:

- walking sound pressure level $L_{n,walk,i}$ (in third-octave bands) according to Formula (1);
- the uncertainty of the walking sound pressure level, $u_{walk,i}$, according to Formula (3);
- the A-weighted walking sound pressure level $L_{n,walk,A}$ according to Formula (2);
- the uncertainty of the A-weighted walking sound pressure level, $u_{walk,A}$, according to Formula (4).

8 Precision

It is assumed, that in Formula (1), essentially, only the four measured levels and the reverberation times are uncertain. The uncertainty of the walking noise level of a third-octave band i , $u_{walk,i}$, then results from Formula (3).

$$u_{walk,i} = 10^{-L_{n,walk,i}/10} \cdot \sqrt{2 \cdot 10^{(L_{i,Fl,c} + L_{i,ref,b} - L_{i,Fl,b})/5} \cdot u_L^2 + \left(\frac{0,16 V_{upper}}{A_0}\right)^2 \left[\left(\frac{10^{L_{i,pads}/10}}{T_{i,upper,pads}}\right)^2 + \left(\frac{10^{L_{i,with}/10}}{T_{i,upper,with}}\right)^2 \right] \cdot (u_L^2 + u_{LT}^2)} \quad (3)$$

where

u_L is the uncertainty of the (standard levels, in decibels);

u_{LT} is the uncertainty of the reverberation time levels, in decibels.

If particular values are not known, the following ones according to [6] and [7] should be used for all third-octave bands:

— $u_L = 0,4$ dB;

— $u_{LT} = 0,5$ dB.

Shielding effects by the tapping machines ([8] and [9]) are ignored here.

The uncertainty of the A-weighted walking sound pressure level results from Formula (4).

$$u_{walk,A} = \frac{1}{\sum_{j=1}^{21} 10^{(L_{n,walk,j} + C_j)/10}} \cdot \sqrt{\sum_{i=1}^{21} \left[10^{(L_{n,walk,i} + C_i)/10} \cdot u_{walk,i} \right]^2} \quad (4)$$

where

C_i, C_j are the A-weighting coefficients in the third-octave bands i resp. j .