

---

**Razširjena uporaba rezultatov preskusov trajnosti samozapiranja za požarno odporna in/ali dimotesna vrata in okna, ki se odpirajo - 1. del: Trajnost samozapiranja jeklenih vrat z vrtljivim krilom**

Extended application of test results on durability of self-closing for fire resistance and/or smoke control doorsets and openable windows - Part 1: Durability of self-closing of hinged and pivoted steel doorsets

Erweiterter Anwendungsbereich von Prüfergebnissen zur Dauerhaftigkeit des Selbstschließens für Feuerschutz- und/oder Rauchschutztüren und zu öffnende Fenster - Teil 1: Dauerhaftigkeit des Selbstschließens von Drehflügeltoren und Drehflügeltüren aus Stahl

[oSIST prEN 17020-1:2021](https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pr-en-17020-1-2021)

[https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-](https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pr-en-17020-1-2021)

[0ba41ad8a083/osist-pr-en-17020-1-2021](https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pr-en-17020-1-2021)

Application étendue des résultats d'essais de durabilité de la fermeture automatique des blocs-portes et fenêtres ouvrantes résistants au feu et/ou étanches à la fumée - Partie 1 : Durabilité de la fermeture automatique des blocs-portes battants et pivotants en acier

**Ta slovenski standard je istoveten z: prEN 17020-1**

---

**ICS:**

13.220.50	Požarna odpornost gradbenih materialov in elementov	Fire-resistance of building materials and elements
91.060.50	Vrata in okna	Doors and windows

**oSIST prEN 17020-1:2021**

**en,fr,de**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[oSIST prEN 17020-1:2021](#)

<https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pren-17020-1-2021>

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**DRAFT**  
**prEN 17020-1**

May 2021

ICS 13.220.50; 91.060.50

English Version

## Extended application of test results on durability of self-closing for fire resistance and/or smoke control doorsets and openable windows - Part 1: Durability of self-closing of hinged and pivoted steel doorsets

Application étendue des résultats d'essais de durabilité de la fermeture automatique des blocs-portes et fenêtres ouvrantes résistants au feu et/ou étanches à la fumée - Partie 1 : Durabilité de la fermeture automatique des blocs-portes battants et pivotants en acier

Erweiterter Anwendungsbereich von Prüfergebnissen zur Dauerhaftigkeit des Selbstschließens für Feuerschutz- und/oder Rauchschutztüren und zu öffnende Fenster - Teil 1: Dauerhaftigkeit des Selbstschließens von Drehflügeltüren und Drehflügeltüren aus Stahl

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 127.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

**Warning** : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

<b>Contents</b>	<b>Page</b>
European foreword.....	3
Introduction .....	4
1 Scope.....	5
2 Normative references.....	5
3 Terms and definitions .....	6
4 Determination of the field of extended application .....	7
4.1 General.....	7
4.2 Procedure for evaluation .....	7
4.3 Procedure for maximum field of extended application .....	7
4.4 Interpretation of test results .....	8
5 Extended application report.....	8
6 Classification report.....	8
Annex A (normative) Construction parameter variations .....	9
Annex B (normative) Arrangements for doorsets incorporating side and/or over panels .....	73
Annex C (normative) Construction parameter variation simulation by applying additional weights.....	80

[osIST prEN 17020-1:2021](https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pren-17020-1-2021)

<https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pren-17020-1-2021>

## European foreword

This document (prEN 17020-1:2021) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings”, the secretariat of which is held by BSI.

This document is currently submitted to the CEN Enquiry.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

A list of all parts in the EN 17020 series can be found on the CEN website.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[oSIST prEN 17020-1:2021](https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pren-17020-1-2021)

<https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pren-17020-1-2021>

## Introduction

The EN 15269 series of standards covering extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware, does not include the durability of self-closing of the doorsets following an extended application process. This document is one of the EN 17020 series of standards intended to be used for the purpose of producing an extended application report based on the evaluation of one or more durability of self-closing tests. These European Standards may also be used to identify the best selection of test specimens required to cover a wide range of product variations.

Before there can be any consideration for extended application, the doorset should have been tested in accordance with EN 1191 to achieve a test result which could generate a classification in accordance with EN 13501-2 and EN 16034 at least equal to the classification subsequently required from extended application considerations.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[oSIST prEN 17020-1:2021](https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pren-17020-1-2021)

<https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pren-17020-1-2021>

## 1 Scope

This document covers single and double leaf, hinged and pivoted, steel based doorsets as covered by EN 15269-2 or EN 15269-20.

This document prescribes the methodology for extending the application of test results obtained from durability of self-closing test(s) conducted in accordance with EN 1191.

Subject to the completion of the appropriate self-closing test(s), the extended application can cover all or some of the following non-exhaustive list

- door leaf;
- side, transom and/or overpanels;
- ventilation grilles and/or louvres;
- wall/ceiling fixed elements (frame/suspension system);
- glazing for door leaf, side, transom and flush over panels;
- items of building hardware;
- decorative finishes;
- intumescent, smoke, draught or acoustic seals;
- alternative supporting construction(s).

## 2 Normative references

oSIST prEN 17020-1:2021

[https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-](https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pr-en-17020-1-2021)

[0ba41ad8a083/osist-pr-en-17020-1-2021](https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pr-en-17020-1-2021)

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 179, *Building hardware - Emergency exit devices operated by a lever handle or push pad, for use on escape routes - Requirements and test methods*

EN 1125, *Building hardware - Panic exit devices operated by a horizontal bar, for use on escape routes - Requirements and test methods*

EN 1154, *Building hardware - Controlled door closing devices - Requirements and test methods*

EN 1191, *Windows and doors - Resistance to repeated opening and closing - Test method*

EN 1363-1, *Fire resistance tests - Part 1: General requirements*

EN 1363-2, *Fire resistance tests - Part 2: Alternative and additional procedures*

EN 1634-1, *Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware - Part 1: Fire resistance test for door and shutter assemblies and openable windows*

EN 1634-3, *Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware - Part 3: Smoke control test for door and shutter assemblies*

**prEN 17020-1:2021 (E)**

EN 1935, *Building hardware - Single-axis hinges - Requirements and test methods*

EN 12209, *Building hardware - Mechanically operated locks and locking plates - Requirements and test methods*

EN 12519, *Windows and pedestrian doors - Terminology*

EN 13501-2:2016, *Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services*

EN 13637, *Building hardware - Electrically controlled exit systems for use on escape routes - Requirements and test methods*

EN 14846, *Building hardware - Locks and latches - Electromechanically operated locks and striking plates - Requirements and test methods*

EN 15269-1, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 1: General requirements*

EN 15269-2, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 2: Fire resistance of hinged and pivoted steel doorsets*

EN 15685, *Building hardware - Multipoint locks, latches and locking plates - Requirements and test methods*

EN 16034, *Pedestrian doorsets, industrial, commercial, garage doors and openable windows - Product standard, performance characteristics - Fire resisting and/or smoke control characteristics*

EN ISO 13943, *Fire safety - Vocabulary (ISO 13943)*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1191, EN 1363-1, EN 1363-2, EN 1634-1, EN 1634-3, EN 12519, EN 15269-1, EN 15269-2 and EN ISO 13943 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

#### 3.1

##### **full scale test**

test of a full size doorset in accordance with EN 1191

#### 3.2

##### **core**

material fitted centrally within the thickness of a door leaf which may consist of a single sheet of material or a combination either of sheets of the same material or layers of different materials



### 3.3

#### panel

component of a door leaf separated from other elements by joints which break through the total door thickness

Note 1 to entry: A door leaf can consist of one or more panels.

## 4 Determination of the field of extended application

### 4.1 General

**4.1.1** Before there can be any consideration for extended application, the doorset shall have been tested in accordance with EN 1191 to achieve a test result, which could generate a classification in accordance with EN 13501-2 and/or correspond to a use category according to EN 16034.

**4.1.2** A review of the doorset construction parameters can indicate that one or more characteristics can be improved by a particular parameter variation. All evaluations shall be made on the basis of retaining the classifications obtainable from testing to EN 1191, including those with a lower number of opening and closing cycles. However, this shall never lead to an increased classification for any specific parameter beyond that achieved during any one test unless specifically identified in the relevant Construction Parameter Variation tables.

**4.1.3** If, when following the extended application procedure, any part of the classified product cannot be covered by the extended application rules, that part shall be omitted from the subsequent extended application report and classification report.

### 4.2 Procedure for evaluation

**4.2.1** Identify the variations from the original test specimen(s) which are required to be covered by an extended application report.

**4.2.2** Locate the variations in the appropriate parameter variation by reference to columns (1) and (2) of Table A.1.

**4.2.3** Establish from the contents of column (3) of Table A.1 whether any extended application is available without the need for further testing.

**4.2.4** Where this is deemed to be possible this can be recorded in the extended application report together with any appropriate restrictions and the stated rules from column (3) in Table A.1.

**4.2.5** Where the variations required can only be achieved from additional testing according to column (4), the additional test can be made on a similar specimen type to the original test against which the extended application is sought. Alternatively, column (4) in Table A.1 identifies an option for alternative testing and relevant test parameters.

### 4.3 Procedure for maximum field of extended application

**4.3.1** It is possible to provide a limited field of extended application from the results of a single test. However, where a manufacturer intends to produce a range of doors incorporating single leaf door assemblies and also double leaf door assemblies with or without glazing, with alternative items of building hardware, etc., it is recommended that careful consideration is given to the complete range of doorset designs and options in order to minimize the testing required before testing commences.

**4.3.2** Establish all the parameter variations which are required to be part of the product range.

**prEN 17020-1:2021 (E)**

**4.3.3** Determine which are the most important specification requirements and incorporate as many as possible into the specimen(s) for the first tests in the series.

**4.3.4** Conduct the first durability test or a series of tests and then establish which of the original desired parameter variations have not been covered by this test(s).

**4.3.5** Identify these parameter variations in Table A.1 and establish if any extended application is possible without further testing.

**4.3.6** Record this for the extended application report together with any restrictions and rules given in column (3) in Table A.1.

**4.3.7** Evaluate which, if any, of the desired parameter variations have not been covered by the initial field of extended application derived from 4.3.6 above.

**4.3.8** Determine if the product range is to include only single leaf doorsets or if the range is to also include double leaf configurations. Where only single doorsets are to be part of the product range, the outstanding construction parameter variations shall only be incorporated into specimens for the single leaf doorsets. Where single leaf and double leaf doorsets are to be included in the product range, the outstanding construction parameter variations for the extended application of single leaf doorsets may be incorporated into either repeated single leaf doorset tests or, in the weakest option, as defined in column (4) of the table in Table A.1, double leaf doorset configurations.

**4.3.9** Select the required outstanding parameter variations from column (1) and column (2) of Table A.1 and observe from column (4) in Table A.1 which are the most appropriate weakest specimen options for further testing.

**4.3.10** If the complete selection of required parameter variations has not been covered by the tests completed in accordance with 4.3.8 and 4.3.9 above, then an appropriate test or tests may be carried out with the additional product variations incorporated.

## **4.4 Interpretation of test results**

**4.4.1** In order to maximize the extended field of application, it is important that the test reports shall record details of any failures occurred throughout the test duration.

**4.4.2** Where a series of tests have been conducted, the field of extended application shall be based on the lowest performance achieved from the complete series of tests unless premature failure has been attributed to one or more specific construction parameter variations.

**4.4.3** Where it has been possible to identify specific parameter failures, the extended application for all other construction parameter variations can be based on the performance achieved after isolating the premature failure(s).

## **5 Extended application report**

Prepare an extended application report in accordance with the requirements of EN 15269-1, based on the results of evaluations in accordance with the above.

## **6 Classification report**

The classification report shall be determined from the results of the extended application report and shall be presented in accordance with EN 13501-2:2016, Annex A.

## Annex A (normative)

### Construction parameter variations

Table A.1 below is designed to be used by experts competent in the field of self-closing durability testing of hinged and pivoted steel doorsets.

The table shall only be used to assess a field of extended application when at least one positive self-closing durability test to EN 1191 has generated a classification according to EN 13501-2 and EN 16034.

The first two columns identify possible variations to the construction details of the specimen tested. It is presupposed that the variation does not restrain the door closing.

Column (3) leads to the judgement of the possibility of extending the field of application.

Where additional tests are deemed to be necessary, the type of specimen approved for incorporation of the changed parameter is defined in column (4). Where it is possible to use information from tests performed on one configuration for evidence on a different configuration, this allowance has been made in order to reduce the overall number of tests required for extended application evaluation e.g. single action doorsets to double action doorsets.

Where an additional test is required in column (4), the test is a full scale test unless otherwise specified.

In order to maximize the possible field of application from a minimum number of tests, the parameter changes have been spread over a series of test specimens. Where more than a single parameter variation is required, the influence on other variations shall also be taken into account.

[oSIST prEN 17020-1:2021](https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pren-17020-1-2021)

<https://standards.iteh.ai/catalog/standards/sist/26ef2205-fb5e-4711-9dcd-0ba41ad8a083/osist-pren-17020-1-2021>

Table A.1 — Construction parameter variations

Construction Parameter	Variation	Possibility of extension	Additional Evidence Required	
(1)	(2)	(3)	(4)	
<b>A Door leaf</b>				
In certain cases, the rules given in Section A are also appropriate to side, transom and flush over panels or the door frame; where this is the case it is clearly indicated at the beginning of the relevant section. For double leaf door sets, both leaves shall be of the same basic construction.				
<b>A.1 General</b>				
A.1.1	Number of leaves — See Figure A.1 only applicable to doorsets tested without transom and/or flush over panels. See Annex C.	Single leaf from double leaf test	Possible	–
A.1.2	Number of leaves — See Figure A.1 only applicable to doorsets tested without transom and/or flush over panels. See Annex C.	Double leaf from single leaf test	Not possible without additional test	Additional test double leaf doorset
A.1.3	Number of panels per leaf (primary or secondary)	Add (one panel per leaf — on any leaf)	Possible if tested at least one leaf (single, primary or secondary) with the minimum of two panels, panel size not increased and the intended jointing technique centrally located in the door leaf otherwise not possible without an additional test	Additional test double for single and double leaf door sets or single for single leaf doorsets
A.1.4	Number of panels per leaf(primary or secondary) — See Figure A.2	Reduce (one panel per leaf)	Possible providing the tested width of the panel is not increased otherwise not possible without an additional test	Additional test double for single and double leaf door sets or single for single leaf door sets doorset
A.1.5	Intumescent seals between frame and door leaf/leaves — See Figure A.3.	Location towards the frame rebate	Possible	–
A.1.6	Intumescent seals between frame and door leaf/leaves — See Figure A.4.	Location away from the frame rebate	Possible	–

Construction Parameter	Variation	Possibility of extension	Additional Evidence Required
(1)	(2)	(3)	(4)
A.1.7 Intumescent seals between meeting edges of the door leaves	Location	Possible	–
A.1.8 Non intumescent seals between frame and door leaf/leaves (draught/smoke/acoustic etc.) — Euroclass A1, e.g. ceramic products (fitted in leaf or frame) — See Figure A.5	Location	Possible	–
A.1.9 Non intumescent seals between meeting edges of the door leaves (draught/smoke/acoustic etc.) — Euroclass A1, e.g. ceramic products	Location	Possible	–
A.1.10 Non intumescent seals/combination of non-intumescent and intumescent seals between door leaves and/or frames (draught /smoke/acoustic etc.) — Euroclass A1 (fitted in leaf or frame). — See Figure A.6	Location	Possible providing the deformation of the seal will not increase during movement of the door leaf/leaves otherwise not possible without an additional test	Additional test double for single and double leaf door sets or single for single leaf doorsets
A.1.11 Non intumescent seals between door leaves and/or frames (draught/smoke/acoustic etc.) — Euroclass A1, e.g. ceramic products (fitted in leaf or frame). — See Figure A.7	Add	Not possible without an additional test	Additional test double for single and double leaf door sets or single for single leaf doorsets
A.1.12 Non intumescent seals between door leaves and/or frames (draught/smoke/acoustic etc.) — Euroclass A1, e.g. ceramic products (fitted in leaf or frame) — See Figure A.8	Remove	Possible	–

## prEN 17020-1:2021 (E)

Construction Parameter	Variation	Possibility of extension	Additional Evidence Required
(1)	(2)	(3)	(4)
A.1.13 Non intumescent seals between door leaves and/or frames (draught/smoke/acoustic etc.) — < Euroclass A1 (fitted in leaf or frame) — See Figure A.9	Add	Not possible without an additional test	Additional test double for single and double leaf door sets or single for single leaf doorsets
A.1.14 Non intumescent seals between door leaves and/or frames (draught/smoke/acoustic etc.) — < Euroclass A1 (fitted in leaf or frame) — See Figure A.10	Remove	Possible	–
A.1.15 Ventilation grilles (louvres) in door leaf tested without ventilation grille — See Figure A.11a	Add	possible providing the requirements of Annex C are fulfilled otherwise not possible without an additional test	Additional test single or double leaf doorset
A.1.16 Ventilation grilles (louvres) in door leaf — See Figure A.11b	Remove	Possible	–
A.1.17 Ventilation grilles (louvres) in door leaf tested with ventilation grille	Location in vertical direction	Possible	–
A.1.18 Ventilation grilles (louvres) in door leaf tested with ventilation grille — See Figure A.12	Location in horizontal direction	Possible	–
A.1.19 Ventilation grilles (louvres) in door leaf tested with ventilation grille — See Figure A.13a — See Figure A.13b	Smaller size Larger size	Smaller size: Possible Larger size: Possible providing the requirements of Annex C are fulfilled otherwise not possible without an additional test	– Additional test single or double leaf doorset

Construction Parameter		Variation	Possibility of extension			Additional Evidence Required
(1)		(2)	(3)			(4)
A.1.20	Rebate (door leaves to frames) — See Figure A.14a	Add	Possible			—
A.1.21	Rebate (meeting edges) — See Figure A.14b	Add (one rebate)	Possible			—
A.1.22	Rebate (door leaves to frames) — See Figure A.15	Remove	Possible			—
A.1.23	Rebate (meeting edges)	Remove	Possible			—
A.1.24	Latched condition for single and double leaf doorsets	Change in latching condition	Possible in line with the following relationship:			Additional test double for single and double leaf doorsets or single for single leaf doorsets
			tested without a latch/lock	tested with a latch/lock but unlatched	tested with a latch/lock latched	
		extension to: without a lock/latch	—	Possible	possible	
		extension to: with lock/latch but unlocked/unlatched (disengaged)	Possible	—	possible	
		extension to: with a lock/latch, latched	Not possible	Not possible	—	