

---

**Razširjena uporaba rezultatov preskusov trajnosti samozapiranja za vrata in okna, ki se odpirajo - 4. del: Trajnost samozapiranja požarno odpornih in/ali dimotesnih zastekljenih vrat v kovinskih okvirjih z vrtljivim krilom in oken, ki se odpirajo**

Extended application of test results on durability of self-closing for doorsets and openable windows - Part 4: Durability of self-closing of fire resistance and/or smoke control hinged and pivoted metal framed glazed doorsets and openable windows

Erweiterter Anwendungsbereich von Prüfergebnissen zur Dauerhaftigkeit der Selbstschließung für Türen und zu öffnende Fenster - Teil 4: Dauerhaftigkeit der Selbstschließung von verglasten Drehflügeltüren und zu öffnenden Fenstern mit Metall (rohr)rahmen mit Feuerwiderstandseigenschaften

<https://standards.iteh.ai/catalog/standards/sist/26d82544-2849-4241-8ae1-cac9781fe448/sist-en-17020-4-2021>

Application étendue des résultats d'essais de durabilité de la fermeture automatique des blocs-portes et fenêtres ouvrantes - Partie 4 : Durabilité de la fermeture automatique des blocs-portes vitrés battants et pivotants à ossature métallique et des fenêtres ouvrantes à ossature métallique résistants au feu et/ou étanches à la fumée

**Ta slovenski standard je istoveten z: EN 17020-4:2021**

---

**ICS:**

13.220.50	Požarna odpornost gradbenih materialov in elementov	Fire-resistance of building materials and elements
91.060.50	Vrata in okna	Doors and windows

**SIST EN 17020-4:2021**

**en,fr,de**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 17020-4:2021](https://standards.iteh.ai/catalog/standards/sist/26d82544-2849-4241-8ae1-cac9781fe448/sist-en-17020-4-2021)

<https://standards.iteh.ai/catalog/standards/sist/26d82544-2849-4241-8ae1-cac9781fe448/sist-en-17020-4-2021>

EUROPEAN STANDARD

EN 17020-4

NORME EUROPÉENNE

EUROPÄISCHE NORM

May 2021

ICS 13.220.50; 91.060.50

English Version

Extended application of test results on durability of self-closing for doorsets and openable windows - Part 4: Durability of self-closing of fire resistance and/or smoke control hinged and pivoted metal framed glazed doorsets and openable windows

Application étendue des résultats d'essais de durabilité de la fermeture automatique des blocs-portes et fenêtres ouvrantes - Partie 4 : Durabilité de la fermeture automatique des blocs-portes vitrés battants et pivotants à ossature métallique et des fenêtres ouvrantes à ossature métallique résistants au feu et/ou étanches à la fumée

Erweiterter Anwendungsbereich von Prüfergebnissen zur Dauerhaftigkeit der Selbstschließung für Türen und zu öffnende Fenster - Teil 4: Dauerhaftigkeit der Selbstschließung von verglasten Drehflügeltüren und zu öffnenden Fenstern mit Metall(rohr)rahmen mit Feuerwiderstandseigenschaften

ITEH STANDARD PREVIEW

This European Standard was approved by CEN on 12 April 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

<b>Contents</b>	<b>Page</b>
<b>European foreword</b> .....	<b>3</b>
<b>Introduction</b> .....	<b>4</b>
<b>1 Scope</b> .....	<b>5</b>
<b>2 Normative references</b> .....	<b>5</b>
<b>3 Terms and definitions</b> .....	<b>6</b>
<b>4 Determination of the field of extended application</b> .....	<b>7</b>
<b>4.1 General</b> .....	<b>7</b>
<b>4.2 Procedure for evaluation</b> .....	<b>7</b>
<b>4.3 Procedure for maximum field of extended application</b> .....	<b>7</b>
<b>4.4 Interpretation of test results</b> .....	<b>8</b>
<b>5 Extended application report</b> .....	<b>8</b>
<b>6 Classification report</b> .....	<b>8</b>
<b>Annex A (normative) Construction parameter variations</b> .....	<b>9</b>
<b>Annex B (normative) Construction parameter variation simulation by applying additional weights</b> .....	<b>54</b>
<b>Bibliography</b> .....	<b>55</b>

**ITeH STANDARD PREVIEW**  
(standards.iteh.ai)

SIST EN 17020-4:2021

<https://standards.iteh.ai/catalog/standards/sist/26d82544-2849-4241-8ae1-cac9781fe448/sist-en-17020-4-2021>

## European foreword

This document (EN 17020-4:2021) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2021, and conflicting national standards shall be withdrawn at the latest by November 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 17020-4:2021

<https://standards.iteh.ai/catalog/standards/sist/26d82544-2849-4241-8ae1-cac9781fe448/sist-en-17020-4-2021>

**EN 17020-4:2021 (E)****Introduction**

The EN 15269 series of standards covering extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their items of building hardware, does not include the durability of self-closing of the doorsets following an extended application process. This document is one of the EN 17020 series of standards intended to be used for the purpose of producing an extended application report based on the evaluation of one or more durability of self-closing tests. These European Standards may also be used to identify the best selection of test specimens required to cover a wide range of product variations.

**iTeh STANDARD PREVIEW  
(standards.iteh.ai)**

SIST EN 17020-4:2021

<https://standards.iteh.ai/catalog/standards/sist/26d82544-2849-4241-8ae1-cac9781fe448/sist-en-17020-4-2021>

## 1 Scope

This document is applicable to single and double leaf, hinged and pivoted metal framed, glazed doorsets or openable windows as covered by EN 15269-5 or EN 15269-20.

This document prescribes the methodology for extending the application of test results obtained from durability of self-closing test(s) conducted in accordance with EN 1191.

Subject to the completion of the appropriate self-closing test(s), the extended application can cover all or some of the following non-exhaustive list:

- doorsets and openable windows;
- door or window leaves;
- wall or ceiling fixed elements (frame or suspension system);
- glazing and non-glazed panels in doorset and openable window, side, transom and/or overpanels;
- items of building hardware;
- decorative finishes;
- intumescent, smoke, draught or acoustic seals;
- alternative supporting construction(s).

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1125, *Building hardware - Panic exit devices operated by a horizontal bar, for use on escape routes - Requirements and test methods*

EN 1154, *Building hardware - Controlled door closing devices - Requirements and test methods*

EN 1158, *Building hardware - Door coordinator devices - Requirements and test methods*

EN 1191, *Windows and doors - Resistance to repeated opening and closing - Test method*

EN 1363-1, *Fire resistance tests - Part 1: General requirements*

EN 1634-1, *Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware - Part 1: Fire resistance test for door and shutter assemblies and openable windows*

EN 1634-3, *Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware - Part 3: Smoke control test for door and shutter assemblies*

EN 16035, *Hardware performance sheet (HPS) - Identification and summary of test evidence to facilitate the inter-changeability of building hardware for application to fire resisting and/or smoke control doorsets and/or openable windows*

EN 1935, *Building hardware - Single-axis hinges - Requirements and test methods*

**EN 17020-4:2021 (E)**

EN 12209, *Building hardware - Mechanically operated locks and locking plates - Requirements and test methods*

EN 12519, *Windows and pedestrian doors - Terminology*

EN 13501-1, *Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests*

EN 13501-2:2016, *Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services*

EN 13637, *Building hardware - Electrically controlled exit systems for use on escape routes - Requirements and test methods*

EN 14846, *Building hardware - Locks and latches - Electromechanically operated locks and striking plates - Requirements and test methods*

EN 15269-1, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 1: General requirements*

EN 15269-5:2014+A1:2016, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 5: Fire resistance of hinged and pivoted metal framed glazed doorsets and openable windows*

EN 15269-20, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware - Part 20: Smoke control for doors, shutters, operable fabric curtains and openable windows*

<https://standards.iteh.ai/catalog/standards/sist/26d82544-2849-4241-8ae1->

EN 15685<sup>1</sup>, *Building hardware - Requirements and test methods - Multipoint locks, latches and locking plates - Characteristics and test methods*

EN 16034, *Pedestrian doorsets, industrial, commercial, garage doors and openable windows - Product standard, performance characteristics - Fire resisting and/or smoke control characteristics*

EN 179, *Building hardware - Emergency exit devices operated by a lever handle or push pad, for use on escape routes - Requirements and test methods*

EN ISO 13943, *Fire safety - Vocabulary (ISO 13943)*

### **3 Terms and definitions**

For the purposes of this document, the terms and definitions given in EN 1191, EN 1363-1, EN ISO 13943, EN 1634-1, EN 1634-3, EN 12519, EN 15269-1, EN 15269-5 and EN 15269-20, and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

---

<sup>1</sup> Under preparation. Stage at the time of publication: prEN 15685.



### 3.1

#### full scale test

test of a full size doorset/openable window in accordance with EN 1191

## 4 Determination of the field of extended application

### 4.1 General

**4.1.1** Before there can be any consideration for extended application, the doorset/openable window shall have been tested in accordance with EN 1191 to achieve a test result which could generate a classification in accordance with EN 13501-2 or correspond to a use category according to EN 16034.

**4.1.2** A review of the doorset/openable window construction parameters can indicate that one or more characteristics can be improved by a particular parameter variation. All evaluations shall be made on the basis of retaining the classifications obtainable from testing to EN 1191, including those with a lower number of opening and closing cycles. However, this shall never lead to an increased classification for any specific parameter beyond that achieved by testing, unless specifically identified in the relevant Construction Parameter Variation tables.

**4.1.3** If, when following the extended application procedure, any part of the classified product cannot be covered by the extended application rules, that part shall be omitted from the subsequent extended application report and classification report.

### 4.2 Procedure for evaluation

**4.2.1** Identify the variations from the original test specimen(s) which are required to be covered by an extended application report.

**4.2.2** Locate the variations in the appropriate parameter variation by reference to columns (1) and (2) of Annex A, Table A.1.

**4.2.3** Establish from the contents of column (3) of Annex A, Table A.1 whether any extended application is available without the need for further testing.

**4.2.4** Where this is deemed to be possible, this can be recorded in the extended application report, together with any appropriate restrictions and the stated rules from column (3) in Annex A, Table A.1.

**4.2.5** Where the variations required can only be achieved from additional testing according to column (4), the additional test can be made on a similar specimen type to the original test against which the extended application is sought. Alternatively, column (4) in Annex A, Table A.1 identifies an option for alternative testing and relevant test parameters.

### 4.3 Procedure for maximum field of extended application

**4.3.1** It is possible to provide a limited field of extended application from the results of a single test. However, where a manufacturer intends to produce a range of doorsets and openable windows incorporating single leaf door assemblies and also double leaf door assemblies with or without glazing, with alternative items of building hardware, etc., it is recommended that careful consideration is given to the complete range of doorset designs and openable window designs and options in order to minimize the testing required before testing commences.

**4.3.2** Establish all the parameter variations which are required to be part of the product range.

**EN 17020-4:2021 (E)**

**4.3.3** Determine which are the most important specification requirements and incorporate as many as possible into the specimen(s) for the first tests in the series.

**4.3.4** Conduct the first durability test or a series of tests and then establish which of the original desired parameter variations have not been covered by this test(s).

**4.3.5** Identify these parameter variations in Annex A, Table A.1 and establish if any extended application is possible without further testing.

**4.3.6** Record this for the extended application report together with any restrictions and rules given in column (3) in Annex A, Table A.1.

**4.3.7** Evaluate which, if any, of the desired parameter variations have not been covered by the initial field of extended application derived from 4.3.6 above.

**4.3.8** Determine if the product range is to include only single leaf doorsets or if the range is also to include double leaf configurations. Where only single leaf doorsets are to be part of the product range, the outstanding construction parameter variations shall only be incorporated into specimens for the single leaf doorsets. Where single leaf and double leaf doorsets are to be included in the product range, the outstanding construction parameter variations for the extended application of single leaf doorsets may be incorporated into either repeated single leaf doorset tests or, in the weakest option, as defined in column (4) of the table in Annex A, Table A.1, double leaf doorset configurations.

**4.3.9** Select the required outstanding parameter variations from column (1) and column (2) of Annex A, Table A.1 and observe from column (4) in Annex A, Table A.1 which are the most appropriate weakest specimen options for further testing.

**4.3.10** If the complete selection of required parameter variations has not been covered by the tests completed in accordance with 4.3.8 and 4.3.9 above, then an appropriate test or tests may be carried out with the additional product variations incorporated.

#### **4.4 Interpretation of test results**

**4.4.1** In order to maximize the extended field of application, it is important that the test reports shall record details of any failures occurred throughout the test duration.

**4.4.2** Where a series of tests have been conducted, the field of extended application shall be based on the lowest performance achieved from the complete series of tests, unless premature failure has been attributed to one or more specific construction parameter variations.

**4.4.3** Where it has been possible to identify specific parameter failures, the extended application for all other construction parameter variations can be based on the performance achieved after isolating the premature failure(s).

### **5 Extended application report**

Prepare an extended application report in accordance with the requirements of EN 15269-1, based on the results of evaluations in accordance with the above.

### **6 Classification report**

The classification report shall be determined from the results of the extended application report and shall be presented in accordance with EN 13501-2:2016, Annex A.

## Annex A (normative)

### Construction parameter variations

Table A.1 below is designed to be used by experts competent in the field of fire and smoke resistance and durability of self-closing testing of hinged and pivoted metal framed glazed doorsets and openable windows.

This table shall only be used to assess a field of extended application when at least one positive durability of self-closing test according to EN 1191 has generated a classification according to EN 13501-2 and EN 16034.

The first two columns identify possible variations to the construction details of the specimen tested. It is presupposed that the variations do not restrain the door/window closing.

Column (3) leads to the judgement of the possibility of extending the field of application.

Where additional tests are deemed to be necessary, the type of specimen approved for incorporation of the changed parameter is defined in column (4). Where it is possible to use information from tests performed on one configuration for evidence on a different configuration, this allowance has been made in order to reduce the overall number of tests required for extended application evaluation e.g. single action doorsets to double action doorsets.

Where an additional test is required in column (4), the test is a full scale test, unless otherwise specified.

In order to maximize the possible field of application from a minimum number of tests, the parameter changes have been spread over a series of test specimens. Where more than a single parameter variation is required, the influence on other variations shall also be taken into account.

All the rules in Table A.1, with exception are applicable to doorsets and openable windows. However, in the text only the word "doorset" is used. The word "doorset" can be replaced by "openable windows" in every rule.

NOTE Column (1) contains titles that are identical to the ones of EN 15269-5:2014+A1:2016, Table A.1, without reference to possible figures. For clarification the figures that are included in EN 15269-5:2014+A1:2016, Annex A can be used.

Table A.1 — Construction parameter variations

Construction parameter	Variation	Possibility of extension	Additional evidence required
(1)	(2)	(3)	(4)
<b>A Door leaf</b>			
For double leaf doorsets, both leaves shall be of the same basic construction.			
<b>A.1 General</b>			
A.1.1 Number of leaves	Single leaf from double leaf test	Possible	–
A.1.2 Number of leaves	Double leaf from single leaf test	Not possible without additional test	Additional test double leaf doorset
A.1.3 Intumescent seals between frame and door leaf/leaves	Location towards the frame rebate	Possible	–
A.1.4 Intumescent seals between frame and door leaf/leaves	Location away from the frame rebate	Possible	–
A.1.5 Intumescent seals between meeting edges of the door leaves	Location	Possible	–
A.1.6 Non-intumescent seals between frame and door leaf/leaves (draught/smoke/acoustic, etc.) – (Reaction to fire class A1 according to EN 13501-1) e.g. ceramic products (fitted in leaf or frame).	Location	Possible	–

Construction parameter	Variation	Possibility of extension	Additional evidence required
A.1.7 Non-intumescent seals between meeting edges of the door leaves (draught smoke/acoustic, etc.) – (Reaction to fire class A1 according to EN 13501-1)	Location	Possible providing the deformation of the seal will not increase during movement of the door leaf/leaves otherwise not possible without an additional test	Additional test double for single and double leaf doorsets or single for single leaf doorsets
A.1.8 Non-intumescent seals between door leaves and/or frames (draught/smoke/acoustic, etc.) – < Reaction to fire class A1 according to EN 13501-1 (fitted in leaf or frame)	Location	Possible providing the deformation of the seal will not increase during movement of the door leaf/leaves otherwise not possible without an additional test	Additional test double for single and double leaf doorsets or single for single leaf doorsets
A.1.9 Non-intumescent seals between door leaves and/or frames (draught/smoke/acoustic, etc.) – (Reaction to fire class A1 according to EN 13501-1), e.g. ceramic products (fitted in leaf or frame)	Add	Not possible without an additional test	Additional test double for single and double leaf doorsets or single for single leaf doorsets
A.1.10 Non-intumescent seals between door leaves and/or frames (draught/smoke/acoustic, etc.) – (Reaction to fire class A1 according to EN 13501-1), e.g. ceramic products (fitted in leaf or frame)	Remove	Possible	–
A.1.11 Non-intumescent seals between door leaves and/or frames (draught/smoke/acoustic, etc.) – < Reaction to fire class A1 according to EN 13501-1 (fitted in leaf or frame)	Add	Not possible without an additional test	Additional test double for single and double leaf doorsets or single for single leaf doorsets
A.1.12 Non-intumescent seals between door leaves and/or frames (draught/smoke/acoustic, etc. – < Reaction to fire class A1 according to EN 13501-1 (fitted in leaf or frame)	Remove	Possible	–

## EN 17020-4:2021 (E)

Construction parameter	Variation	Possibility of extension	Additional evidence required
A.1.13 Ventilation grilles (louvres) in door leaf tested without ventilation grille	Add	Possible providing the requirements of Annex B are fulfilled otherwise not possible without an additional test	Additional test single or double leaf doorset
A.1.14 Ventilation grilles (louvres) in door leaf	Remove	Possible	–
A.1.15 Ventilation grilles (louvres) in the infill of the door leaf tested with ventilation grille	Location in vertical direction	Possible	–
A.1.16 Ventilation grilles (louvres) in the infill of the door leaf tested with ventilation grille	Location in horizontal direction	Possible	–
A.1.17 Ventilation grilles (louvres) in door leaf tested with ventilation grille	Location in horizontal and/or vertical direction	Possible <a href="https://standards.iteh.ai/catalog/standards/sist/26d82544-2849-4241-8ac1-cac9781fc448/sist-en-17020-4-2021">SIST EN 17020-4:2021 https://standards.iteh.ai/catalog/standards/sist/26d82544-2849-4241-8ac1-cac9781fc448/sist-en-17020-4-2021</a>	–
A.1.18 Ventilation grilles (louvres) in door leaf or in the infill of the door leaf tested with ventilation grille	Smaller size	Possible	–
A.1.19 Ventilation grilles (louvres) in door leaf or in the infill of the door leaf tested with ventilation grille	Larger size	Possible providing the requirements of Annex B are fulfilled otherwise not possible without an additional test	Additional test single or double leaf doorset
A.1.20 Rebate (door leaves to frames)	Add	Possible	–
A.1.21 Rebate (meeting edges)	Add (one rebate or two rebates)	Possible	–

Construction parameter	Variation	Possibility of extension	Additional evidence required			
A.1.22 Rebate (door leaves to frames and meeting edges)	Remove	Possible	–			
A.1.23 Latched condition for single and double leaf doorsets	Change in latching condition	Possible in line with the following relationship:		Additional test double for single and double leaf doorsets or single for single leaf doorsets.		
			tested without a latch/lock		tested with a latch/lock but unlatched	tested with a latch/lock latched
		extension to: without a lock/latch	—		Possible	possible
		extension to: with lock/latch but unlocked/unlatched (disengaged)	Possible		—	possible
	extension to: with a lock/latch, latched	Not possible	Not possible	—		
A.1.24 Latching/locking	Remove from door leaf tested with latching/locking	Possible	–			