

SLOVENSKI STANDARD

SIST EN 50549-1:2019/AC:2019

01-junij-2019

**Zahteve za vzporedno vezavo generatorskih postrojev z razdelilnim omrežjem - 1.
del: Vezava z nizkonapetostnim razdelilnim omrežjem - Generatorski postroji do
vključno tipa B - Popravek AC**

Requirements for generating plants to be connected in parallel with distribution networks
- Part 1: Connection to a LV distribution network - Generating plants up to and including
Type B

iTeh STANDARD PREVIEW
Anforderungen für zum Parallelbetrieb mit einem Verteilnetz vorgesehene
Erzeugungsanlagen - Teil 1: Anschluss an das Niederspannungsverteilnetz bis
einschließlich Typ B

[SIST EN 50549-1:2019/AC:2019](#)

Exigences relatives aux centrales électriques destinées à être raccordées en parallèle à
des réseaux de distribution - Partie 1: Raccordement à un réseau de distribution BT -
Centrales électriques jusqu'au Type B inclus

Ta slovenski standard je istoveten z: EN 50549-1:2019/AC:2019-04

ICS:

29.160.20	Generatorji	Generators
29.240.01	Omrežja za prenos in distribucijo električne energije na splošno	Power transmission and distribution networks in general

SIST EN 50549-1:2019/AC:2019 en

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

[SIST EN 50549-1:2019/AC:2019](#)

<https://standards.iteh.ai/catalog/standards/sist/eb9f91d8-f3b7-460b-b0a1-f8d5bf02d0fe/sist-en-50549-1-2019-ac-2019>



Corrigendum to EN 50549-1:2019

English version

Replace the incomplete Table F.1 by the following complete table:

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

[SIST EN 50549-1:2019/AC:2019](#)

<https://standards.iteh.ai/catalog/standards/sist/eb9f91d8-f3b7-460b-b0a1-f8d5bf02d0fe/sist-en-50549-1-2019-ac-2019>

Table F.1 — Typical protection functions and related regulations on interface protection relays in the Italian solution

Protection function	Default threshold value	Default relay operate time	Maximum opening time of the output-break circuit (interface CB with tripping command operated from a voltage absence coil)
Maximum voltage U>.S1 (ANSI CODE 59.S1), 10 minutes mean function (according to EN 61000-4-30, Class S, but adopting a moving window with refresh time ≤ 3 s)	1,10 Vn	Start time ≤ 3 s, not adjustable. Delay time setting = 0 ms Depending on voltage values during the moving window. Maximum value 603s.	Depending on voltage values during the moving window. Maximum 603,70 s.
Maximum voltage U>.S2 (ANSI CODE 59.S2)	1,20 Vn	200 ms	270 ms
Minimum voltage U<.S1 (ANSI CODE 27.S1) ⁽¹⁾	0,85 Vn	1500 ms	1570 ms
Minimum voltage U<.S2 (ANSI CODE 27.S2) ⁽¹⁾	0,4 Vn	200 ms	270 ms
Maximum frequency f>.S2 (ANSI CODE 81.S2) ⁽²⁾	50,2 Hz	150 ms	170 ms
Minimum frequency f<.S2 (ANSI CODE 81.S2) ⁽²⁾	49,8 Hz	150 ms	170 ms
Maximum frequency f>.S1 (ANSI CODE 81.S1) ⁽²⁾	51,5 Hz	1,0 s	1,07 s
Minimum frequency f<.S1 (ANSI CODE 81.S1) ⁽²⁾	47,5 Hz	4,0 s	4,07 s
Maximum residual voltage U0> (ANSI CODE 59V0) ⁽³⁾	5 % Vrn ⁽⁴⁾	For protection use: 25 s For voltmetric unlock use (ANSI CODE 81V): 0 ms (equal to start time: 70 ms) https://standards.iteh.ai/catalog/standard/SIST-EN-50549-1-2019-ac-2019	For protection use: 25,07 s For voltmetric unlock use: equal to start time ⁽¹⁾
Maximum inverse sequence voltage U1> (ANSI CODE 59 Vi) ⁽¹⁾	15% Vn/En ⁽⁵⁾ (indicative, depending on the network)	For voltmetric unlock use (ANSI CODE 81V): 0 ms (equal to start time: 70 ms)	Equal to start time
Minimum direct sequence voltage Ud< (ANSI CODE 27 Vd) ⁽¹⁾	70% Vn/En ⁽⁵⁾ (indicative, depending on the network)	For voltmetric unlock use (ANSI CODE 81V): 0 ms (equal to start time: 70 ms)	Equal to start time
Transfer trip		<150 ms	<220 ms

(1) Threshold active only for inverters and rotating generators connected to distribution network with AC/AC converters. For rotating generators directly connected U<.S2: operate time 70 ms, threshold value 70%, U<.S1: excluded.

(2) For voltage values below 0,2 Vn, f>.S1, f>.S2 & f<.S1, f<.S2 protections shall be disabled.

(3) Function used both for tripping and for voltmetric unlock function.

(4) Regulation in % of nominal residual voltage Vrn in case of a phase to earth fault with 0 Ω fault resistance derived directly from an open delta winding or calculated internally the IPR from phase to earth voltages derived from non iron core voltage transducers.

(5) Regulation in % of nominal phase to earth or phase to phase voltage, according to voltage measurements methods.