



# SLOVENSKI STANDARD SIST EN 54-3:2014+A1:2019

01-julij-2019

Nadomešča:  
SIST EN 54-3:2014

---

## Sistemi za odkrivanje in javljanje požara ter alarmiranje - 3. del: Naprave za alarmiranje - Zvočne naprave

Fire detection and fire alarm systems - Part 3: Fire alarm devices - Sounders

Brandmeldeanlagen - Teil 3: Feueralarmeinrichtungen Akustische Signalgeber

Systemes de détection et d'alarme incendie - Partie 3: Dispositifs sonores d'alarme feu

Ta slovenski standard je istoveten z: **EN 54-3:2014+A1:2019**

### ICS:

13.220.20	Požarna zaščita	Fire protection
13.320	Alarmni in opozorilni sistemi	Alarm and warning systems

**SIST EN 54-3:2014+A1:2019**

**en,fr,de**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 54-3:2014+A1:2019

<https://standards.iteh.ai/catalog/standards/sist/d84aaf8d-eab3-4a86-b3ea-67caf2c333eb/sist-en-54-3-2014a1-2019>

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN 54-3:2014+A1**

March 2019

ICS 13.220.20

Supersedes EN 54-3:2014

English Version

## Fire detection and fire alarm systems - Part 3: Fire alarm devices - Sounders

Systèmes de détection et d'alarme incendie - Partie 3 :  
Dispositifs sonores d'alarme feu

Brandmeldeanlagen - Teil 3: Feueralarmeinrichtungen  
Akustische Signalgeber

This European Standard was approved by CEN on 8 May 2014 and includes Amendment 1 approved by CEN on 14 October 2018.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

<https://standards.iteh.ai/catalog/standards/sist/d84aaf8d-eab3-4a86-b3ea-67caf2c333eb/sist-en-54-3-2014a1-2019>



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

<b>Contents</b>	<b>Page</b>
European foreword.....	5
Introduction .....	8
<b>1 Scope.....</b>	<b>9</b>
<b>2 Normative references.....</b>	<b>9</b>
<b>3 Terms, definitions and abbreviations .....</b>	<b>10</b>
<b>3.1 Definitions .....</b>	<b>10</b>
<b>3.2 Abbreviations .....</b>	<b>12</b>
<b>4 Requirements.....</b>	<b>12</b>
<b>4.1 Compliance .....</b>	<b>12</b>
<b>4.2 Operational reliability.....</b>	<b>12</b>
<b>4.2.1 Duration of operation.....</b>	<b>12</b>
<b>4.2.2 Provision for external conductors .....</b>	<b>12</b>
<b>4.2.3 Flammability of materials.....</b>	<b>12</b>
<b>4.2.4 Enclosure protection.....</b>	<b>13</b>
<b>4.2.5 Access .....</b>	<b>13</b>
<b>4.2.6 Manufacturer's adjustment.....</b>	<b>13</b>
<b>4.2.7 On-site adjustment of the operation mode.....</b>	<b>13</b>
<b>4.2.8 Software controlled sounders.....</b>	<b>14</b>
<b>4.3 Performance parameters under fire conditions.....</b>	<b>15</b>
<b>4.3.1 Sound pressure level.....</b>	<b>15</b>
<b>4.3.2 Frequencies and sound pattern.....</b>	<b>15</b>
<b>4.3.3 Synchronisation.....</b>	<b>15</b>
<b>4.3.4 Performance of voice sounders .....</b>	<b>16</b>
<b>4.3.5 Voice sounders sequence timing .....</b>	<b>16</b>
<b>4.4 Durability of performance parameters under fire conditions .....</b>	<b>16</b>
<b>4.4.1 Temperature resistance .....</b>	<b>16</b>
<b>4.4.2 Humidity resistance .....</b>	<b>16</b>
<b>4.4.3 Shock and vibration resistance.....</b>	<b>17</b>
<b>4.4.4 Corrosion resistance.....</b>	<b>17</b>
<b>4.4.5 Electrical stability .....</b>	<b>17</b>
<b>5 Testing, assessment and sampling methods.....</b>	<b>17</b>
<b>5.1 General.....</b>	<b>17</b>
<b>5.1.1 Atmospheric conditions for tests .....</b>	<b>17</b>
<b>5.1.2 Operating conditions for tests.....</b>	<b>18</b>
<b>5.1.3 Mounting arrangements.....</b>	<b>18</b>
<b>5.1.4 Tolerances .....</b>	<b>18</b>
<b>5.1.5 Provision for tests.....</b>	<b>18</b>
<b>5.1.6 Test schedule.....</b>	<b>19</b>
<b>5.1.7 Reproducibility.....</b>	<b>20</b>
<b>5.2 Operational reliability.....</b>	<b>21</b>
<b>5.2.1 Duration of operation.....</b>	<b>21</b>
<b>5.2.2 Provision for external conductors .....</b>	<b>21</b>
<b>5.2.3 Flammability of materials.....</b>	<b>21</b>
<b>5.2.4 Enclosure protection.....</b>	<b>21</b>
<b>5.2.5 Access .....</b>	<b>23</b>

5.2.6	Manufacturer's adjustments.....	23
5.2.7	On site adjustments of the operating mode .....	23
5.2.8	Requirements for software controlled devices .....	23
5.3	Performance parameters under fire conditions .....	23
5.3.1	Sound pressure level .....	23
5.3.2	Frequencies and sound patterns.....	24
5.3.3	Synchronisation .....	24
5.3.4	Performance of voice sounders .....	25
5.3.5	Voice sounder sequence timing.....	26
5.4	Durability of performance parameters under fire conditions.....	27
5.4.1	Heat resistance .....	27
5.4.2	Humidity resistance.....	30
5.4.3	Shock and vibration resistance .....	32
5.4.4	Corrosion resistance, SO <sub>2</sub> corrosion (endurance) .....	36
5.4.5	Electrical stability .....	37
6	Assessment and verification of constancy of performance (AVCP).....	38
6.1	General .....	38
6.2	Type testing .....	38
6.2.1	General .....	38
6.2.2	Test samples, testing and compliance criteria.....	39
6.2.3	Test reports .....	39
6.3	Factory production control (FPC).....	39
6.3.1	General .....	39
6.3.2	Requirements.....	40
6.3.3	Product specific requirements.....	42
6.3.4	Initial inspection of factory and FPC.....	43
6.3.5	Continuous surveillance of FPC.....	43
6.3.6	Procedure for modifications.....	44
6.3.7	One-off products, pre-production products, (e.g prototypes) and products produced in very low quantities.....	44
7	Classification and designation .....	44
8	Marking, labelling and packaging.....	44
Annex A	(normative) $\square_{A1}$ Sound pressure level measurement for fire alarm sounders $\square_{A1}$ .....	46
A.1	General .....	46
A.2	Mounting arrangements.....	46
A.3	Instrumentation.....	46
A.4	Background noise level .....	46
A.5	Measurement of sound pressure level.....	46
Annex B	(normative) Comparative sound pressure level test during environmental conditioning.....	51
B.1	General .....	51
B.2	Test chamber.....	51
B.2.1	Size .....	51
B.2.2	Shape .....	51
B.2.3	Rigidity .....	52
B.2.4	Surface treatment.....	52
B.3	Mounting arrangements.....	52
B.4	Instrumentation.....	52
B.5	Background noise level .....	52
B.6	Test procedure .....	52
B.6.1	Number and positioning of microphones .....	52

## EN 54-3:2014+A1:2019 (E)

<b>B.6.2 Measurement of sound pressure level .....</b>	<b>53</b>
<b>Annex C (informative) Data supplied with sounders .....</b>	<b>56</b>
<b>Annex D (informative) Sound patterns used in some European countries .....</b>	<b>57</b>
<b>D.1 Introduction .....</b>	<b>57</b>
<b>D.2 Standards references .....</b>	<b>57</b>
<b>D.3 Information on sound patterns .....</b>	<b>58</b>
<b>D.3.1 Introduction .....</b>	<b>58</b>
<b>Annex E (informative) Comparison of flammability test requirements in various standards .....</b>	<b>61</b>
<b>E.1 Introduction .....</b>	<b>61</b>
<b>E.2 Relevant standards .....</b>	<b>61</b>
<b>E.3 Vertical burning tests .....</b>	<b>61</b>
<b>E.4 Horizontal burning tests .....</b>	<b>62</b>
<b>Annex ZA (informative) Relationship of this European Standard with Regulation (EU) No.305/2011 .....</b>	<b>64</b>
<b>Bibliography .....</b>	<b>67</b>

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 54-3:2014+A1:2019](https://standards.iteh.ai/catalog/standards/sist/d84aaf8d-eab3-4a86-b3ea-67caf2c333eb/sist-en-54-3-2014a1-2019)  
<https://standards.iteh.ai/catalog/standards/sist/d84aaf8d-eab3-4a86-b3ea-67caf2c333eb/sist-en-54-3-2014a1-2019>

## European foreword

This document (EN 54-3:2014+A1:2019) has been prepared by Technical Committee CEN/TC 72 “Fire detection and fire alarm systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2019, and conflicting national standards shall be withdrawn at the latest by March 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes A1 EN 54-3:2014 A1.

This document includes Amendment 1 approved by CEN on 14 October 2018.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

A1 EN 54-3:2001 A1 has been revised so as to align with the second answer of CEN/TC 72 to Mandate M/109. A1 EN 54-3:2014 A1 includes new clauses and annexes as follows:

- Requirements for software controlled devices (5.2.8);
- Clause 6 Assessment and verification of constancy of performance (AVCP);
- Clause 7 Classification and designation;
- Clause 8 Marking, labelling and packaging;
- Annex C Data supplied with sounders;
- Annex D (informative) Sound patterns used in some European countries;
- Annex E (informative) Comparison of flammability test requirements in various standards.

The previous Annex C dealt with the requirements and test methods for voice sounders. The content of this annex has been integrated in the main body of the standard, specifically under 4.3.3, 4.3.4, 4.3.5, 5.3.3, 5.3.4 and 5.3.5. In addition, Annex ZA has been revised to align with the Construction Products Regulation (CPR).

A1 Amendment 1 to EN 54-3:2014 corrects some of the errors and clarifies some of the points. A1

EN 54, *Fire detection and fire alarm systems*, consists of the following parts:

- *Part 1: Introduction*
- *Part 2: Control and indicating equipment*

**EN 54-3:2014+A1:2019 (E)**

- *Part 3: Fire alarm devices – Sounders*
- *Part 4: Power supply equipment*
- *Part 5: Heat detectors – Point detectors*
- *Part 7: Smoke detectors – Point detectors using scattered light, transmitted light or ionization*
- *Part 10: Flame detector – Point detectors*
- *Part 11: Manual call points*
- *Part 12: Smoke detectors – Line detector using an optical light beam*
- *Part 13: Compatibility assessment of system components*
- *Part 14: Guidelines for planning, design, installation, commissioning, use and maintenance*
- *Part 15: Point detectors using a combination of detected phenomena*
- *Part 16: Voice alarm control and indicating equipment*
- *Part 17: Short circuit isolators*
- *Part 18: Input/output devices*
- *Part 20: Aspirating smoke detectors*
- *Part 21: Alarm transmission and fault warning routine equipment*
- *Part 22: Line-type heat detectors*
- *Part 23: Fire alarm devices – Visual alarms*
- *Part 24: Components of voice alarm systems – Loudspeakers*
- *Part 25: Components using radio links and system requirements*
- *Part 26: Carbon monoxide detectors – Point detectors*
- *Part 27: Duct smoke detectors*
- *Part 28: Non-resettable (digital) line type heat detectors*
- *Part 29: Multi-sensor fire detectors - Point detectors using a combination of smoke and heat sensors*
- *Part 30: Multi-sensor fire detectors - Point detectors using a combination of carbon monoxide and heat sensors*
- *Part 31: Multi-sensor detector – Point detectors using a combination of smoke, carbon monoxide and optionally heat sensors*
- *Part 32: Guidelines for the planning, design, installation, commissioning, use and maintenance of voice alarm systems*

iTech STANDARD PREVIEW  
(standards.iteh.ai)

SIST EN 54-3:2014+A1:2019  
<https://standards.iteh.ai/catalog/standards/sist/d8-4aa8d-eab3-4a86-b3ea-67caf2c333eb/sist-en-54-3-2014a1-2019>



NOTE This list includes standards that are in preparation and other standards may be added. For current status of published standards refer to [www.cen.eu](http://www.cen.eu).

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 54-3:2014+A1:2019](https://standards.iteh.ai/catalog/standards/sist/d84aaf8d-eab3-4a86-b3ea-67caf2c333eb/sist-en-54-3-2014a1-2019)

<https://standards.iteh.ai/catalog/standards/sist/d84aaf8d-eab3-4a86-b3ea-67caf2c333eb/sist-en-54-3-2014a1-2019>

## Introduction

The purpose of a fire alarm sounder is to warn person(s) within, or in the vicinity of, a building of the occurrence of a fire emergency situation in order to enable such a person(s) to take appropriate measures.

This European Standard recognizes that the exact nature of the sound requirements, i.e. its frequency range, temporal pattern and output level will vary according to the nature of the installation, the type of risk present and appropriate measures to be taken, the type of signals used by other non-emergency alarms (see, for example, EN ISO 7731) and national differences in custom and practice. The resulting standard specifies, therefore, a common method for the testing of the operational performance of sounders against the specification declared by the manufacturer rather than imposing common requirements.

In some European countries, specific frequencies of sound and sound patterns are used. These may be given in national codes or standards (see Annex D). Attention is drawn to national safety regulations which may specify maximum safe sound pressure level received by occupants of a building.

Attention is also drawn to ISO 8201:1987, *Acoustics – Audible emergency evacuation signal*, the international standard which specifies the temporal pattern and the required sound pressure level of an audible emergency evacuation signal.

This European Standard gives common requirements for sounders as well as for their performance under climatic, mechanical and electrical interference conditions which are likely to occur in the service environment. This European Standard covers sounders for either an indoor or an outdoor application environment category.

In fire detection and fire alarm systems, voice sounders are used as alarm devices for warning the occupants of a building of the occurrence of a fire risk, using a combination of an attention-drawing signal and dedicated voice message(s). The requirements, test methods and performance criteria specified in this standard for sounders are also applicable to voice sounders. Additional requirements, test methods and performance criteria specific to voice sounders are also incorporated.

## 1 Scope

This European Standard specifies the requirements, test methods and performance criteria for fire alarm sounders, including voice sounders, in a fixed installation intended to signal an audible warning between the fire detection and fire alarm systems and the occupants of a building (see EN 54-1:2011).

This European Standard provides for the assessment and verification of constancy of performance (AVCP) of fire alarm sounders to this EN.

This European Standard is not intended to cover:

- a) loudspeaker type devices primarily intended for emitting emergency voice messages that are generated from an external audio source;
- b) supervisory sounders, for example, within the control and indicating equipment.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54-1:2011, *Fire detection and fire alarm systems — Part 1: Introduction*

EN 50130-4:2011, *Alarm systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems*

EN 60068-1:1994, *Environmental testing — Part 1: General and guidance (IEC 60068-1:1988 + Corrigendum 1988 + A1:1992)*

EN 60068-2-1:2007, *Environmental testing — Part 2-1: Tests — Test A: Cold (IEC 60068-2-1:2007)*

EN 60068-2-2:2007, *Environmental testing — Part 2-2: Tests — Test B: Dry heat (IEC 60068-2-2:2007)*

EN 60068-2-6:2008, *Environmental testing — Part 2-6: Tests — Test Fc: Vibration (sinusoidal)(IEC 60068-2-6:2007)*

EN 60068-2-27:2009, *Environmental testing — Part 2-27: Tests — Test Ea and guidance: Shock (IEC 60068-2-27:2008)*

EN 60068-2-30:2005, *Environmental testing — Part 2-30: Tests — Test Db: Damp heat, cyclic (12 h + 12 h cycle) (IEC 60068-2-30:2005)*

EN 60068-2-42:2003, *Environmental testing — Part 2-42: Tests — Test Kc: Sulphur dioxide test for contacts and connections (IEC 60068-2-42:2003)*

EN 60068-2-75:1997, *Environmental testing — Part 2-75: Tests — Test Eh: Hammer tests (IEC 60068-2-75:1997)*

EN 60068-2-78:2013, *Environmental testing — Part 2-78: Tests — Test Cab: Damp heat, steady state (IEC 60068-2-78:2012)*

EN 60529:1991, *Degrees of protection provided by enclosures (IP Code) (IEC 60529:1989)*

**EN 54-3:2014+A1:2019 (E)**

EN 60529:1991/A1:2000, *Degrees of protection provided by enclosures (IP Code)* (IEC 60529:1989/A1:1999)

Ⓐ EN 60529:1991/A2:2013, *Degrees of protection provided by enclosures (IP Code)* (IEC 60529:1989/A2:2013) Ⓐ

EN 60695-11-10:2013, *Fire hazard testing — Part 11-10: Test flames — 50 W horizontal and vertical flame test methods* (IEC 60695-11-10:2013)

Ⓐ EN 60695-11-20:2015, *Fire hazard testing — Part 11-20: Test flames — 500 W flame test methods* (IEC 60695-11-20:2015) Ⓐ

EN 61672-1:2003, *Electroacoustics — Sound level meters — Part 1: Specifications* (IEC 61672-1:2002)

**3 Terms, definitions and abbreviations**

For the purposes of this European Standard, the following terms, definitions and abbreviations and those given in EN 54-1 apply.

**3.1 Definitions****3.1.1****A-weighted sound pressure level**

$L_{pA}$   
Ⓐ sound pressure level, expressed in dB(A), which is 20 times the logarithm to base ten of the ratio of the A-weighted sound pressure to the reference pressure of 20  $\mu$ Pa at 1 kHz Ⓐ

Note 1 to entry: The A-weighting characteristics are given in EN 61672-1:2003.

**3.1.2****delta sound pressure level** **$\Delta(L_{pA})$** 

decrease in the mean A-weighted sound pressure level between measurements on the same specimen (Annex B)

Note 1 to entry: In this standard  $\Delta(L_{pA})$  is used to compare the sound pressure level measured during environmental tests with that first measured on the same specimen during the reproducibility test.

**3.1.3****equivalent sound pressure level** **$L_{Aeq,T}$** 

the value of the sound pressure level, in dB(A), of continuous sound that, within a specified time interval, T, has the same mean-square sound pressure as a sound that varies with time

**3.1.4****fire alarm sounder**

sound generating device intended to signal an audible warning of fire between a fire detection and fire alarm system and the occupants of a building

**3.1.5****maximum sound pressure level** **$L_{AFmax,T}$** 

the maximum value of the sound pressure level, in dB(A), measured within a specified time interval, T and with a specified time weighting

Note 1 to entry: For application within the framework of this standard the time weighting Fast applies. Refer to EN 61672-1:2003.

### 3.1.6 mode (of operation)

one of a possible number of pre-defined sounds (or sound outputs) of the sounder which can be selected by means specified by the manufacturer

EXAMPLE Sound patterns, sound pressure levels.

### 3.1.7 reference point

point representing the origin of the sound within or on the surface of the sounder as specified by the manufacturer

Note 1 to entry: The reference point is used in Annex A.

### 3.1.8 sound pattern

pre-defined acoustic alarm signal

Note 1 to entry: Sound pattern is also often referred to as tone.

### 3.1.9 supervisory sounder

audible device on a piece of equipment used for drawing attention to a change of status

Note 1 to entry: Supervisory sounders are often mounted within the fire detection and fire alarm control and indicating equipment.

<https://standards.iteh.ai/catalog/standards/sist/d84aaf8d-eab3-4a86-b3ea-67caf2c333eb/sist-en-54-3-2014a1-2019>

### 3.1.10 type A sounder

device primarily intended for indoor applications

Note 1 to entry: Type A sounders may be suitable for some protected outdoor situations.

### 3.1.11 type B sounder

device primarily intended for outdoor applications

Note 1 to entry: Type B sounders may be more suitable than type A sounders for some indoor situations where high temperature and/or humidity are present.

### 3.1.12 volume control

means for adjusting sound pressure level

## EN 54-3:2014+A1:2019 (E)

### 3.2 Abbreviations

AC	Alternating current
AVCP	Assessment and verification of constancy of performance
CWFT	Classified without Further Testing
DC	Direct current
DoP	Declaration of performance
MS	Member states
NPD	No performance determined
RMS	Root mean square
SPL	Sound pressure level

## 4 Requirements

### 4.1 Compliance

In order to comply with this standard, sounders shall meet the requirements of this clause, which shall be verified by visual inspection or engineering assessment and shall be tested as described in Clause 5 and shall meet the requirements of the tests.

### 4.2 Operational reliability

#### 4.2.1 Duration of operation

The sounder shall be rated for at least 100 h operation. No limitation by the manufacturer on duty factor or maximum on-time shall prevent the device from operating the 1 h 'on' 1 h 'off' cycle required by the test procedure described in 5.2.1.

**A1** This requirement does not apply to the capacity of batteries that may be used within sounders as a means of local storage of operating power. The capacity and charging requirements of such batteries need to meet the requirement of the system. **A1**

#### 4.2.2 Provision for external conductors

The sounder, unless it is a radio-linked component not using wires, shall provide space within its enclosure for external conductors to be brought in and terminated. Entry holes for conductors or cables shall be provided or the location where such holes are to be made shall be indicated, by providing a template or some other suitable means.

Terminals for connecting external conductors to the sounder shall be designed so that the conductors are clamped between metal surfaces without being damaged.

This requirement shall be assessed as specified in 5.2.2.

#### 4.2.3 Flammability of materials

Plastic materials used in the construction of sounders shall comply with the following flammability requirements:

- EN 60695-11-10:2013 Class V-2 or HB75 for devices consuming less than or equal to 15 W of power;
- A1** EN 60695-11-20:2015 Class 5VB **A1** for devices consuming more than 15 W of power.

NOTE Annex E gives information on the test requirements and classification given in the European Standards and equivalent flammability ratings in UL 94.

This shall be assessed as specified in 5.2.3.

#### 4.2.4 Enclosure protection

The degree of protection provided by the enclosure of the sounders shall meet the following requirements:

- a) Type A sounders: Code IP21C of  $\text{A1}$  EN 60529:1991 as amended by EN 60529:1991/A1:2000 and EN 60529:1991/A2:2013  $\text{A1}$ ;
- b) Type B sounders: Code IP33C of  $\text{A1}$  EN 60529:1991 as amended by EN 60529:1991/A1:2000 and EN 60529:1991/A2:2013  $\text{A1}$ .

This shall be assessed as specified in 5.2.4 and meet the compliance criteria of 5.2.4.3.

#### 4.2.5 Access

Means shall be provided to limit access for removal of parts or the whole device and to make adjustment to the mode of operation, e.g. special tool, codes, hidden screws, seals, etc.

NOTE The use of a special tool is intended to discourage unauthorised persons from easily accessing the equipment.

This requirement shall be assessed as specified in 5.2.5.

#### 4.2.6 Manufacturer's adjustment

It shall not be possible to change the manufacturer's settings or to access the message recording function of voice sounders except by special means (e.g. the use of a special code or tool) or by breaking or removing a seal.

This requirement shall be assessed as specified in 5.2.6.

#### 4.2.7 On-site adjustment of the operation mode

If there is provision for on-site adjustment of the mode of operation of the sounder:

- a) For each setting, at which the manufacturer claims compliance with this standard, the sounder shall comply with 4.2.6.
- b) Any setting(s), at which the manufacturer does not claim compliance with this standard, shall comply with 4.2.6 and:
  - 1)  $\text{A1}$  for volume controls, the limits of the compliant range of sound pressure levels shall be clearly shown in the associated data,  $\text{A1}$
  - 2)  $\text{A1}$  for sound pattern(s), the compliant setting(s) shall be clearly marked in the associated data.  $\text{A1}$

These adjustments may be carried out at the sounder or at the control and indicating equipment.

This requirement shall be assessed as specified in 5.2.7.