

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Explosive atmospheres –  
Part 20-1: Material characteristics for gas and vapour classification – Test  
methods and data**

**Atmosphères explosives –  
Partie 20-1: Caractéristiques des produits pour le classement des gaz et des  
vapeurs – Méthodes et données d'essai**

[ISO/IEC 80079-20-1:2017](https://standards.iteh.ai/ISO/IEC/80079-20-1/2017)

<https://standards.iteh.ai/catalog/standards/iso/bd9011eb-f114-411f-b21a-a9ff2025f1ec/iso-iec-80079-20-1-2017>



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2017 ISO/IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about ISO/IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'ISO/IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

#### IEC Catalogue - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

#### IEC publications search - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### IEC Glossary - [std.iec.ch/glossary](http://std.iec.ch/glossary)

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [csc@iec.ch](mailto:csc@iec.ch).

### A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Catalogue IEC - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

#### Recherche de publications IEC - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

#### Glossaire IEC - [std.iec.ch/glossary](http://std.iec.ch/glossary)

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

#### Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [csc@iec.ch](mailto:csc@iec.ch).



# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



**Explosive atmospheres –**  
**Part 20-1: Material characteristics for gas and vapour classification – Test**  
**methods and data**

**Atmosphères explosives –**  
**Partie 20-1: Caractéristiques des produits pour le classement des gaz et des**  
**vapeurs – Méthodes et données d'essai**

<https://standards.iteh.ai/catalog/standards/iso/bd9011eb-f114-411f-b21a-a9ff2025f1ec/iso-iec-80079-20-1-2017>

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

**Warning! Make sure that you obtained this publication from an authorized distributor.**  
**Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references .....	7
3 Terms and definitions .....	7
4 Classification of gases and vapours.....	9
4.1 General.....	9
4.2 Classification according to the maximum experimental safe gap (MESG).....	9
4.3 Classification according to the minimum igniting current ratio (MIC ratio).....	10
4.4 Classification according to the similarity of chemical structure .....	10
4.5 Classification of mixtures of gases .....	10
5 Data for flammable gases and vapours, relating to the use of equipment.....	11
5.1 Determination of the properties .....	11
5.1.1 General .....	11
5.1.2 Equipment group .....	11
5.1.3 Flammable limits.....	11
5.1.4 Flash point (FP).....	11
5.1.5 Temperature class .....	12
5.1.6 Minimum igniting current (MIC).....	12
5.1.7 Auto-ignition temperature (AIT).....	12
5.2 Properties of particular gases and vapours .....	12
5.2.1 Coke oven gas.....	12
5.2.2 Ethyl nitrite .....	12
5.2.3 MESG of carbon monoxide .....	12
5.2.4 Methane, Equipment Group IIA.....	13
6 Method of test for the maximum experimental safe gap (MESG).....	13
6.1 Outline of method .....	13
6.2 Test apparatus.....	13
6.2.1 General .....	13
6.2.2 Material and mechanical strength .....	14
6.2.3 Exterior chamber .....	14
6.2.4 Interior chamber .....	14
6.2.5 Gap adjustment .....	14
6.2.6 Injection of mixture .....	14
6.2.7 Position of ignition source.....	14
6.3 Procedure .....	14
6.3.1 Preparation of gas mixtures .....	14
6.3.2 Temperature and pressure.....	14
6.3.3 Gap adjustment .....	15
6.3.4 Ignition .....	15
6.3.5 Observation of the ignition process.....	15
6.4 Determination of maximum experimental safe gap (MESG).....	15
6.4.1 General .....	15
6.4.2 Preliminary tests.....	15
6.4.3 Confirmatory tests .....	15
6.4.4 Reproducibility of maximum experimental safe gaps (MESG).....	15
6.4.5 Tabulated values .....	16

6.5	Verification of the MESH determination method .....	16
7	Method of test for auto-ignition temperature (AIT).....	16
7.1	Outline of method .....	16
7.2	Apparatus .....	16
7.2.1	General .....	16
7.2.2	Test vessel and support.....	17
7.2.3	Thermocouples .....	17
7.2.4	Oven .....	17
7.2.5	Metering devices .....	18
7.2.6	Mirror .....	18
7.2.7	Timer .....	18
7.2.8	Equipment for purging the test vessel with air.....	18
7.2.9	Automated apparatus.....	18
7.3	Sampling, preparation and preservation of test samples .....	19
7.3.1	Sampling .....	19
7.3.2	Preparation and preservation.....	19
7.4	Procedure .....	19
7.4.1	General .....	19
7.4.2	Sample injection .....	20
7.4.3	Determination of the auto-ignition temperature (AIT).....	20
7.5	Auto-ignition temperature (AIT) .....	21
7.6	Validity of results .....	21
7.6.1	Repeatability .....	21
7.6.2	Reproducibility.....	21
7.7	Data.....	22
7.8	Verification of the auto-ignition temperature determination method .....	22
Annex A (normative)	Ovens of test apparatus for the tests of auto-ignition temperature .....	23
A.1	General.....	23
A.2	“IEC oven” .....	23
A.3	“DIN oven” .....	23
Annex B (informative)	Tabulated values .....	30
Annex C (informative)	Determination of cool flames .....	84
Annex D (informative)	Volume dependence of auto-ignition temperature.....	86
Bibliography	.....	87
Figure 1	– Test apparatus .....	13
Figure A.1	– Test apparatus: assembly .....	24
Figure A.2	– Section A-A (flask omitted) .....	25
Figure A.3	– Base heater (board made of refractory material) .....	25
Figure A.4	– Flask guide ring (board made of refractory material) .....	26
Figure A.5	– Neck heater (board made of refractory material) .....	26
Figure A.6	– Oven.....	27
Figure A.7	– Lid of steel cylinder.....	28
Figure A.8	– Lid of steel cylinder.....	29
Figure A.9	– Injection of gaseous sample.....	29
Figure C.1	– Additional thermocouple to detect cool flames .....	84

Figure C.2 – ‘Negative temperature coefficient’ shown for butyl butyrate as an example .....	85
Figure D.1 – Volume dependence of auto-ignition temperature .....	86
Table 1 – Classification of temperature class and range of auto-ignition temperatures.....	12
Table 2 – Values for verification of the apparatus .....	16
Table 3 – Values for verification of the apparatus .....	22
Table B.1 – Material data.....	32

**iTeh Standards**  
**(<https://standards.iteh.ai>)**  
**Document Preview**

[ISO/IEC 80079-20-1:2017](#)

<https://standards.iteh.ai/catalog/standards/iso/bd9011eb-f114-411f-b21a-a9ff2025f1ec/iso-iec-80079-20-1-2017>

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### EXPLOSIVE ATMOSPHERES –

#### Part 20-1: Material characteristics for gas and vapour classification – Test methods and data

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard ISO/IEC 80079-20-1 has been prepared by subcommittee 31M: Non-electrical equipment and protective systems for explosive atmospheres, of IEC technical committee 31: Equipment for explosive atmospheres.

This first edition of ISO/IEC 80079-20-1 cancels and replaces IEC 60079-20-1:2010. It constitutes a technical revision. No significant changes were made with respect to IEC 60079-20-1:2010.

It is published as a double logo standard.

The text of this standard is based on the following documents:

FDIS	Report on voting
31M/122/FDIS	31M/126/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60079 series, under the general title: *Explosive atmospheres*, as well as the International Standard 80079 series, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh Standards

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

[ISO/IEC 80079-20-1:2017](https://standards.iteh.ai/catalog/standards/iso/bd9011eb-f114-411f-b21a-a9ff2025f1ec/iso-iec-80079-20-1-2017)

<https://standards.iteh.ai/catalog/standards/iso/bd9011eb-f114-411f-b21a-a9ff2025f1ec/iso-iec-80079-20-1-2017>



## EXPLOSIVE ATMOSPHERES –

### Part 20-1: Material characteristics for gas and vapour classification – Test methods and data

#### 1 Scope

This part of ISO/IEC 80079 provides guidance on classification of gases and vapours. It describes a test method intended for the measurement of the maximum experimental safe gaps (MESG) for gas-air mixtures or vapour-air mixtures under normal conditions of temperature and pressure (20 °C, 101,3 kPa) so as to permit the selection of an appropriate group of equipment. This document also describes a test method intended for use in the determination of the auto-ignition temperature (AIT) of a vapour-air mixture or gas-air mixture at atmospheric pressure, so as to permit the selection of an appropriate temperature class of equipment.

Values of chemical properties of materials are provided to assist in the selection of equipment to be used in hazardous areas. Further data may be added as the results of validated tests become available.

The materials and the characteristics included in a table (see Annex B) have been selected with particular reference to the use of equipment in hazardous areas. The data in this document have been taken from a number of references which are given in the bibliography.

These methods for determining the MESG or the AIT may also be used for gas-air-inert mixtures or vapour-air-inert mixtures. However, data on air-inert mixtures are not tabulated.

#### 2 Normative references

[ISO/IEC 80079-20-1:2017](https://standards.iteh.ai/catalog/standards/iso/bd9011eb-f114-411f-b21a-a9ff2025f1ec/iso-iec-80079-20-1-2017)

<https://standards.iteh.ai/catalog/standards/iso/bd9011eb-f114-411f-b21a-a9ff2025f1ec/iso-iec-80079-20-1-2017>

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-426, *International Electrotechnical Vocabulary – Part 426: Electrical apparatus for explosive atmospheres* (available at <http://www.electropedia.org/>)

IEC 60079-11, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety "i"*

IEC 60079-14, *Explosive atmospheres – Part 14: Electrical installations design, selection and erection*

#### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-426 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

### **3.1 auto-ignition**

reaction which is evidenced by a clearly perceptible flame and/or explosion, and for which the ignition delay time does not exceed 5 min

Note 1 to entry: See 7.2.2 for a test method.

### **3.2 ignition delay time**

time between the completed injection of the flammable material and the ignition

### **3.3 auto-ignition temperature**

#### **AIT**

lowest temperature (of a surface) at which under specified test conditions an ignition of a flammable gas or vapour in mixture with air or air-inert gas occurs

Note 1 to entry: See Clause 7 for a test method.

### **3.4 maximum experimental safe gap**

#### **MESG**

maximum gap of a joint of 25 mm in width which prevents any transmission of an explosion during tests made under the conditions specified in this document

Note 1 to entry: See Clause 6 for a test method.

### **3.5 minimum ignition current**

#### **MIC**

minimum current in a specified test circuit that causes the ignition of the explosive test mixture in the spark test apparatus according to IEC 60079-11

Note 1 to entry: See 5.1.6 for the test circuit.

### **3.6 flammable limits**

lower flammable limit (LFL) and upper flammable limit (UFL) of gas in a gas-air mixture, between which a flammable mixture is formed

Note 1 to entry: The term “explosive limits” is used especially in European standardization and regulations interchangeably to describe these limits.

Note 2 to entry: The concentration can be expressed as either a volume fraction or a mass per unit volume.

#### **3.6.1 lower flammable limit**

##### **LFL**

concentration of flammable gas or vapour in air, below which an explosive gas atmosphere does not form

Note 1 to entry: For the purposes of Ex Equipment, this was previously referred to as the lower explosive limit (LEL).

Note 2 to entry: The concentration can be expressed as either a volume fraction or a mass per unit volume.

#### **3.6.2 upper flammable limit**

##### **UFL**

concentration of flammable gas or vapour in air, above which an explosive gas atmosphere does not form

Note 1 to entry: For the purposes of Ex Equipment, this was previously referred to as the upper explosive limit (UEL).

Note 2 to entry: The concentration can be expressed as either a volume fraction or a mass per unit volume.

### **3.7 equipment grouping**

classification system of equipment related to the explosive atmosphere for which they are intended to be used

Note 1 to entry: IEC 60079-0 identifies three equipment groups:

Group I – equipment for mines susceptible to fire damp;

Group II, which is sub-divided into groups IIA, IIB and IIC – equipment for all places with an explosive gas atmosphere other than mines susceptible to fire damp;

Group III, which is sub-divided into groups IIIA, IIIB and IIIC – equipment for all places with an explosive dust atmosphere other than mines susceptible to fire damp.

### **3.8 flash point FP**

lowest liquid temperature at which, under specified test conditions, a liquid gives off vapours in quantity such as to be capable of forming an ignitable vapour-air mixture

### **3.9 gas**

gaseous phase of a substance that cannot reach equilibrium with its liquid or solid state in the temperature and pressure range of interest

Note 1 to entry: This is a simplification of the scientific definition, and merely requires that the substance is above its boiling point or sublimation point at the ambient temperature and pressure.

### **3.10 vapour**

gaseous phase of a substance that can reach equilibrium with its liquid or solid state in the temperature and pressure range of interest

Note 1 to entry: This is a simplification of the scientific definition, and merely requires that the substance is below its boiling point or sublimation point at the ambient temperature and pressure.

## **4 Classification of gases and vapours**

### **4.1 General**

Equipment Group I addresses mines susceptible to firedamp.

NOTE Firedamp consists mainly of methane, but always contains small quantities of other gases, such as nitrogen, carbon dioxide, and hydrogen, and sometimes ethane and carbon monoxide. The terms firedamp and methane are used frequently in mining practice as synonyms.

Equipment Group II addresses flammable gases and vapours other than in mines susceptible to firedamp. Equipment Group II gases and vapours are classified according to their MESG and/or MIC ratio into equipment groups IIA, IIB and IIC.

All flammable materials are classified according to their AIT into temperature classes.

### **4.2 Classification according to the maximum experimental safe gap (MESG)**

Gases and vapours may be classified according to their MESG into Equipment Groups IIA, IIB or IIC, based on the determination method described in this document. In order to ensure standardized results the MESG apparatus is dimensioned to avoid the possible effects of obstruction on the safe gaps.

NOTE 1 The standard method for determining MESG is described in 6.2, but where determinations have been undertaken only in an 8 l spherical vessel with ignition close to the flange gap these can be accepted provisionally.

NOTE 2 The design of the test apparatus for safe gap determination, other than that used for selecting the appropriate equipment group of enclosure for a particular gas, may need to be different to the one described in this document. For example, the volume of the enclosure, flange width, gas concentrations and the distance between the flanges and any external wall or obstruction may have to be varied. As the design depends on the particular investigation which is to be undertaken, it is impracticable to recommend specific design requirements, but for most applications the general principles and precautions indicated in this document will still apply.

NOTE 3 In IEC 60079-14 minimum distances of obstruction from the flameproof flange joints related to the equipment group of the hazardous area are given.

For the purpose of classification the MESG limits are:

Equipment Group IIA:  $MESG \geq 0,90$  mm.

Equipment Group IIB:  $0,50 \text{ mm} < MESG < 0,90$  mm.

Equipment Group IIC:  $MESG \leq 0,50$  mm.

Determination of both the MESG and MIC ratio is required when  $0,50 < MESG < 0,55$ . Then the equipment group is determined by MIC ratio,

NOTE 4 For gases and highly volatile liquids, the MESG is determined at 20 °C.

NOTE 5 If it was necessary to do the MESG determination at temperatures higher than ambient temperature a temperature 5 K above that needed to give the necessary vapour pressure or 50 K above the flash point is used and this value of MESG is given in the table and the classification of the equipment group is based on this result.

### 4.3 Classification according to the minimum igniting current ratio (MIC ratio)

Gases and vapours may be classified according to the ratio of their minimum igniting currents (MIC) to the ignition current of laboratory methane into Equipment Groups IIA, IIB or IIC. The purity of laboratory methane shall be not less than 99,9 % by volume.

NOTE The standard method of determining MIC ratios is with the apparatus described in IEC 60079-11, but where determinations have been undertaken in other apparatus these can be accepted provisionally.

For the purpose of classification the MIC ratios are:

Equipment Group IIA:  $MIC > 0,80$ .

Equipment Group IIB:  $0,45 \leq MIC \leq 0,80$ .

Equipment Group IIC:  $MIC < 0,45$ .

Determination of both the MESG and MIC ratio is required when  $0,70 < MIC < 0,90$  or  $0,40 < MIC < 0,50$ . Then the equipment group is determined by MESG.

### 4.4 Classification according to the similarity of chemical structure

When a gas or vapour is a member of a homologous series of compounds, the classification of the gas or vapour can provisionally be inferred from the data of the neighbouring members of the series.

The classification according to the similarity of chemical structure is not allowed if the classification of one of the neighbouring members is based on MESG and the other on MIC ratio.

### 4.5 Classification of mixtures of gases

Mixtures of gases should generally be allocated to an equipment group only after a special determination of MESG or MIC ratio. One method to estimate the equipment group is to determine the MESG of the mixture by applying a form of Le Châtelier's principle:

$$MESG_{\text{mix}} = \frac{1}{\sum_i \left( \frac{X_i}{MESG_i} \right)}$$

Where  $X_i$  is the percentage by volume of material  $i$  and  $MESG_i$  is the MESG of material  $i$ .

This method should not be applied in case of exceptions to the Le Châtelier's principle and to mixtures and/or streams that have:

- a) acetylene or its equivalent hazard (e.g. self-decomposition properties);
- b) oxygen or other strong oxidizer as one of the components;
- c) large concentrations (over 5 % by volume) of carbon monoxide. Because unrealistically high MESG values may result, caution should be exercised with two component mixtures where one of the components is an inert, such as nitrogen.

For mixtures containing an inert such as nitrogen in concentrations less than 5 % by volume, use an MESG of infinity. For mixtures containing an inert such as nitrogen in concentrations 5 % by volume and greater, use an MESG of 2.

NOTE An alternate method that includes stoichiometric ratios is presented in the essay "Maximum experimental safe gap of binary and ternary mixtures," by Brandes and Redeker.

## 5 Data for flammable gases and vapours, relating to the use of equipment

### 5.1 Determination of the properties

#### 5.1.1 General

The compounds listed in this document are in accordance with Clause 4, or have physical properties similar to those of other compounds in that list.

#### 5.1.2 Equipment group

The equipment groups are the result of MESG or MIC ratio determination except where there is no value listed for MESG or MIC ratio. For these, the equipment group is based on chemical similarity (see Clause 4).

NOTE If it was necessary to do the MESG determination at temperatures higher than ambient temperature, a temperature 5 K above that needed to give the necessary vapour pressure or 50 K above the Flash Point is used. This value of MESG is given in Table B.1 and the classification of the equipment group is based on this result.

#### 5.1.3 Flammable limits

Determinations have been made by a number of different methods, but the preferred method is with a low energy ignition at the bottom of a vertical tube. The values (in percentage by volume and mass per volume) are listed in Table B.1.

If the flash point is high, the compound does not form a flammable vapour air/mixture at normal condition of temperature (20 °C). Where flammability data are presented for such compounds the determinations have been made at a temperature sufficiently elevated to allow the vapour to form a flammable mixture with air.

#### 5.1.4 Flash point (FP)

The value given in Table B.1 is the "closed cup" measurement. When this data was not available, the "open cup" value is quoted and indicated by (oc). The symbol < (less than), indicates that the flash point is below the value (in degree Celsius) stated, this probably being the limit of the apparatus used.

### 5.1.5 Temperature class

The temperature class of a gas or vapour is given according to IEC 60079-14, as shown in Table 1:

**Table 1 – Classification of temperature class and range of auto-ignition temperatures**

Temperature class	Range of auto-ignition temperature (AIT) °C
T1	> 450
T2	300 < AIT ≤ 450
T3	200 < AIT ≤ 300
T4	135 < AIT ≤ 200
T5	100 < AIT ≤ 135
T6	85 < AIT ≤ 100

### 5.1.6 Minimum igniting current (MIC)

The apparatus for the determination of minimum igniting current is defined in IEC 60079-11. The test apparatus shall be operated in a 24 V d.c. circuit containing a  $(95 \pm 5)$  mH air-cored coil. The current in this circuit is varied to a minimum value until ignition of the most easily ignited concentration of the specific gas or vapour in air is obtained.

### 5.1.7 Auto-ignition temperature (AIT)

The value of auto-ignition temperature depends on the method of testing. The preferred method and data obtained is given in Clause 7 and in Annex A.

If the compound is not included in these data, the data obtained in similar apparatus, such as the apparatus described by ASTM E659, is listed.

NOTE Results from using the apparatus described in ASTM D2155 (now replaced by ASTM E659) were reported by C.J. Hilado and S.W. Clark. The apparatus is similar to the one used by Zabetakis. If there is no determination by either the IEC apparatus, nor similar apparatus, the lowest value obtained in other apparatus is listed. A more comprehensive list of data for auto-ignition temperature, with the reference to sources, is given by Hilado and Clark.

## 5.2 Properties of particular gases and vapours

### 5.2.1 Coke oven gas

Coke oven gas is a mixture of hydrogen, carbon monoxide and methane. If the sum of the concentrations (Vol. %) of hydrogen and carbon monoxide is less than 75 % by volume of the total, flameproof equipment of Equipment Group IIB is recommended; otherwise, equipment of Equipment Group IIC is recommended.

### 5.2.2 Ethyl nitrite

The auto-ignition temperature of ethyl nitrite is 95 °C, above which the gas suffers explosive decomposition.

NOTE Ethyl nitrite is not be confused with its isomer, nitroethane.

### 5.2.3 MESH of carbon monoxide

The MESH for carbon monoxide relates to a mixture with air saturated with moisture at normal ambient temperature. This determination indicates the use of Equipment Group IIB equipment