



SLOVENSKI STANDARD
oSIST prEN 16247-2:2020
01-marec-2020

Energetske presoje - 2. del: Stavbe

Energy audits - Part 2: Buildings

Energieaudits - Teil 2: Gebäude

Audits énergétiques - Partie 2: Bâtiments

Ta slovenski standard je istoveten z: prEN 16247-2

<https://standards.iteh.ai/catalog/standards/sist/1921f422-c6d3-487f-8bef-755daa23c495/osist-pren-16247-2-2020>

ICS:

03.100.70	Sistemi vodenja	Management systems
27.015	Energijska učinkovitost. Ohranjanje energije na splošno	Energy efficiency. Energy conservation in general
91.040.01	Stavbe na splošno	Buildings in general

oSIST prEN 16247-2:2020

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN 16247-2:2020](https://standards.iteh.ai/catalog/standards/sist/1921f422-e6d3-487f-8bef-755daa23c495/osist-pren-16247-2-2020)

<https://standards.iteh.ai/catalog/standards/sist/1921f422-e6d3-487f-8bef-755daa23c495/osist-pren-16247-2-2020>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 16247-2

January 2020

ICS 03.120.10; 27.015; 91.120.10

Will supersede EN 16247-2:2014

English version

Energy audits - Part 2: Buildings

Audits énergétiques - Partie 2: Bâtiments

Energieaudits - Teil 2: Gebäude

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/CLC/JTC 14.


If this draft becomes a European Standard, CEN and CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN and CENELEC in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN and CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN and CENELEC members are the national standards bodies and national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation. Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



CEN-CENELEC Management Centre:
Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	4
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and Definitions	6
4 Quality requirements	8
4.1 Energy auditor.....	8
4.1.1 Competency.....	8
4.1.2 Confidentiality.....	8
4.1.3 Objectivity.....	8
4.1.4 Transparency.....	8
4.2 Energy audit process.....	8
5 Elements of the energy audit process.....	8
5.1 Preliminary contact.....	8
5.2 Start-up meeting.....	9
5.3 Collecting data.....	10
5.3.1 General.....	10
5.3.2 Information request.....	10
5.3.3 Review of the available data.....	12
5.3.4 Preliminary data analysis.....	12
5.4 Field work.....	12
5.4.1 Aim of field work.....	12
5.4.2 Conduct.....	13
5.4.3 Site visits.....	13
5.5 Analysis.....	13
5.5.1 General.....	13
5.5.2 Energy breakdown.....	14
5.5.3 Energy performance indicators.....	14
5.5.4 Energy efficiency improvement opportunities.....	14
5.6 Report.....	15
5.6.1 General.....	15
5.6.2 Content of report.....	15
5.7 Final meeting.....	15
Annex A (informative) Examples of parties of an energy audit in buildings.....	16
Annex B (informative) Examples of checklists for energy audit field work in buildings.....	17
B.1 General.....	17
B.2 Checklist.....	17
B.3 Building visit checklist.....	18
B.4 The building envelope.....	19

B.5	Useful documents	20
Annex C (informative) Examples of the analysis of energy use in buildings		22
C.1	Overview of the energy use in a building	22
C.2	Analysis of the energy use in a building.....	23
C.3	Energy breakdown examples.....	23
Annex D (informative) Examples of analysis checklists for energy audits in buildings.....		26
D.1	General.....	26
D.2	Checklist	26
Annex E (informative) Examples of energy performance indicators in buildings		30
E.1	General.....	30
E.2	Global indicators	30
E.3	Detailed indicators	30
Annex F (informative) Examples of energy efficiency improvement opportunities in buildings.....		31
Annex G (informative) Examples of analysis and savings calculations in energy audits in buildings		33
G.1	Roof insulation	33
G.2	Ventilation system	36
Annex H (informative) Examples of the reporting of an energy audit in buildings		40
H.1	General.....	40
H.2	Table of contents	40
Annex I (informative) Example of energy improvement verification method in buildings.....		42
I.1	General.....	42
I.2	Energy signature	42
Bibliography.....		44

prEN 16247-2:2020 (E)**European foreword**

This document (prEN 16247-2:2020) has been prepared by Technical Committee CEN/CLC/JWG 14 “Energy audits”, the secretariat of which is held by BSI.

This document is currently submitted to the CEN Enquiry.

This document will supersede EN 16247-2:2014.

This Part provides additional material to Part 1 for the Buildings sector and should be used in conjunction with Part 1.

This document is part of the series EN 16247 “Energy audits” which comprises the following:

- Part 1 General requirements;
- Part 2 Buildings;
- Part 3 Processes;
- Part 4 Transport;
- Part 5 Competence of energy auditors.

ITeH STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN 16247-2:2020](https://standards.iteh.ai/catalog/standards/sist/1921f422-e6d3-487f-8bef-755daa23c495/osist-pren-16247-2-2020)

<https://standards.iteh.ai/catalog/standards/sist/1921f422-e6d3-487f-8bef-755daa23c495/osist-pren-16247-2-2020>

Introduction

An energy audit can help an organization to identify opportunities to improve energy efficiency. It can be part of a site wide energy management system.

The use and operation of buildings requires the provision of services such as heating, cooling, ventilation, lighting, domestic hot water, transportation systems (e.g. elevators, escalators and moving walkways) in buildings, information systems and processes. In addition, energy is used by appliances within the building.

The energy consumption depends on:

- local climatic conditions;
- the characteristics of the building envelope;
- the designed indoor environment conditions;
- the characteristics and settings of the technical building systems;
- activities and processes in the building;
- occupant behaviour and operational regime.

Dealing with buildings, the audited objects are sometimes similar, technically simple and numerous (as in the residential sector) but can also be unique, complex and highly technical (such as hospitals, swimming pools and spas, etc.).

Energy audits in buildings may include the whole building or parts of the building or some technical system.

Energy performance indicators (benchmark values, if available) or average statistical specific energy consumption data are usually published nationally for different building types and ages. This information can be used in the analysis to provide comparative energy performance evaluation.

NOTE The energy audits covered under this standard might be independent from building energy performance certification and other legislative requirements.

1 Scope

This document is applicable to specific energy audit requirements in buildings. It specifies the requirements, methodology and deliverables of an energy audit in a building or group of buildings. It is applied in conjunction with, and is supplementary to, EN 16247-1, *Energy audits — Part 1: General requirements*. It provides additional requirements to EN 16247-1 and is applied simultaneously.

If processes are included in the scope of the energy audit, the energy auditor can choose to apply EN 16247-3, *Energy audits — Part 3: Processes*. If on-site transport on a site is included in the scope of the energy audit, the energy auditor can choose to apply EN 16247-4, *Energy audits — Part 4: Transport*.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 16247-1:2012, *Energy audits - Part 1: General requirements*

EN ISO 52000-1, *Energy performance of buildings - Overarching EPB assessment - Part 1: General framework and procedures (ISO 52000-1:2017)*

(standards.iteh.ai)

3 Terms and Definitions

oSIST prEN 16247-2:2020

<https://standards.iteh.ai/catalog/standards/sist/1921422-e6d3-487f-8bef-753dad25c495/osist-pr-en-16247-2-2020>

For the purposes of this European Standard, the terms and definitions given in EN 16247-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 building

construction as a whole, including its envelope and all technical building systems, for which energy may be used to condition the indoor climate, to provide domestic hot water and illumination and other services related to the use of the building and the activities performed within the building

Note 1 to entry: The term can refer to the building as a whole or to parts thereof that have been designed or altered to be used separately.

Note 2 to entry: The building could include its site location and related external environment.

Note 3 to entry: Processes within the building, for example chilling of food in supermarkets, are addressed in EN 16247-3.

3.2**system boundary**

boundary that includes within it all areas associated with the audited object (both inside and outside the audited object) where energy is consumed or produced

Note 1 to entry: Inside the system boundary the system losses are taken into account explicitly, outside the system boundary they are taken into account in a conversion factor.

3.3**energy need**

energy to be delivered to or extracted from a building in a defined time period by a technical system to provide a building service

3.4**energy carrier**

substance or physical phenomenon that can be used directly or indirectly to be transformed into useful energy

Note 1 to entry: The default energy content of fuels is gross calorific value.

3.5**delivered energy (final energy)**

energy, expressed per energy carrier, supplied to the technical building systems through the system boundary, to satisfy the uses taken into account or to produce electricity

Note 1 to entry: Delivered energy can be calculated for defined energy uses or it can be measured.

Note 2 to entry: Energy uses include heating, cooling, ventilation, domestic hot water, lighting, appliances, etc.

<https://standards.iteh.ai/catalog/standards/sist/1921f422-e6d3-487f-8bef-755daa23c495/osist-pren-16247-2-2020>

3.6**produced energy**

heat or electricity generated within the system boundary

Note 1 to entry: Produced energy can be used within the system boundary or exported.

3.7**exported energy**

energy, expressed for each energy carrier, delivered by the technical building systems through the system boundary and used outside the system boundary

Note 1 to entry: It can be specified by generation types (e.g. CHP, photovoltaic, etc) in order to apply different weighting factors.

Note 2 to entry: Exported energy can be calculated or it can be measured.

3.8**building services**

the services provided by the technical building systems and by appliances to condition the indoor environment (thermal comfort, air quality, visual and acoustic quality) and other services related to the use of the building

prEN 16247-2:2020 (E)**3.9****technical building system**

technical equipment for heating, cooling, ventilation, domestic hot water, lighting, information systems and on-site energy production

Note 1 to entry: A technical building system can refer to one or a combination of building services (e.g. heating system include heating, domestic hot water system and controls).

Note 2 to entry: A technical building system is composed of different subsystems and includes controls.

Note 3 to entry: On-site energy production can include heat or electricity.

4 Quality requirements**4.1 Energy auditor****4.1.1 Competency**

The energy auditor shall demonstrate that they have qualifications or experience covering the scope, complexity and thoroughness of the audit.

NOTE See EN 16247-5

4.1.2 Confidentiality

The energy auditor shall respect all the legal and commercial confidentiality requirements agreed with the organization, which cover all parties involved, such as tenants, maintenance organizations, building occupants.

4.1.3 Objectivity

Objectivity is defined in EN 16247-1:2012, 4.1.3

4.1.4 Transparency

Transparency is defined in EN 16247-1:2012, 4.1.4

4.2 Energy audit process

When a sampling method is used, any selected sample of spaces, systems or equipment shall be representative of the whole building or of a group of buildings.

NOTE See Informative Annex A: A flow diagram of the energy audit process.

5 Elements of the energy audit process**5.1 Preliminary contact**

The energy auditor shall identify all parties/organizations and their roles in ownership, management, use, operation and maintenance of the building and their respective impacts and interests on energy use and consumption.

NOTE 1 See Informative Annex B: Examples of parties of an energy audit in buildings.

The scope of the audit should be agreed to cover technical interaction of the systems within the building, and the interaction of the systems with the building. Optimization of some specific energy use to the exclusion of others may give misleading results.

The agreed aims of the energy audit may contain:

- a) reducing energy consumption and costs;
- b) reducing environmental impact;
- c) Checking or ensuring indoor environment for quality of health and well-being (comfort, indoor air quality, and illuminance levels);
- d) complying with legislation or with voluntary obligations.

The energy audit scope and boundaries shall define what is included, in terms of:

- a) which buildings from a list of buildings or parts of a building;
- b) which energy services;
- c) which technical building systems;
- d) which areas and systems outside the building;
- e) which energy performance indicators could be used as appropriate to the audit.

The energy audit level of thoroughness, as defined in EN 16247-1, Annex A shall be agreed, taking into account that it will impact:

- a) time on site; [oSIST prEN 16247-2:2020
https://standards.iteh.ai/catalog/standards/sist/1921f422-e6d3-487f-8bef-755daa23c495/osist-pren-16247-2-2020](https://standards.iteh.ai/catalog/standards/sist/1921f422-e6d3-487f-8bef-755daa23c495/osist-pren-16247-2-2020)
- b) choice of samples;
- c) level of modelling;
- d) requirements for measurements;
- e) level of metering, including sub-metering;
- f) level of defining the energy efficiency improvement opportunities;
- g) required auditor's skills.

NOTE 2 See Part 1 Informative Annex A: Proposal of Energy Audit Level of Thoroughness

5.2 Start-up meeting

During the start-up meeting the energy auditor shall agree with the organization on:

- a) timing of site visits, e.g. whether within or outside normal working hours;
- b) level of occupant engagement;
- c) areas of restricted access;
- d) potential health hazards and risks.

prEN 16247-2:2020 (E)

The energy auditor shall, where available, obtain from the organization:

- a) set-points and operational limits of indoor environmental conditions (such as temperatures, air flows, air quality, illuminance, noise) and any seasonal variations;
- b) occupancy patterns for the different range of activities within the building;
- c) comments from any occupant or other party on operational performance of the building and the level of the building service;
- d) energy certificates prepared for the building;
- e) whether any building occupant awareness or motivation programmes have been implemented.

5.3 Collecting data**5.3.1 General**

The data collection shall be appropriate to the scope and level of thoroughness of the energy audit.

5.3.2 Information request

The energy auditor shall collect with the organization the following data as required by the scope and level of thoroughness of the energy audit:

- a) energy carriers, present and available;
- b) energy related data: <https://standards.iteh.ai/catalog/standards/sist/1921f422-e6d3-487f-8bef-755daa23c495/osist-pr-en-16247-2-2020>
 - 1) delivered, produced and exported energy, for each energy carrier (for example identify the energy streams for a CHP unit, or for photovoltaic systems where production is used locally or exported);
 - 2) energy consumption data (or readings with related time and date) of any available meters, counters or monitoring systems (e.g. heat meter, domestic hot water meter, fuel meter, burner hour counter);
 - 3) data from individual metering, if available;
 - 4) short-interval (e.g. hourly) energy demand / load curve, if available;
 - 5) relevant related measurements;

The frequency of the data should be appropriate to the scope and thoroughness of the energy audit. Building energy audits may deal with hourly, daily, weekly or monthly consumption data as available and appropriate.

NOTE Where only annual data are available, monthly profiles may be estimated, depending on the level of thoroughness of the audit.

The energy related data should be recorded by the building and control system if available.

- c) relevant variable and static factors affecting energy consumption:
- 1) climatic data (e.g. temperature, degree-days, hygrometry, lighting) from the local building automation and control system (BACS), if available;
 - 2) occupancy patterns;
 - 3) internal set points;
- Information for quantifying the relevant variable and static factors affecting energy consumption should be recorded by the building control system if available (e.g. occupancy times, degree-hours etc).
- d) information on important changes in the past 3 years or the period covered by the available operational data, concerning:
- 1) the physical form of the building;
 - 2) the spaces – either in dimension and/or in use;
 - 3) the building envelope (renovation of windows, added insulation, etc.);
 - 4) the technical building systems and the areas they serve;
 - 5) the tenant arrangements;
 - 6) occupancy of spaces (different occupancy times, extended hours behaviour and internal loads);
 - 7) set points and occupant behaviour;
- e) values to be used, adapted to the local/national performance indicators (if relevant):
- 1) floor area;
 - 2) building volume;
 - 3) others;
- f) existing design, operation and maintenance documents and information, such as:
- 1) as-built building plans;
 - 2) any external factors that may influence the energy performance of the building (e.g. shading by adjacent trees or buildings);
 - 3) indications of supplied building services (i.e. which rooms or zones are heated, cooled, ventilated) on the building lay-out plan;
 - 4) technical building system schematics, indicating the system zones, if any;
 - 5) control diagrams and settings;
 - 6) appliance and component data and ratings;

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN 16247-2:2020](https://standards.iteh.ai/catalog/standards/sist/1921f422-e6d3-487f-8bef-755dad23c495/osist-pr-en-16247-2-2020)

<https://standards.iteh.ai/catalog/standards/sist/1921f422-e6d3-487f-8bef-755dad23c495/osist-pr-en-16247-2-2020>