



Designation: ~~C444-95~~ Designation: **C 444 – 03 (Reapproved 2009)**

Standard Specification for Perforated Concrete Pipe¹

This standard is issued under the fixed designation C 444; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

1. Scope

1.1 This specification covers perforated concrete pipe intended to be used for underdrainage.

~~1.2A complete metric companion to Specification C444 has been developed—C444M; therefore, no metric equivalents are presented in this specification.~~

1.2 This specification is the inch-pound companion to Specification C 444M; therefore, no SI equivalents are presented in the specification.

1.3 This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

2. Referenced Documents

2.1 *ASTM Standards*:²

C 822 [Terminology Relating to Concrete Pipe and Related Products](#)

3. Terminology

3.1 *Definitions*—For definitions of terms relating to concrete pipe, see Terminology C 822.

4. Classification

4.1 Pipe manufactured according to this specification shall be of two classes known as Type 1 and Type 2, which cover two arrangements of perforations ~~that may~~ be used with pipe manufactured according to any of the standard specifications for plain or reinforced concrete pipe, and any of the classifications within those standard specifications.

4.1.1 Type 1 perforated pipe shall have circular perforations conforming to 6.1 and Table 1.

4.1.2 Type 2 perforated pipe shall have slotted perforations conforming to 6.2 and Table 2.

4.1.3 It is intended that perforated pipe shall be specified by reference to this specification and the specification for the type and class of pipe desired.

NOTE 1—*Example* “Perforated concrete pipe shall conform to the requirements of Specification C 444 Type 2, and all applicable requirements of Specification C 14, Class 2.”

5. Basis of Acceptance

5.1 The acceptability of the pipe shall be determined by the results of all applicable tests (Note 2) prescribed for the type and class of pipe specified, and by inspection to determine whether the pipe conforms to this specification as to design and freedom from defects.

NOTE 2—It is intended that all tests will be applicable except those having to do with permeability and the hydrostatic test.

6. Perforations

6.1 *Type 1*—Perforations shall be circular, not more than $\frac{5}{16}$ in. or less than $\frac{3}{16}$ in. in diameter, and arranged in rows parallel to the axis of the pipe. Perforations shall be 3 in. center-to-center, along rows. The spigot or tongue end shall not be perforated

¹ This specification is under the jurisdiction of ASTM Committee ~~E-13~~ C13 on Concrete Pipe and is the direct responsibility of Subcommittee ~~C13.01 on Nonreinforced Concrete Sewer, Drain, and Irrigation Pipe.~~ C13.01 on Nonreinforced Concrete Sewer, Drain, and Irrigation Pipe.

Current edition approved June 15, 1995. Published August 1995. Originally published as C444-59. Last previous edition C444-94, on Non-Reinforced Concrete Sewer, Drain and Irrigation Pipe.

Current edition approved June 1, 2009. Published July 2009. Originally approved in 1959. Last previous edition approved in 2003 as C 444 – 03.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* Vol 04.05 volume information, refer to the standard’s Document Summary page on the ASTM website.