



SLOVENSKI STANDARD
SIST EN IEC 61084-1:2024

01-november-2024

**Sistemi kabelskih korit in sistemi kabelskih cevi za električne inštalacije - 1. del:
Splošne zahteve (IEC 61084-1:2017)**

Cable trunking systems and cable ducting systems for electrical installations - Part 1:
General requirements (IEC 61084-1:2017)

Elektroinstallationskanalsysteme für elektrische Installationen - Teil 1: Allgemeine
Anforderungen (IEC 61084-1:2017)

Systèmes de goulottes et systèmes de conduits profilés pour installations électriques -
Partie 1 : Exigences générales (IEC 61084-1:2017)

Ta slovenski standard je istoveten z: EN IEC 61084-1:2024

[SIST EN IEC 61084-1:2024](https://standards.sist.si/catalog/standards/sist/714d047c-1037-4897-bc00-00011511e000/sist-en-iec-61084-1-2024)

<https://standards.sist.si/catalog/standards/sist/714d047c-1037-4897-bc00-00011511e000/sist-en-iec-61084-1-2024>

ICS:

29.120.10	Inštalacijske cevi za električne namene	Conduits for electrical purposes
-----------	--	-------------------------------------

SIST EN IEC 61084-1:2024

en

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN IEC 61084-1

September 2024

ICS 29.060.01; 29.120.01

Supersedes EN 50085-1:2005; EN 50085-1:2005/A1:2013

English Version

**Cable trunking systems and cable ducting systems for electrical installations - Part 1: General requirements
(IEC 61084-1:2017)**

Systèmes de goulottes et systèmes de conduits profilés
pour installations électriques - Partie 1 : Exigences
générales
(IEC 61084-1:2017)

Installationskanalsysteme für elektrische Installationen -
Teil 1: Allgemeine Anforderungen
(IEC 61084-1:2017)

This European Standard was approved by CENELEC on 2024-08-05. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

[SIST EN IEC 61084-1:2024](https://standards.iteh.ai/catalog/standards/sist/74ad0a9c-1657-4897-bc80-689a1344e0e6/sist-en-iec-61084-1-2024)

<https://standards.iteh.ai/catalog/standards/sist/74ad0a9c-1657-4897-bc80-689a1344e0e6/sist-en-iec-61084-1-2024>



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 61084-1:2024 (E)

European foreword

This document (EN IEC 61084-1:2024) consists of the text of document IEC 61084-1:2017, prepared by SC 23A "Cable management systems" of IEC/TC 23 "Electrical accessories".

The following dates are fixed:

- latest date by which this document has to be (dop) 2025-08-05 implemented at national level by publication of an identical national standard or by endorsement
- latest date by which the national standards (dow) 2029-08-05 conflicting with this document have to be withdrawn

This document supersedes EN 50085-1:2005 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN-CENELEC shall not be held responsible for identifying any or all such patent rights.

Any feedback and questions on this document should be directed to the users' national standards body/national committee. A complete listing of these bodies can be found on the CEN and CENELEC websites.

iTeh Standards

Endorsement notice

(<https://standards.iteh.ai>)

Document Preview

The text of the International Standard IEC 61084-1:2017 was approved by CENELEC as a European Standard without any modification.

[SIST EN IEC 61084-1:2024](https://standards.iteh.ai/catalog/standards/sist/74ad0a9c-1657-4897-bc80-689a1344e0e6/sist-en-iec-61084-1-2024)

<https://standards.iteh.ai/catalog/standards/sist/74ad0a9c-1657-4897-bc80-689a1344e0e6/sist-en-iec-61084-1-2024>



IEC 61084-1

Edition 2.0 2017-03

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Cable trunking systems and cable ducting systems for electrical installations –
Part 1: General requirements**

**Systèmes de goulottes et systèmes de conduits-profilés pour installations
électriques –
Partie 1: Exigences générales**

[SIST EN IEC 61084-1:2024](https://standards.iteh.ai/)

<https://standards.iteh.ai/catalog/standards/sist/74ad0a9c-1657-4897-bc80-689a1344e0e6/sist-en-iec-61084-1-2024>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.060.01; 29.120.10

ISBN 978-2-8322-4113-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 General requirements	12
5 General conditions for tests	12
6 Classification	13
6.1 According to material	13
6.2 According to resistance to impact for installation and application	13
6.2.1 CTS/CDS for impact 0,5 J.....	13
6.2.2 CTS/CDS for impact 0,7 J.....	13
6.2.3 CTS/CDS for impact 1 J.....	13
6.2.4 CTS/CDS for impact 2 J.....	13
6.2.5 CTS/CDS for impact 5 J.....	13
6.2.6 CTS/CDS for impact 10 J.....	13
6.2.7 CTS/CDS for impact 20 J.....	13
6.3 According to temperatures as given in Table 1, Table 2 and Table 3 below.....	13
6.4 According to resistance to flame propagation.....	14
6.4.1 Flame propagating CTS/CDS.....	14
6.4.2 Non-flame propagating CTS/CDS	14
6.5 According to electrical continuity characteristic	14
6.5.1 CTS/CDS with electrical continuity characteristic	14
6.5.2 CTS/CDS without electrical continuity characteristic	14
6.6 According to electrical insulating characteristic	14
6.6.1 CTS/CDS without electrical insulating characteristic	14
6.6.2 CTS/CDS with electrical insulating characteristic	14
6.7 According to degrees of protection provided by enclosure according to IEC 60529:1989	14
6.7.1 According to protection against ingress of solid foreign objects	14
6.7.2 According to protection against ingress of water	14
6.7.3 According to protection against access to hazardous parts	14
6.8 According to protection against corrosive or polluting substances	14
6.9 According to the system access cover retention	14
6.9.1 CTS/CDS access cover, which can be opened without a tool	14
6.9.2 CTS/CDS access cover, which can only be opened with a tool	14
7 Marking and documentation.....	14
8 Dimensions.....	17
9 Construction	17
9.1 Sharp edges	17
9.2 Apparatus mounting.....	17
9.3 Means for protective separation and/or retention	17
9.4 Mechanical connections	18
9.5 Accessible conductive parts.....	19
9.6 Equipotential bonding	20
9.7 Access to live parts.....	20
9.8 Inlet openings	21

9.9	Membranes	21
9.10	Cable restrainer	21
9.11	Cable anchorage.....	22
10	Mechanical properties.....	23
10.1	Mechanical strength.....	23
10.2	Cable support test.....	23
10.3	Impact test.....	23
10.3.1	Impact test for storage and transport	23
10.3.2	Impact test for installation and application	24
10.4	Linear deflection test.....	24
10.5	External load test.....	24
10.5.1	Fixing test for apparatus mounting of socket outlets	24
10.5.2	Fixing test for apparatus mounting other than socket outlets.....	25
10.6	System access cover retention.....	25
11	Electrical properties.....	26
11.1	Electrical continuity.....	26
11.1.1	General	26
11.1.2	Preparation and conditioning	26
11.1.3	Electrical impedance tests	26
11.2	Electrical insulation.....	28
11.2.1	Solid insulation	28
11.2.2	Conditioning and preparation.....	28
11.2.3	Insulation resistance test	29
11.2.4	Dielectric strength test.....	29
12	Thermal properties	29
12.1	Resistance to heat	29
12.1.1	General	29
12.1.2	Test for non-metallic or composite system components necessary to retain current-carrying parts in position.....	29
12.1.3	Test for non-metallic or composite system components not necessary to retain current-carrying parts in position.....	30
13	Fire hazard	30
13.1	Reaction to fire	30
13.1.1	Initiation of fire	30
13.1.2	Contribution to fire	31
13.1.3	Spread of fire.....	31
13.1.4	Additional reaction to fire characteristics	32
13.2	Resistance to fire.....	32
14	External influences	32
14.1	Degree of protection provided by enclosure	32
14.1.1	General	32
14.1.2	Protection against ingress of solid foreign objects	32
14.1.3	Protection against ingress of water	33
14.1.4	Protection against access to hazardous parts	33
14.2	Protection against corrosive or polluting substances	33
15	Electromagnetic compatibility	33
Annex A (informative) Types of cable trunking systems (CTS) and cable ducting systems (CDS).....		42
Annex B (normative) CTS/CDS IK code		44

Bibliography.....	45
Figure 1 – Types and application of trunking systems (CTS) and ducting systems (CDS)	34
Figure 2 – Example of impact test apparatus	35
Figure 3 – Arrangement for test for resistance to flame propagation	36
Figure 4 – Enclosure for test for resistance to flame propagation	37
Figure 5 – Ball pressure test apparatus.....	37
Figure 6 – Electrical impedance tests arrangement.....	39
Figure 7 – Examples of membranes and grommets	39
Figure 8 – Typical apparatus for testing the resistance of cable anchorage to pull force	40
Figure 9 – Typical apparatus for testing the resistance of cable anchorage to twist force	41
Figure 10 – Piston for durability of marking test	41
Table 1 – Minimum storage and transport temperature	13
Table 2 – Minimum installation and application temperature	13
Table 3 – Maximum application temperature	13
Table 4 – Torque values for the test of screwed connections	19
Table 5 – Forces and torques to be applied to cable anchorage	23
Table 6 – Impact test values	24
Table A.1 – Types of CTS and CDS for wall and ceiling installation	42
Table A.2 – Types of CTS and CDS for floor installation	42
Table A.3 – Types of CTS and CDS for installation between two opposite surfaces	43

SIST EN IEC 61084-1:2024

<https://standards.iteh.ai/catalog/standards/sist/74ad0a9c-1657-4897-bc80-689a1344e0e6/sist-en-iec-61084-1-2024>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**CABLE TRUNKING SYSTEMS AND CABLE DUCTING
SYSTEMS FOR ELECTRICAL INSTALLATIONS –****Part 1: General requirements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61084-1 has been prepared by subcommittee 23A: Cable management systems, of IEC technical committee 23: Electrical accessories.

This second edition cancels and replaces the first edition published in 1991 and Amendment 1:1993. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- classification;
- construction;
- mechanical and electrical properties.

This part of the IEC 61084 series is not intended to be used by itself.

The text of this standard is based on the following documents:

FDIS	Report on voting
23A/826/FDIS	23A/833/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61084 series, published under the general title *Cable trunking and cable ducting systems for electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[SIST EN IEC 61084-1:2024](https://standards.iteh.ai/catalog/standards/sist/74ad0a9c-1657-4897-bc80-689a1344e0e6/sist-en-iec-61084-1-2024)

<https://standards.iteh.ai/catalog/standards/sist/74ad0a9c-1657-4897-bc80-689a1344e0e6/sist-en-iec-61084-1-2024>

CABLE TRUNKING SYSTEMS AND CABLE DUCTING SYSTEMS FOR ELECTRICAL INSTALLATIONS –

Part 1: General requirements

1 Scope

This part of the IEC 61084 series specifies requirements and tests for cable trunking systems (CTS) and cable ducting systems (CDS) intended for the accommodation, and where necessary for the electrically protective separation, of insulated conductors, cables and possibly other electrical equipment in electrical and/or communication systems installations. The maximum voltage of these installations is 1 000 V AC and 1 500 V DC.

This document does not apply to conduit systems, cable tray systems, cable ladder systems, power track systems or equipment covered by other standards.

NOTE This part of the IEC 61084 series is not intended to be used by itself.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60417, *Graphical symbols for use on equipment*

IEC 60423:2007, *Conduit systems for cable management – Outside diameters of conduits for electrical installations and threads for conduits and fittings*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013

IEC 60695-2-11:2014, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

IEC 60695-11-2:2013, *Fire hazard testing – Part 11-2: Test flames – 1 kW pre-mixed flame – Apparatus, confirmatory test arrangement and guidance*

IEC 61032:1997, *Protection of persons and equipment by enclosures – Probes for verification*

ISO 2768-1:1989, *General tolerances – Part 1: Tolerances for linear and angular dimensions without individual tolerance indications*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

cable trunking system

CTS

assembly comprising a trunking length and possibly other system components to provide an enclosure for the accommodation and laying in of insulated conductors and cables and possibly the accommodation of other electrical equipment

Note 1 to entry: Different types of CTS are shown in Figure 1 and explained in Annex A.

3.2

cable ducting system

CDS

assembly comprising a ducting length and possibly other system components to provide an enclosure for the accommodation and drawing in of insulated conductors and cables and possibly the accommodation of other electrical equipment

Note 1 to entry: Different types of CDS are shown in Figure 1 and explained in Annex A.

3.3

system component

part of the system which includes:

- a) trunking length or ducting length;
- b) trunking fitting or ducting fitting;
- c) fixing device;
- d) apparatus mounting device;
- e) system accessory

Note 1 to entry: A system does not necessarily include all system components a) to e). Different combinations of system components can be used.

3.4

trunking length

main component of a cable trunking system comprising a base with one or more access covers which may be opened or removed

3.5

ducting length

main component of a cable ducting system, characterized by a closed non-circular cross section

3.6

fitting

system component to connect, change direction or terminate trunking lengths or ducting lengths

3.7

fixing device

system component to secure other system components to the wall, ceiling, floor or other structure

3.8

apparatus mounting device

system component to accommodate electrical apparatus (switches, socket outlets, circuit-breakers, telephone outlets, etc...) which can be an integral part of electrical apparatus