



Designation: F90-07 Designation: F 90 - 09

Standard Specification for Wrought Cobalt-20Chromium-15Tungsten-10Nickel Alloy for Surgical Implant Applications (UNS R30605)¹

This standard is issued under the fixed designation F 90; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reappraisal.

1. Scope*

1.1 This specification covers the requirements for wrought cobalt-20chromium-15tungsten-10nickel alloy used for surgical implants. The properties specified apply specifically to wrought bar, rod, wire, sheet, and strip, but do not apply to surgical fixation wire (see Specification F 1091).

~~1.2 The values stated in inch-pound units are to be regarded as the standard. The SI equivalents in parentheses are for information only.~~

1.2 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

2. Referenced Documents

2.1 ASTM Standards:²

A 751 Test Methods, Practices, and Terminology for Chemical Analysis of Steel Products

E 8 Test Methods for Tension Testing of Metallic Materials

E 29 Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications

E 45 Test Methods for Determining the Inclusion Content of Steel

E 354 Test Methods for Chemical Analysis of High-Temperature, Electrical, Magnetic, and Other Similar Iron, Nickel, and Cobalt Alloys

F 981 Practice for Assessment of Compatibility of Biomaterials for Surgical Implants with Respect to Effect of Materials on Muscle and Bone

F 1091 Specification for Wrought Cobalt-20Chromium-15Tungsten-10Nickel Alloy Surgical Fixation Wire (UNS R30605) F2527

F 2527 Specification for Wrought Seamless and Welded and Drawn Cobalt Alloy Small Diameter Tubing for Surgical Implants (UNS R30003, UNS R30008, UNS R30035, UNS R30605, and UNS R31537)

2.2 Aerospace Material Specification:³

AMS 2269 Chemical Check Analysis Limits, Wrought Nickel Alloys and Cobalt Alloys

AMS 5759 Cobalt Alloy, Corrosion and Heat Resistant Bars, Forgings, and Rings, 52Co - 20 Cr - 10Ni - 15W, Solution Heat Treated

2.3 ISO Standards:⁴

ISO 5832-5 Wrought Cobalt-Chromium-Tungsten-Nickel Alloy

ISO 6892 Metallic Materials Tensile Testing at Ambient Temperature

ISO 9001 Quality System—Requirements

2.4 American Society for Quality (ASQ) Standard:

C1 Specification of General Requirements for a Quality Program⁵

3. Classification

3.1 *Bar*—Round, rectangular, or other complex shaped product delivered straightened and cut to defined lengths, with a

¹ This specification is under the jurisdiction of ASTM Committee F04 on Medical and Surgical Materials and Devices and is the direct responsibility of Subcommittee F04.12 on Metallurgical Materials.

~~Current edition approved May 15, 2007. Published June 2007. Originally approved in 1968. Last previous edition approved in 2001 as F90-01.~~

Current edition approved June 1, 2009. Published July 2009. Originally approved in 1968. Last previous edition approved in 2007 as F 90 - 07.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from Society of Automotive Engineers (SAE), 400 Commonwealth Dr., Warrendale, PA 15096-0001, <http://www.sae.org>.

⁴ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

⁵ Available from American Society for Quality (ASQ), 600 N. Plankinton Ave., Milwaukee, WI 53203, <http://www.asq.org>.

*A Summary of Changes section appears at the end of this standard.

maximum cross-sectional area of 16 in.² (103 cm²).

3.2 *Wire*—Round, rectangular, or other complex shaped product produced and delivered in coils.

3.3 *Fine Wire*—Wire with diameter or major dimension less than 0.063 in. (1.6 mm).

4. Ordering Information

4.1 Inquiries and orders for material under this specification shall include the following information:

4.1.1 Quantity,

4.1.2 ASTM designation and date of issue,

4.1.3 Mechanical properties (see Section 7),

4.1.4 Form (bar, rod, wire, sheet, strip),

4.1.5 Applicable dimensions including size, thickness, width, and length (exact, random, or multiples) or drawing number,

4.1.6 Condition (see 5.1),

4.1.7 Finish (see 5.2),

4.1.8 Other requirements.

5. Materials and Manufacture

5.1 *Condition*—Bar, wire, sheet, and strip shall be furnished to the purchaser, as specified, in the annealed or cold-worked condition.

5.2 *Finish*:

5.2.1 Bar and wire shall be furnished bright annealed, cold drawn, pickled, ground, or ground and polished, as specified by the purchaser.

5.2.2 Sheet shall be furnished bright annealed, pickled, cold-rolled, or polished, as specified by the purchaser.

6. Chemical Requirements

6.1 The heat analysis shall conform to the chemical composition of Table 1. The supplier shall not ship material that is outside the limits specified in Table 1.

6.1.1 Requirements for the major and minor elemental constituents are listed in Table 1. Also listed are important residual elements. Analysis for elements not listed in Table 1 is not required to verify compliance with this specification.

6.2 *Product Analysis*— The product analysis is either for the purpose of verifying the composition of a heat or lot or to determine variations in the composition within the heat.

6.2.1 Acceptance or rejection of a heat or lot of material may be made by the purchaser on the basis of this product analysis.

6.2.2 Product analysis tolerances do not broaden the specified heat analysis requirements but instead cover variations between laboratories in the measurement of chemical content. Product analysis limits shall be as specified in Table 2.

6.3 For referee purposes, Test Methods E 354 shall be used.

6.4 Methods and practices relating to chemical analysis required by this specification shall be in accordance with Test Methods A 751.

7. Mechanical Requirements

7.1 The material in the annealed condition shall conform to the mechanical properties specified in Tables 3 and 4.

7.2 Material in the cold worked condition shall conform to the mechanical properties specified in Table 3.

7.3 Tensile properties shall be determined in accordance with Test Methods E 8. Perform at least one tension test from each lot. Should any test piece not meet the specified requirements, test two additional test pieces representative of the same lot, in the same manner, for each failed test piece. The lot shall be considered in compliance only if all additional test pieces meet the specified requirements.

TABLE 1 Chemical Requirements

Element	Composition, % (mass/mass)	
	min	max
Carbon	0.05	0.15
Manganese	1.00	2.00
Silicon	...	0.40
Phosphorus	...	0.040
Sulfur	...	0.030
Chromium	19.00	21.00
Nickel	9.00	11.00
Tungsten	14.00	16.00
Iron	...	3.00
Cobalt ⁴	balance	balance

⁴ Approximately equal to the difference between 100 % and the sum percentage of the other specified elements. The percentage of the cobalt difference is not required to be reported.