



SLOVENSKI STANDARD
SIST EN 14366:2005+A1:2019

01-december-2019

Laboratorijsko merjenje hrupa pri napeljavah za odpadno vodo

Laboratory measurement of noise from waste water installations

Messung der Geräusche von Abwasserinstallationen im Prüfstand

Mesurage en laboratoire du bruit émis par les installations d'évacuation des eaux usées

Ta slovenski standard je istoveten z: EN 14366:2004+A1:2019

[SIST EN 14366:2005+A1:2019](https://standards.iteh.ai/catalog/standards/sist/01e127a8-b139-451b-95b0-46f04f739d7e/sist-en-14366-2005a1-2019)

<https://standards.iteh.ai/catalog/standards/sist/01e127a8-b139-451b-95b0-46f04f739d7e/sist-en-14366-2005a1-2019>

ICS:

17.140.20	Emisija hrupa naprav in opreme	Noise emitted by machines and equipment
91.140.80	Drenažni sistemi	Drainage systems

SIST EN 14366:2005+A1:2019

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 14366:2005+A1:2019

<https://standards.iteh.ai/catalog/standards/sist/01e127a8-b139-451b-95b0-46f04f739d7e/sist-en-14366-2005a1-2019>

EUROPEAN STANDARD

EN 14366:2004+A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2019

ICS 17.140.20; 91.140.80

Supersedes EN 14366:2004

English Version

Laboratory measurement of noise from waste water installations

Mesurage en laboratoire du bruit émis par les installations d'évacuation des eaux usées

Messung der Geräusche von Abwasserinstallationen im Prüfstand

This European Standard was approved by CEN on 23 September 2004 and includes Amendment 1 approved by CEN on 28 July 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	3
Introduction	4
1 Scope.....	5
2 Normative references.....	5
3 Terms and definitions	5
4 Notations.....	7
5 Principle of the test method.....	8
5.1 Structure-borne sound measurements (index s).....	8
5.2 Airborne sound measurement (index a).....	8
6 Equipment	8
6.1 Requirements for the frequency range of measurement.....	8
6.2 Requirements for the acoustic equipment	8
6.3 Requirements for the hydraulic equipment.....	8
6.4 Requirements for the wall structural sensitivity measuring equipment.....	8
7 Test facilities.....	9
7.1 Construction requirements.....	9
7.2 Acoustic requirements.....	9
8 Test specimen.....	9
8.1 Geometry.....	9
8.2 Mounting of the specimen.....	11
9 Test procedure and evaluation.....	12
9.1 Wall structural sensitivity measurement.....	12
9.2 Flow rate.....	13
9.3 Measurements.....	13
9.4 Correction for background noise	13
9.5 Normalisation.....	14
9.6 Calculation of structure-borne sound level L_{sn} and normalisation with respect to the acoustic properties of the wall.....	14
9.7 Calculation of the airborne level L_{an}	15
10 Calculation of single number quantities.....	15
10.1 Single number descriptor for structure-borne sound.....	15
10.2 Single number descriptor for airborne sound.....	15
11 Precision.....	15
11.1 Repeatability.....	15
11.2 Reproducibility.....	15
12 Expression of results.....	15
13 Test report.....	16
Annex A (normative) Wall structural sensitivity measurement.....	17
Annex B (informative) Background ; application of reciprocity for calibrating the test wall.....	18
Bibliography.....	20

European foreword

This document (EN 14366:2004+A1:2019) has been prepared by Technical Committee CEN/TC 126 “Acoustic properties of building elements and of buildings”, the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2020 and conflicting national standards shall be withdrawn at the latest by April 2020.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1 approved by CEN on 28 July 2019.

This document supersedes EN 14366:2004.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

<https://standards.iteh.ai/catalog/standards/sist/01e127a8-b139-451b-95b0-46f04f739d7e/sist-en-14366-2005a1-2019>

Introduction

Noise from wastewater installations is generated by the flow and fall of water in the piping system. There are many different ways to install such systems in buildings, depending on national building codes. They may be firmly cemented into walls and floors, fixed by clips in walls and covered slabs, or hung exposed in the plenum above a suspended ceiling. It seems advisable, therefore, to define measuring methods for both structure-borne and airborne sound.

Important noise sources are bends after vertical sections, but also discontinuities, e.g. inlets, couplings and sleeves. Apart from that the noise impact on the inhabitants of a building strongly depends on the material properties of the pipes, on the methods used in joining and fastening them and on the local building practice.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 14366:2005+A1:2019](https://standards.iteh.ai/catalog/standards/sist/01e127a8-b139-451b-95b0-46f04f739d7e/sist-en-14366-2005a1-2019)

<https://standards.iteh.ai/catalog/standards/sist/01e127a8-b139-451b-95b0-46f04f739d7e/sist-en-14366-2005a1-2019>

1 Scope

This document:

- specifies methods for the measurement of airborne and structure-borne sound produced in waste water and rain water installations under laboratory conditions;
- defines the expression of the results.

It is applicable to waste water piping systems and parts thereof, but not to the actual sources of the wastewater, e.g. lavatories, toilets and bathtubs or any active units. It applies to pipes with natural ventilation and made of any common material in commonly used diameters (up to 150 mm).

A1 The test results can be used for the comparison of products and materials, but cannot be used as values obtained in buildings in situ; in situ values can be predicted using the procedure described in EN 12354-5:2009, 5.5, which transfers laboratory data to field data, assuming the in-situ installation is exactly the same as the one described in the test report. **A1**

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 61672-1, *Electroacoustics - Sound level meters - Part 1: Specifications* (IEC 61672-1:2002)

EN ISO 140-3:1995, *Acoustics – Measurement of sound insulation in buildings and of building elements – Part 3: Laboratory measurements of airborne sound insulation of building elements* (ISO 140-3:1995)

EN ISO 354, *Acoustics – Measurement of sound absorption in a reverberation room* (ISO 354:2003)

EN ISO 6926, *Acoustics – Requirements for the performance and calibration of reference sound sources used for the determination of sound power levels* (ISO 6926:2000)

ISO 5348, *Mechanical vibration and shock – Mechanical mounting of accelerometers*

ISO 16063-21, *Methods for the calibration of vibration and shock transducers – Part 21: Vibration calibration by comparison to a reference transducer*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

waste water

any type of water including rainwater evacuated from buildings into the sewer system

3.2

waste water installation

the total of pipes and all fixing components, used to evacuate waste water, but excluding the actual sources of the waste water, e.g. sinks, toilets, bathtubs, gutter or any active units (pumps...)

EN 14366:2004+A1:2019 (E)**3.3****specimen**

object of tests according to this standard. Specimens are simple wastewater installation systems with a single path of water flow. Any combination of commercial elements may be assembled to form a specimen

3.4**source room**

test room used for airborne sound measurement; the specimen is mounted inside the test room

3.5**receiving room**

test room used for structure-borne sound measurement; the specimen is mounted outside the test room

3.6**standard configuration**

a mandatory form of specimen used for comparison

3.7**standard mounting**

mandatory mounting conditions for the standard configuration

3.8**standard test wall**

mandatory test wall used for comparison

iTeh STANDARD PREVIEW
(standards.iteh.ai)

3.9**wall structural sensitivity**

normalised ratio between a point force exciting the test wall and the sound power radiated by the test wall. The wall structural sensitivity is measured according to a reciprocity method described in Annex A

[SIST EN 14366:2005+A1:2019](https://standards.iteh.ai/catalog/standards/sist/01e127a8-b139-451b-95b0-468453947e18/sist-en-14366-2004-a1-2019)

[https://standards.iteh.ai/catalog/standards/sist/01e127a8-b139-451b-95b0-](https://standards.iteh.ai/catalog/standards/sist/01e127a8-b139-451b-95b0-468453947e18/sist-en-14366-2004-a1-2019)

[468453947e18/sist-en-14366-2004-a1-2019](https://standards.iteh.ai/catalog/standards/sist/01e127a8-b139-451b-95b0-468453947e18/sist-en-14366-2004-a1-2019)

3.10**reference wall**

standardized wall of 250 kg/m² used for normalisation of the measurement results and described by a reference structural sensitivity spectrum (given in clause 9)

3.11**frequency range of measurement**

range in 1/3 octave bands over which measurements are carried out

4 Notations

f	frequency in Hz
T_e	reverberation time measured in the source (emission) room, in seconds (according to EN ISO 354)
T_r	reverberation time measured in the receiving room, in seconds
V_e	volume in the source room in cubic metres
V_r	volume in the receiving room in cubic metres
L'_s	average sound pressure level due to structure-borne sound measured in the receiving room (according to EN ISO 140-3) before correction for background noise, in decibels
L'_t	average total sound pressure level measured in the source room (according to EN ISO 140-3) including airborne and structure-borne sound, before correction for background noise, in decibels
L_B	measured background sound pressure level, in decibels
L_s	structure-borne sound pressure level after correction for background noise, in decibels
L_t	total sound pressure level after correction for background noise, in decibels
L_{sn}	structure-borne sound pressure level normalized to an equivalent absorption area of 10 m ² , in decibels
L_{tn}	total sound pressure level normalized to an equivalent absorption area of 10 m ² , in decibels
L_{an}	airborne sound pressure level normalized to an equivalent absorption area of 10 m ² , in decibels
$L_{s,A}$	A-weighted structure-borne pressure level, in decibels
$L_{a,A}$	A-weighted airborne sound pressure level, in decibels
D_A	attenuation values of the A-weighted filter, in decibels
T_m	measuring time, in seconds
L_{SS}	wall structural sensitivity level, in decibels
L_{SSR}	structural sensitivity level of the reference wall, in decibels
ΔL_{SS}	structural sensitivity correction in decibels : $\Delta L_{SS} = L_{SS} - L_{SSR}$
L_{sc}	structure-borne sound characteristic level, in decibels : $L_{sc} = L_{sn} - \Delta L_{SS}$
L_W	sound power level (ref 10 ⁻¹² watts) of the sound reference source, in decibels
L'_v	vibration velocity level (ref 10 ⁻⁹ m/s) at the clamp fixing, in decibels, before correction for background vibration
L_v	vibration velocity level (ref 10 ⁻⁹ m/s) at the clamp fixing, in decibels, after correction for background vibration

EN 14366:2004+A1:2019 (E)**5 Principle of the test method****5.1 Structure-borne sound measurements (index s)**

The specimen is mounted outside the test room (receiving room), connected as in practice to the test wall using the fixing material specified by the manufacturer of the system. A steady flow of tap water is applied and the total sound transmitted into the test room is measured (L'_s). The specimen is then disconnected from the test wall and the water system operated in order to measure the background noise. The values L'_s are then corrected for background noise giving the values L_s . These values are then normalized (see 9.5) to an equivalent absorption area of 10 m² using the measured reverberation time T_r of the receiving room giving the values L_{sn} .

After the last step, the results are corrected for the difference in structural sensitivity between the test wall used and the reference wall (correction given in clause 9).

5.2 Airborne sound measurement (index a)

The specimen is mounted on a test wall inside the test room (source room). Appropriate openings in the ceiling and in the floor are provided. A steady flow of tap water is applied. The sound in the test room, produced as airborne sound radiated directly from the object but also as structure-borne sound radiated by the wall is measured (L'_t). The water flow is stopped in order to measure the background noise. The values L'_t are then corrected for background noise giving the values L_t and normalized to an equivalent absorption area of 10 m² using the measured reverberation time T_e of the source room giving the values L_{tn} .

Later in the progress of calculation the structure-borne contribution is subtracted giving the values L_{an} .

SIST EN 14366:2005+A1:2019

6 Equipment

<https://standards.iteh.ai/catalog/standards/sist/01e127a8-b139-451b-95b0-46f04f739d7e/sist-en-14366-2005a1-2019>

6.1 Requirements for the frequency range of measurement

Throughout this standard the frequency range is limited to the eighteen 1/3 octave bands with mid-frequencies from 100 Hz to 5 000 Hz. If additional information is required in the low frequency range, measurements at 1/3 octaves 50 Hz, 63 Hz and 80 Hz can be made; guidance for such additional measurements is given in EN ISO 140-3:1995 Annex F.

6.2 Requirements for the acoustic equipment

The equipment shall comply with the requirements of EN ISO 140-3:1995 clause 4.

6.3 Requirements for the hydraulic equipment

The hydraulic equipment shall be able to generate flow rates between 0,5 l/s and an upper limit depending on the inner diameter of the tested specimen (given in 9.2). The equipment shall be able to measure the flow with an accuracy of 5 %.

6.4 Requirements for the wall structural sensitivity measuring equipment

The reciprocity method requires the use of a reference sound source calibrated according to EN ISO 6926. The vibration transducer used shall be calibrated according to ISO 16063-21 and fixed according to ISO 5348.

7 Test facilities

7.1 Construction requirements

7.1.1 Test room

The test room shall have a volume of at least 50 m³ and an interior height of (3,0 ± 0,5) m. The test wall shall not be less than 3,5 m wide. Openings in the ceiling and in the floor are provided for the installation of the test objects.

A combination of two adjacent test rooms may be advantageous, allowing the simultaneous measurement of the airborne and the structure-borne sound.

Additional space above and below the test room is required to ensure the standardised falling height of the measured system of about 6 m (see 8.1.2.).

7.1.2 Test wall

A single wall built of bricks, blocks or poured concrete shall be defined as the standard test wall; hollow bricks or blocks are not allowed. Its mass per unit area, including a coat of mineral based plaster on both sides, shall be (200 ± 50) kg/m².

Any other mass per unit area can be used, as long as the applicability condition defined in Annex A.2 is fulfilled.

7.2 Acoustic requirements

According to EN ISO 140-3, the reverberation time shall be in the range 1s – 2s.

8 Test specimen

8.1 Geometry

8.1.1 Components

The objects tested according to this standard consist of systems of wastewater installations with a single path of the water flow. They consist of:

- an inlet, part of the test object according to Figure 1;
- any combination of straight pipes with tees, bends, joints and inlets, mounted on the test wall;
- a basement bend of totally approximately 90 degree angle, being part of the specimen.

8.1.2 Falling height h

The falling height h shall be in the range 5,8 m – 7,5 m, measured between the inlet point and the impact point (Figure 2). The inlet point is given as the intersection of the axis of the inlet tube with the axis of the vertical pipe; the impact point is defined by the intersection of the vertical pipe axis with the wall of the basement bend.