

Third edition
2013-07-15

AMENDMENT 1
2016-06-01

**Safety devices for protection against
excessive pressure —**

**Part 1:
Safety valves**

AMENDMENT 1

iTeh STANDARD PREVIEW
(standards.iteh.ai)

*Dispositifs de sécurité pour protection contre les pressions
excessives —*

Partie 1: Soupapes de sûreté

ISO 4126-1:2013/Amd 1:2016

AMENDEMENT 1

<https://standards.iteh.ai/catalog/standards/sist/9b44b98a-a337-4810-a510-cc32d122cafa/iso-4126-1-2013-amd-1-2016>



Reference number
ISO 4126-1:2013/Amd.1:2016(E)

© ISO 2016

iTeh STANDARD PREVIEW (standards.iteh.ai)

[ISO 4126-1:2013/Amd 1:2016](https://standards.iteh.ai/catalog/standards/sist/9b44b98a-a337-4810-a510-cc32d122cafa/iso-4126-1-2013-amd-1-2016)

<https://standards.iteh.ai/catalog/standards/sist/9b44b98a-a337-4810-a510-cc32d122cafa/iso-4126-1-2013-amd-1-2016>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2016, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

Amendment 1 to ISO 4126-1:2013 was prepared by Technical Committee ISO/TC 185, *Safety devices for protection against excessive pressure*.

[ISO 4126-1:2013/Amd 1:2016](#)

<https://standards.iteh.ai/catalog/standards/sist/9b44b98a-a337-4810-a510-cc32d122cafa/iso-4126-1-2013-amd-1-2016>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 4126-1:2013/Amd 1:2016

<https://standards.iteh.ai/catalog/standards/sist/9b44b98a-a337-4810-a510-cc32d122cafa/iso-4126-1-2013-amd-1-2016>

Safety devices for protection against excessive pressure —

Part 1: Safety valves

AMENDMENT 1

Page 9

Clause 7.2.1 General Requirements

Delete the text and substitute:

7.2.1 General Requirements

The set pressures at which the operating characteristics are determined shall be the minimum and maximum set pressures for which the spring is designed. Valves for air or other gas service shall be tested using air or any other gas of known characteristics or superheated steam with a minimum of 10 °C of superheat. Valves for steam service shall be tested on steam, air or other gas of known characteristics. Valves for liquid service shall be tested on water or other liquids of known characteristics.

The allowable tolerances or limits as applicable on the operating characteristics are as follows:

- a) set pressure: $\pm 3\%$ of set pressure or $\pm 0,1$ bar, whichever is the greater;
- b) lift at overpressure: not less than the values stated by the manufacturer;
- c) overpressure: the value stated by the manufacturer but not exceeding 10 % of set pressure or 0,1 bar, whichever is greater;
- d) blowdown: not greater than the value stated by the manufacturer, but within the following limits:
 - compressible fluids: minimum: 2,0 % [not applicable to safety valves with proportional opening characteristics according to f)], maximum: 15 % or 0,3 bar, whichever is greater;
 - incompressible fluids: minimum: 2,5 % [not applicable to safety valves with proportional opening characteristics according to f)], maximum: 20 % or 0,6 bar, whichever is greater;
- e) overpressure and blowdown of restricted lift valves shall have the same tolerances or limits as the unrestricted lift valves;
- f) overpressure and blowdown of valves with proportional opening characteristics shall be verified and be stable for various lifts between the minimum and maximum stated by the manufacturer. A curve shall be established for valve lift versus overpressure.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO 4126-1:2013/Amd 1:2016](https://standards.iteh.ai/catalog/standards/sist/9b44b98a-a337-4810-a510-cc32d122cafa/iso-4126-1-2013-amd-1-2016)
<https://standards.iteh.ai/catalog/standards/sist/9b44b98a-a337-4810-a510-cc32d122cafa/iso-4126-1-2013-amd-1-2016>