
Klimatske naprave, enote za hlajenje kapljevine ter toplotne črpalke za ogrevanje in hlajenje prostora z električnimi kompresorji - Preskušanje in ocenitev ob delni obremenitvi ter izračun letnega učinka

Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling - Testing and rating at part load conditions and calculation of seasonal performance

Luftkonditionierer, Flüssigkeitskühlsätze und Wärmepumpen mit elektrisch angetriebenen Verdichtern zur Raumbeneizung und -kühlung - Prüfung und Leistungsbemessung unter Teillastbedingungen und Berechnung der jahreszeitbedingten Leistungszahl

<https://standards.iteh.ai/catalog/standards/sist/0d3be441-d22e-447c-8204-e2b4b9c731f1/osist-pr-en-14825-2020>

Climatiseurs, groupes refroidisseurs de liquide et pompes à chaleur avec compresseur entraîné par moteur électrique pour le chauffage et la réfrigération des locaux - Essais et détermination des caractéristiques à charge partielle et calcul de performance

Ta slovenski standard je istoveten z: prEN 14825

ICS:

| | | |
|-----------|---------------------------------------|--|
| 23.120 | Zračniki. Vetrniki. Klimatske naprave | Ventilators. Fans. Air-conditioners |
| 27.080 | Toplotne črpalke | Heat pumps |
| 91.140.30 | Prezračevalni in klimatski sistemi | Ventilation and air-conditioning systems |

oSIST prEN 14825:2020**en,fr,de**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN 14825:2020](#)

<https://standards.iteh.ai/catalog/standards/sist/0d3be441-d22e-447c-8204-e2b4b9c731f4/osist-pren-14825-2020>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 14825

October 2020

ICS 27.080; 91.140.30

Will supersede EN 14825:2018

English Version

Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling - Testing and rating at part load conditions and calculation of seasonal performance

Climatiseurs, groupes refroidisseurs de liquide et pompes à chaleur avec compresseur entraîné par moteur électrique pour le chauffage et la réfrigération des locaux - Essais et détermination des caractéristiques à charge partielle et calcul de performance

Luftkonditionierer, Flüssigkeitskühlsätze und Wärmepumpen mit elektrisch angetriebenen Verdichtern zur Raumbeheizung und -kühlung - Prüfung und Leistungsbemessung unter Teillastbedingungen und Berechnung der jahreszeitbedingten Leistungszahl

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 113.

ITeH STANDARD PREVIEW
(standards.iteh.ai)

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

| | Page |
|--|------|
| European foreword..... | 7 |
| Introduction | 9 |
| 1 Scope..... | 10 |
| 2 Normative references..... | 10 |
| 3 Terms, definitions, symbols, abbreviated terms and units | 11 |
| 3.1 Terms and definitions | 11 |
| 3.2 Symbols, abbreviated terms and units..... | 24 |
| 4 Part load conditions for space cooling | 28 |
| 4.1 General..... | 28 |
| 4.2 Air-to-air units | 28 |
| 4.3 Water(brine)-to-air units..... | 29 |
| 4.4 Air-to-water(brine) units..... | 29 |
| 4.5 Water(brine)-to-water(brine) units | 30 |
| 5 Calculation methods for seasonal space cooling efficiency $\eta_{s,c}$, <i>SEER</i> and <i>SEER</i> _{on} | 31 |
| 5.1 General..... | 31 |
| 5.2 Calculation of the seasonal space cooling efficiency $\eta_{s,c}$ | 31 |
| 5.3 General formula for calculation of <i>SEER</i> | 32 |
| 5.4 Calculation of the reference annual cooling demand Q_c | 32 |
| 5.5 Calculation of the reference annual energy consumption for space cooling Q_{CE} | 32 |
| 5.6 Calculation of <i>SEER</i> _{on} | 33 |
| 5.7 Calculation procedure for determination of EERbin values at part load conditions A, B, C, D | 34 |
| 5.7.1 General..... | 34 |
| 5.7.2 Calculation procedure for fixed capacity units | 34 |
| 5.7.3 Calculation procedure for staged and variable capacity units | 35 |
| 6 Part load conditions for space heating..... | 35 |
| 6.1 General..... | 35 |
| 6.2 Air-to-air units | 36 |
| 6.3 Water(brine)-to-air-units | 37 |
| 6.4 Air-to-water(brine) units..... | 38 |
| 6.4.1 General..... | 38 |
| 6.4.2 Low temperature application | 38 |
| 6.4.3 Intermediate temperature application..... | 39 |
| 6.4.4 Medium temperature application..... | 40 |
| 6.4.5 High temperature application..... | 41 |
| 6.5 DX-to-water(brine) and water(brine)-to-water(brine) units | 42 |
| 6.5.1 General..... | 42 |
| 6.5.2 Low temperature application | 42 |
| 6.5.3 Intermediate temperature application..... | 43 |
| 6.5.4 Medium temperature application..... | 44 |
| 6.5.5 High temperature application..... | 45 |
| 7 Calculation methods for seasonal space heating efficiency $\eta_{s,h}$, <i>SCOP</i> , <i>SCOP</i> _{on} and <i>SCOP</i> _{net} of heat pumps..... | 46 |

| | | |
|--------|---|----|
| 7.1 | General | 46 |
| 7.2 | Calculation of the seasonal space heating efficiency $\eta_{s,h}$ | 46 |
| 7.3 | General formula for calculation of $SCOP$ | 47 |
| 7.4 | Calculation of the reference annual heating demand Q_H | 47 |
| 7.5 | Calculation of the annual energy consumption for heating Q_{HE} | 48 |
| 7.6 | Calculation of $SCOP_{on}$ and $SCOP_{net}$ | 48 |
| 7.7 | Calculation procedure for determination of COP_{bin} values at part load conditions A to G | 50 |
| 7.7.1 | General | 50 |
| 7.7.2 | Calculation procedure for fixed capacity units | 50 |
| 7.7.3 | Calculation procedure for staged and variable capacity units | 51 |
| 8 | Test methods for hybrid units | 51 |
| 8.1 | General | 51 |
| 8.2 | Separated method | 52 |
| 8.2.1 | General | 52 |
| 8.2.2 | Heat pump testing | 52 |
| 8.2.3 | Boiler testing | 52 |
| 8.2.4 | Energy efficiency and seasonal coefficient of performance calculations | 52 |
| 8.3 | Combined test method | 54 |
| 8.3.1 | General | 54 |
| 8.3.2 | Test conditions | 54 |
| 8.3.3 | Test installation | 54 |
| 8.3.4 | Calculation of gas input | 54 |
| 8.3.5 | Calculation of liquid fuel input | 55 |
| 8.3.6 | Calculation of annual fossil fuel consumption | 55 |
| 8.3.7 | Energy efficiency and seasonal coefficient of performance calculations | 56 |
| 9 | Part load conditions for process cooling | 58 |
| 10 | Calculation method for $SEPR$ | 59 |
| 10.1 | General formula for calculation of $SEPR$ | 59 |
| 10.2 | Calculation procedure for determination of EER_{bin} values at part load conditions A, B, C, D | 60 |
| 10.2.1 | General | 60 |
| 10.2.2 | Calculation procedure for fixed capacity process chillers | 61 |
| 10.2.3 | Calculation procedure for variable capacity process chillers | 61 |
| 11 | Test methods for testing capacities, EER_{bin} and COP_{bin} values during active mode at part load conditions | 61 |
| 11.1 | General | 61 |
| 11.2 | Refrigerant piping | 62 |
| 11.3 | Basic principles | 62 |
| 11.4 | Uncertainties of measurement | 64 |
| 11.5 | Test procedures for units with fixed capacity | 65 |
| 11.5.1 | General | 65 |
| 11.5.2 | Air-to-air and water(brine)-to-air units - Determination of the degradation coefficient C_d | 66 |
| 11.5.3 | Air-to-water(brine), water(brine)-to-water(brine) and DX-to-water(brine) units - Determination of the degradation coefficient C_d | 68 |
| 11.6 | Test procedure for staged and variable capacity units | 69 |
| 11.6.1 | General | 69 |
| 11.6.2 | Settings for the required capacity ratio | 69 |
| 11.6.3 | Compensation method | 69 |

prEN 14825:2020 (E)

| | | |
|---|---|-----------|
| 12 | Test methods for electric power input during thermostat-off mode, standby mode and crankcase heater mode and off mode | 69 |
| 12.1 | Uncertainties of measurement..... | 69 |
| 12.2 | Measurement of electric power input during thermostat-off mode | 70 |
| 12.3 | Measurement of the electric power input during standby mode | 70 |
| 12.4 | Measurement of the electric power input during crankcase heater mode..... | 70 |
| 12.5 | Measurement of the electric power input during off mode | 71 |
| 13 | Test report..... | 71 |
| 14 | Technical documentation..... | 71 |
| 15 | Testing and rating of individual indoor units..... | 71 |
| Annex A (normative) Applicable climate bins and hours for air conditioners with rated capacity of ≤ 12 kW for cooling, or heating if the product has no cooling function | | 72 |
| A.1 | Climate bins..... | 72 |
| A.1.1 | Bin limit temperature..... | 72 |
| A.1.2 | Cooling..... | 72 |
| A.1.3 | Heating..... | 73 |
| A.2 | Hours for active mode, thermostat-off, standby, off mode | 75 |
| A.2.1 | Cooling..... | 75 |
| A.2.2 | Heating..... | 75 |
| A.3 | Hours used for crankcase heater mode | 75 |
| A.3.1 | Cooling..... | 75 |
| A.3.2 | Heating..... | 76 |
| Annex B (normative) Applicable climate bins and hours for air/water(brine)/DX-to-water(brine) heat pumps with a rated heat output ≤ 400 kW | | 77 |
| B.1 | Climate bins..... | 77 |
| B.1.1 | Bin limit temperature..... | 77 |
| B.1.2 | Heating..... | 77 |
| B.2 | Hours for active, thermostat-off, standby and off modes - Heating | 79 |
| B.3 | Hours used for crankcase heater mode - Heating..... | 79 |
| Annex C (normative) Applicable climate bins and hours for process chillers | | 80 |
| C.1 | Climate bins..... | 80 |
| Annex D (normative) Applicable climate bins and hours for air-to-air units > 12 kW, water(brine)-to-air units and comfort chillers | | 84 |
| D.1 | Climate bins..... | 84 |
| D.1.1 | Bin limit temperature..... | 84 |
| D.1.2 | Cooling..... | 84 |
| D.1.3 | Heating..... | 85 |
| D.2 | Hours for active, thermostat-off, standby and off modes | 87 |
| D.2.1 | Cooling..... | 87 |

| | | |
|---------|--|-----|
| D.2.2 | Heating | 87 |
| D.3 | Hours used for crankcase heater mode..... | 87 |
| D.3.1 | Cooling..... | 87 |
| D.3.2 | Heating | 87 |
| Annex E | (normative) Templates for technical documentation..... | 88 |
| E.1 | General | 88 |
| E.2 | Air-to-air units ≤ 12 kW..... | 88 |
| E.3 | Space heaters: air-to-water(brine), water(brine)-to-water(brine) and DX-to-water(brine) units ≤ 400 kW | 92 |
| E.4 | Hybrid units..... | 94 |
| E.5 | Process Chillers | 96 |
| E.6 | Comfort chillers, air-to-air (>12 kW) and water(brine)-to-air air conditioners not exceeding 2 MW..... | 97 |
| E.7 | Air-to-air and water(brine)-to-air heat pumps not exceeding 1 MW..... | 98 |
| Annex F | (informative) Determination of water(brine) temperature for fixed capacity units with variable outlet temperature | 100 |
| F.1 | General | 100 |
| F.2 | Test procedure for an air-to-water unit with fixed water flow rate | 100 |
| F.3 | Test procedure for an air-to-water unit with variable water flow rate..... | 101 |
| Annex G | (informative) Calculation example for $SEER_{on}$ and $SEER$ – Application to a reversible air-to-air unit with variable capacity..... | 103 |
| G.1 | Calculation of $SEER_{on}$ | 103 |
| G.2 | Calculation of $SEER$ | 105 |
| G.2.1 | Calculation of reference annual cooling demand (Q_c) according to Formula (3) | 105 |
| G.2.2 | Calculation of $SEER$ according to Formula (6)..... | 105 |
| Annex H | (informative) Calculation example for $SCOP_{on}$ and $SCOP_{net}$ – Application to a fixed capacity air-to-water(brine) heat pump used for low temperature application | 106 |
| Annex I | (informative) Calculation example for $SCOP_{on}$ and $SCOP_{net}$ – Application to a fixed capacity brine-to-water(brine) heat pump used for medium temperature application | 112 |
| Annex J | (informative) Calculation examples for $SCOP_{on}$ for hybrid units..... | 119 |
| J.1 | Calculation example for $SCOP_{on}$ for variable speed hybrid unit based on heat pump and boiler separated tests..... | 119 |
| J.2 | Calculation example for $SCOP_{on}$ for hybrid unit using combined test method | 121 |
| Annex K | (informative) Calculation example for $SEPR$ – Application to a process chiller with staged capacity | 124 |
| K.1 | Rating performance..... | 124 |
| Annex L | (informative) Compensation methods for air-to-water(brine) and water(brine)-to-water(brine) units..... | 127 |

prEN 14825:2020 (E)

| | | |
|---|---|------------|
| L.1 | General..... | 127 |
| L.2 | Compensation system for reduced capacity test in cooling mode | 127 |
| L.3 | Compensation system for reduced capacity test in heating mode..... | 127 |
| Annex M (normative) Rating of outdoor units of multi-split air conditioners and heat pumps..... | | 129 |
| M.1 | General..... | 129 |
| M.2 | Rating of outdoor units | 129 |
| M.2.1 | General..... | 129 |
| M.2.2 | Test procedure | 130 |
| M.3 | Calculation of the <i>SEER</i> based on the <i>EER</i> _{outdoor} | 130 |
| M.4 | Calculation of the <i>SCOP</i> based on the <i>COP</i> _{outdoor} | 130 |
| Annex N (Normative) Testing and rating of individual indoor units..... | | 131 |
| N.1 | Indoor unit under test | 131 |
| N.2 | Test methods | 131 |
| N.2.1 | General..... | 131 |
| N.2.2 | Calorimeter method..... | 131 |
| N.2.2.1 | 3-room Calorimeter method..... | 131 |
| N.2.2.2 | 2-room calorimeter method..... | 131 |
| N.2.3 | Air-enthalpy method..... | 132 |
| N.2.3.1 | 3-room air enthalpy method..... | 132 |
| N.2.3.2 | 2-room air enthalpy method..... | 132 |
| N.3 | Test conditions..... | 132 |
| N.4 | Rated performance..... | 132 |
| N.5 | Data to be recorded | 133 |
| Annex ZA (informative) Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 206/2012 aimed to be covered..... | | 135 |
| Annex ZB (informative) Relationship between this European Standard and the labelling requirements of Commission Delegated Regulation (EU) No 626/2011 aimed to be covered..... | | 136 |
| Annex ZC (informative) Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 813/2013 aimed to be covered..... | | 137 |
| Annex ZD (informative) Relationship between this European Standard and the energy labelling requirements of Commission Delegated Regulation (EU) No 811/2013 aimed to be covered | | 138 |
| Annex ZE (informative) Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 2015/1095 aimed to be covered..... | | 139 |
| Annex ZF (informative) Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 2016/2281 aimed to be covered..... | | 140 |
| Bibliography..... | | 142 |

European foreword

This document (prEN 14825:2020) has been prepared by Technical Committee CEN/TC 113 “Heat pumps and air conditioning units”, the secretariat of which is held by UNE.

This document is currently submitted to the CEN Enquiry.

This document will supersede EN 14825:2018.

The revision was necessary in order to harmonize this document with Commission Regulation (EU) No 2016/2281 of 30 November 2016 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for air heating products, cooling products, high temperature process chillers and fan coil units and to harmonize with this European Standard with Commission Delegated Regulation (EU) No 626/2011 of 04 May 2011 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to energy labelling of air conditioners and Commission's standardization request M/495 and Amendment N° 1.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Regulation(s), see informative Annex ZA, Annex ZB, Annex ZC, Annex ZD, Annex ZE and Annex ZF, which are integral parts of this document.

The main changes with respect to requirements for *forthcoming regulations* are:

- a) modification of the title to include commercial cooling and process cooling;
- b) modification of Table 4 to include exhaust air dry bulb temperatures;
- c) new requirements for hybrid heat pumps in Clause 8;
- d) new structure to separate requirements for calculation methods for seasonal space heating efficiency of heat pumps (Clause 7) and requirements for test methods for hybrid heat pumps (Clause 8);
- e) updated uncertainties of measurement for the air enthalpy method;
- f) removed the void Annex I and renumbered the following Annexes;
- g) added a new Annex N about testing and rating of individual indoor units;
- h) new informative Annex ZB, Relationship between this European Standard and the requirements of Commission Regulation (EU) No 626/2011 of 04 May 2011; and renumbered the following annexes;
- i) new informative Annex ZE, Relationship between this European Standard and the requirements of Commission Regulation (EU) No 2016/2281 of 30 November 2016;

prEN 14825:2020 (E)

h) new numbering of annexes.

| EN 14825:2018 | EN 14825:20121 |
|----------------------|-----------------------|
| Annex I | |
| Annex J | Annex I |
| Annex K | Annex J |
| Annex L | Annex K |
| Annex M | Annex L |
| Annex N | Annex M |
| | Annex N |
| | Annex O |
| | Annex ZB |
| Annex ZB | Annex ZC |
| Annex ZC | Annex ZD |
| Annex ZD | Annex ZE |
| | Annex ZF |

ITeH STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN 14825:2020](https://standards.iteh.ai/catalog/standards/sist/0d3be441-d22e-447c-8204-e2b4b9c731f4/osist-pren-14825-2020)

<https://standards.iteh.ai/catalog/standards/sist/0d3be441-d22e-447c-8204-e2b4b9c731f4/osist-pren-14825-2020>

Introduction

Heat pumps, air conditioners and liquid chilling packages can be selected and compared at standard rating conditions. These conditions do not represent the usual operating conditions of the equipment over a season. Better comparison for equipment can be assessed by determining Seasonal Energy Efficiency Ratio, Seasonal Coefficient of Performance and Seasonal Energy Performance Ratio that enable to take into account more representative operating conditions and performance at rated capacities.

Fixed capacity heat pumps, air conditioners and liquid chilling packages deal with varying loads by varying the operation time. The efficiency of the system is dependent on the effectiveness of the controlling thermostats. Variable capacity air conditioners, liquid chilling packages and heat pumps, by continuous or step control of the compressor, can more closely match the varying load improving system efficiency.

This document provides part load conditions and calculation methods for calculating the Seasonal Energy Efficiency Ratio ($SEER_{on}$), the seasonal energy performance ratio ($SEPR$) and Seasonal Coefficient of Performance ($SCOP_{on}$ and $SCOP_{net}$) of such units when they are used to fulfil the cooling and heating demands.

Other electric energy consumptions can occur when the unit is not used to fulfil the cooling and heating demands such as those from a crankcase heater or when the unit is on standby. These consumptions are considered in the calculation methods for $SEER$ and $SCOP$.

This document also considers Seasonal Energy Performance Ratio of process chillers ($SEPR$) which is representative of variations in loads throughout a complete year. Test conditions and test method are described to calculate this $SEPR$.

$SEER/SEER_{on}$, $SCOP/SCOP_{on}$, $SCOP_{net}$ and $SEPR$ calculations may be based on calculated or measured values. In case of measured values, this document gives the methods for testing heat pumps, air conditioners and liquid chilling packages at part load conditions.

The standard rating conditions and test methods are given in EN 14511-2 and EN 14511-3.

The standard provides test procedures for the rating of individual indoor units, as part of multisplit systems having a system capacity > 12 kW.

Although this document was prepared in the frame of the Commission Regulation (EU) No 206/2012 implementing Directive 2009/125/EC with regard to ecodesign requirements for air conditioners and comfort fans, it may also be used to show compliance with the requirements of the European Directive 2010/30/EU and Commission Delegated Regulation (EU) No 626/2011.

This document was prepared in the frame of the Commission Regulation (EU) No 813/2013 implementing Directive 2009/125/EC with regard to ecodesign requirements for space heaters and combination heaters. This European standard also aims at showing compliance with the requirements of the European Directive 2010/30/EU and Commission Delegated Regulation (EU) No 811/2013.

This document was prepared in the frame of the Commission Regulation (EU) 2015/1095 of 5 May 2015 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for professional refrigerated storage cabinets, blast cabinets, condensing units and process chillers.

This document was prepared in the frame of the Commission Regulation (EU) 2016/2281 of 30 November 2016 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for air heating products, cooling products, high temperature process chillers and fan coils.

prEN 14825:2020 (E)**1 Scope**

This document covers air conditioners, heat pumps and liquid chilling packages, including comfort and process chillers. It applies to factory made units defined in EN 14511-1, except single duct, double duct, control cabinet and close control units. It also covers direct exchange-to-water(brine) heat pumps (DX-to-water(brine)) as defined in EN 15879-1.

This document also covers hybrid units as defined in this standard.

This document gives the temperatures and part load conditions and the calculation methods for the determination of seasonal energy efficiency $SEER$ and $SEER_{on}$, seasonal space cooling energy efficiency $\eta_{s,c}$ seasonal coefficient of performance $SCOP$, $SCOP_{on}$ and $SCOP_{net}$, and seasonal space heating energy efficiency $\eta_{s,h}$ and seasonal energy performance ratio $SEPR$.

Such calculation methods can be based on calculated or measured values.

In case of measured values, this document covers the test methods for determination of capacities, EER and COP values during active mode at part load conditions. It also covers test methods for power input during thermostat-off mode, standby mode, off mode and crankcase heater mode.

NOTE 1 The word “unit” is used instead of the full terms of the products.

NOTE 2 The word “heating” is used to refer to space heating.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 267:2017, *Automatic forced draught burners for liquid fuels* 020

[https://standards.iteh.ai/catalog/standards/sist/0d3be441-d22e-447c-8204-](https://standards.iteh.ai/catalog/standards/sist/0d3be441-d22e-447c-8204-2f61e2278000/en-267-2017)

EN 304:2018, *Heating boilers — Test code for heating boilers for atomizing oil burners*

EN 14511-1:2019, *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors — Part 1: Terms and definitions*

EN 14511-2:2019, *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors — Part 2: Test conditions*

EN 14511-3:2019, *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors — Part 3: Test methods*

EN 15879-1:2011, *Testing and rating of direct exchange ground coupled heat pumps with electrically driven compressors for space heating and/or cooling — Part 1: Direct exchange-to-water heat pumps*

EN 15502-1:1989, *Gas-fired heating boilers — Part 1: General requirements and tests*

3 Terms, definitions, symbols, abbreviated terms and units

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 14511-1 and EN 15879-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <http://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1.1

active mode

mode corresponding to the hours with a space cooling or heating load of the building and whereby the cooling or heating function of the unit is activated

Note 1 to entry: This condition may involve on/off-cycling of the unit in order to reach or maintain a required indoor air temperature.

3.1.2

active mode seasonal coefficient of performance

$SCOP_{on}$

average coefficient of performance of the unit in active mode for the designated heating season, determined from the part load, supplementary heating capacity (where required) and bin-specific coefficients of performance ($COP_{bin}(T_j)$) and weighted by the bin hours where the bin condition occurs

Note 1 to entry: For calculation of $SCOP_{on}$, the energy consumption during thermostat-off mode, standby mode, off mode and crankcase heater mode are excluded. The energy consumption of a supplementary heater is added for the part load conditions where the declared capacity of the unit is lower than the heating load, regardless whether this supplementary heater is included in the unit or not included in the unit.

Note 2 to entry: Expressed in kWh/kWh.

3.1.3

active mode seasonal energy efficiency ratio

$SEER_{on}$

average energy efficiency ratio of the unit in active mode for the space cooling function, determined from part load and bin-specific energy efficiency ratios ($EER_{bin}(T_j)$) and weighted by the bin hours where the bin condition occurs

Note 1 to entry: For calculation of $SEER_{on}$, energy consumption during thermostat-off mode, standby mode, off mode and that of the crankcase heater is excluded.

Note 2 to entry: Expressed in kWh/kWh.

3.1.4

annual energy consumption for space cooling

Q_{CE}

energy consumption required to meet the reference annual space cooling demand and calculated as the reference annual space cooling demand divided by the active mode seasonal energy efficiency ratio ($SEER_{on}$) and the energy consumption of the unit for thermostat-off-, standby-, off- and crankcase heater mode during the cooling season

Note 1 to entry: Expressed in kWh.

prEN 14825:2020 (E)**3.1.5****annual energy consumption for heating** Q_{HE}

energy consumption required to meet the reference annual heating demand for a designated heating season and calculated as the reference annual heating demand divided by the active mode seasonal coefficient of performance ($SCOP_{on}$) and the energy consumption of the unit for thermostat-off-, standby-, off- and crankcase heater mode during the heating season

Note 1 to entry: Expressed in kWh.

3.1.6**average climate conditions**

temperature conditions characteristic for the city of Strasbourg for the heating season

3.1.7**bin**

outdoor temperature interval of 1 K

3.1.8**bin hours** h_j

hours per season for which an outdoor temperature occurs for each bin j

3.1.9**bin limit temperature**

temperature in the bin for which no more heating or cooling is required

Note 1 to entry: The bin limit temperature equals 16 °C for all climates in space cooling and space heating applications.

<https://standards.iteh.ai/catalog/standards/sist/0d3be441-d22e-447c-8204-e2b4b9c731f4/osist-pren-14825-2020>

3.1.10**bin-specific coefficient of performance** $COP_{bin}(T_j)$

coefficient of performance specific for every bin j with outdoor temperature T_j in a season

3.1.11**bin-specific energy efficiency ratio** $EER_{bin}(T_j)$

energy efficiency ratio specific for every bin j with outdoor temperature T_j in a season

3.1.12**bin temperature** T_j

outdoor air dry bulb temperature

Note 1 to entry: Expressed in °C.

Note 2 to entry: The relative humidity may be indicated by a corresponding wet bulb temperature.

3.1.13**bivalent temperature** T_{biv}

lowest outdoor temperature point at which the unit is declared to have a capacity able to meet 100 % of the heating load without supplementary heater, whether it is integrated in the unit or not

Note 1 to entry: Below this point, the unit may still provide capacity, but additional supplementary heating is necessary to fulfil the full heating load.

Note 2 to entry: Bivalent temperature does not apply to units.

3.1.14**capacity control**

ability of the unit to change its capacity by changing the volumetric flow rate of the refrigerant

Note 1 to entry: Units are indicated as '*fixed*' if the unit cannot change its volumetric flow rate, '*staged*' if the volumetric flow rate is changed or varied in series of not more than two steps, or '*variable*' if the volumetric flow rate is changed or varied in series of three or more steps.

3.1.15**capacity ratio** CR

cooling (or heating) part load or full load divided by the declared cooling (or heating) capacity of the unit at the same temperature conditions

3.1.16**climate conditions**

temperature conditions (dry bulb) characteristic for a specific location

3.1.17**coefficient of performance at declared capacity** COP_d

declared heating capacity of the unit divided by the effective power input of the unit at specific temperature conditions, A, B, C, D, E, F and G, where applicable

Note 1 to entry: Expressed in kW/kW.

3.1.18**coefficient of performance at part load** COP_{bin}

coefficient of performance at the declared capacity, corrected with the degradation coefficient, where applicable

Note 1 to entry: When the declared capacity of the unit is higher than the heating load, the COP_{bin} includes degradation losses. When the declared capacity of the unit is lower than the heating load (i.e. below the bivalent temperature condition), the COP_{bin} is equal to the COP of the declared capacity.

Note 2 to entry: Expressed in kW/kW.

3.1.19**colder climate conditions**

temperature conditions characteristic for the city of Helsinki for the heating season

ITh STANDARD PREVIEW
(standards.iteh.ai)

oSIST prEN 14825:2020
<https://standards.iteh.ai/catalog/standards/sist/0d3be441-d22e-447c-8204-e2b4b9c731f4/osist-pren-14825-2020>