



SLOVENSKI STANDARD

SIST EN 14452:2005

01-september-2005

BUdfUj Y'nUj Ufcj Ub'Y'dfYX'cbYgbUjYb'Ya 'd]hbY'j cXY'nUfUX]dcj fUhbY[Uhc_U!
7 Yj b]dfY_]b'U'b]_n'cXdfh]bUa]nUXcj cX'nfU_U]b'dfYa] b]a 'XYca ž8 B'%'Xc'8 B
&\$'E'8 fi y]bU8 žhd'6

Devices to prevent pollution by backflow of potable water - Pipe interrupter with atmospheric vent and moving element DN 10 to DN 20 - Family D, type B

iTeh STANDARD PREVIEW

Sicherungseinrichtungen zum (Schutz des Trinkwassers) gegen Verschmutzung durch Rückfließen - Rohrunterbrecher mit Lufteintrittsöffnung und beweglichem Teil, DN 10 bis DN 20 - Familie D, Typ B

[SIST EN 14452:2005](#)

[https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-](https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005)

[2c52c162bd77/sist-en-14452-2005](https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005)

Dispositifs de protection contre la pollution de l'eau potable par retour - Rupteur a évent atmosphérique avec élément mobile DN 10 a DN 20 - Famille D, type B

Ta slovenski standard je istoveten z: EN 14452:2005

ICS:

13.060.20	Pitna voda	Drinking water
23.060.50	Blokirni ventili	Check valves
91.140.60	Sistemi za oskrbo z vodo	Water supply systems

SIST EN 14452:2005

en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 14452:2005](#)

<https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 14452

May 2005

ICS 13.060.20; 23.060.50

English version

**Devices to prevent pollution by backflow of potable water - Pipe
interrupter with atmospheric vent and moving element DN 10 to
DN 20 - Family D, type B**

Dispositifs de protection contre la pollution de l'eau potable
par retour - Rupteur à évent atmosphérique avec élément
mobile DN 10 à DN 20 - Famille D, type B

Sicherungseinrichtungen zum Schutz des Trinkwassers
gegen Verschmutzung durch Rückfließen -
Rohrunterbrecher mit Lufteintrittsöffnung und beweglichem
Teil, DN 10 bis DN 20 - Familie D, Typ B

This European Standard was approved by CEN on 24 December 2004.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents	Page
Foreword.....	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	6
4 Nominal sizes	6
5 Designation	6
6 Marking and technical documents	7
7 Symbolisation	8
8 General design characteristics	8
9 Physico-chemical characteristics	9
10 Characteristics and tests	9
11 Acoustic characteristics	15
Annex A (normative) Sampling and test sequence	16

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 14452:2005](https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005)

<https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005>

Foreword

This document (EN 14452:2005) has been prepared by Technical Committee CEN/TC 164 "Water supply", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2005, and conflicting national standards shall be withdrawn at the latest by November 2005.

This document has been worked out in reference with EN 1717 "Protection against pollution of potable water in water installations and general requirements of devices to prevent pollution by backflow".

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 14452:2005](https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005)

<https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005>

Introduction

In respect of potential adverse effects on the quality of water intended for human consumption, caused by the product covered by this document:

- a) this document provides no information as to whether the product may be used without restriction in any of the Member States of the EU or EFTA;
- b) it should be noted that, while awaiting the adoption of verifiable European criteria, existing national regulations concerning the use and/or the characteristics of this product remain in force.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 14452:2005](https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005)

<https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005>

1 Scope

This document specifies:

- a) field of application;
- b) requirements for pipe interrupters with atmospheric vent and moving element;
- c) dimensional and the physico-chemical properties, and the properties of general hydraulic, mechanical and acoustic design of pipe interrupters with elastic membrane of DN 10 to DN 20;
- d) test procedure and requirements for verifying these properties;
- e) marking and presentation;
- f) acoustics.

This document specifies the characteristics of pipe interrupters with atmospheric vent and moving element, DN 10 to DN 20 that are suitable for use in drinking water systems at pressures up to 1 MPa (10 bar) and temperatures up to 65 °C and for 1 h at 90 °C.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 806-1:2000, *Specification for installations inside buildings conveying water for human consumption — Part 1: General*

[SIST EN 14452:2005](https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-632c162bd77/sist-en-806-1-2000)

EN 1717:2000, *Protection against pollution of potable water in water installations and general requirements of devices to prevent pollution by backflow*

EN ISO 228-1, *Pipe threads where pressure-tight joints are not made on the threads — Part 1: Dimensions, tolerances and designation (ISO 228-1:2000)*

EN ISO 3822-1, *Acoustics — Laboratory tests on noise emission from appliances and equipment used in water supply installations — Part 1: Method of measurement (ISO 3822-1:1999)*

EN ISO 3822-3, *Acoustics — Laboratory tests on noise emission from appliances and equipment used in water supply installations — Part 3: Mounting and operating conditions for in-line valves and appliances (ISO 3822-3:1997)*

EN ISO 3822-4, *Acoustics — Laboratory tests on noise emission from appliances and equipment used in water supply installations — Part 4: Mounting and operating conditions for special appliances (ISO 3822-4:1997)*

EN ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full - Part 1: General principles and requirements (ISO 5167-1:2003)*

EN ISO 6509, *Corrosion of metals and alloys — Determination of dezincification resistance of brass (ISO 6509:1981)*

ISO 7-1, *Pipe threads where pressure-tight joints are made on the threads — Part 1: Dimensions, tolerances and designation*

ISO 9227, *Corrosion tests in artificial atmospheres — Salt spray tests*

EN 14452:2005 (E)

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1717:2000, EN 806-1:2000 and the following apply.

pipe interrupter with atmospheric vent and moving element

pipe interrupter with elastic membrane, fitted with air inlet port(s) which is (are) closed, when water flows through it above atmospheric pressure, but which opens (open) to admit air if there is a subatmospheric pressure at the water inlet or when the flow stops, and close to be watertight when the flow of water is resumed at normal pressure. It ensures protection against back siphonage only by draining to the atmosphere, but not against back pressure. Direction of water flow is vertically downwards.

For the purpose of this document "pipe interrupter with atmospheric vent and moving element DB" is hereafter referred to as "device(s)"

4 Nominal size

The nominal size of the device shall correspond to the denomination of the thread according to Table 1, EN ISO 228-1 or ISO 7-1.

Table 1 — Nominal size vs union end thread size

DN	10	15	20
Thread size	$\frac{3}{8}$	$\frac{1}{2}$	$\frac{3}{4}$

(standards.iteh.ai)

5 Designation

[SIST EN 14452:2005
https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005](https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005)

The devices are designated by:

- name;
- reference to this document (EN 14452);
- family, type;
- nominal size (DN);
- body material;
- acoustic group.

Example of designation:

Pipe interrupter EN 14452, family D, type B, DN 20, gun metal, I.

6 Marking and technical documents

6.1 General

In countries where the use of products made of dezincification resistant materials is not required, the dezincification resistant products according to EN ISO 6509, as well as the products which do not contain zinc, may be marked "DR".

In countries where the use of dezincification resistant materials is required, the dezincification resistant products, as well as the products which do not contain zinc, shall be marked "DR".

6.2 Marking

The devices shall be marked permanently and visibly on the casing, or on a fixed data plate.

This information shall be on the upper side, or on each lateral side of the device. The indications shall be indelible and obtained by moulding, engraving or similar procedures.

The marking shall indicate:

- a) name, manufacturer's brand or logo;
- b) arrow indicating normal direction of flow;
- c) nominal size (DN);
- d) acoustic group;

Marking a), b), c), are obligatory. In case there is no marking for d), the device shall be considered as not classified acoustically.

<https://standards.iteh.ai/catalog/standards/sist/5b04ad0c-0038-4bda-baf7-2c52c162bd77/sist-en-14452-2005>

6.3 Technical documents

Each package and/or each batch and/or each catalogue of the supplier/manufacturer shall contain technical product information which shall be written in a commonly spoken language of the country in which the product is sold.

It shall provide the following information:

- a) designation and purpose of the product;
- b) installation instructions;
- c) minimum installation height;
- d) (brand) name and address of supplier/manufacturer;
- e) instructions for maintenance, if any;
- f) spare part list, if any.