
Akustika - Laboratorijsko in terensko merjenje bočnega prenosa zvoka v zraku, udarnega zvoka in zvoka v gradbenih elementih servisne opreme med mejnimi prostori - 5. del: Učinkovitost sevanja gradbenih elementov (ISO/DIS 10848-5:2019)

Acoustics - Laboratory and field measurement of the flanking transmission for airborne, impact and building service equipment sound between adjoining rooms - Part 5: Radiation efficiencies of building elements (ISO/DIS 10848-5:2019)

Akustik - Messung der Flankenübertragung von Luftschall und Trittschall zwischen benachbarten Räumen im Prüfstand - Teil 5: Strahlungswirksamkeit von Bauelementen (ISO/DIS 10848-5:2019)

[SIST EN ISO 10848-5:2020](https://standards.iteh.ai/catalog/standards/sist/4aad5a30-8113-40f9-b6a9-877-0e85d040/sist-en-iso-10848-5-2020)

<https://standards.iteh.ai/catalog/standards/sist/4aad5a30-8113-40f9-b6a9-877-0e85d040/sist-en-iso-10848-5-2020>

Acoustique - Mesurage en laboratoire et sur site des transmissions latérales du bruit aérien, des bruits de choc et du bruit d'équipement technique de bâtiment entre des pièces adjacentes - Partie 5: Efficacité de rayonnement des éléments de construction (ISO/DIS 10848-5:2019)

Ta slovenski standard je istoveten z: prEN ISO 10848-5

ICS:

17.140.01	Akustična merjenja in blaženje hrupa na splošno	Acoustic measurements and noise abatement in general
91.120.20	Akustika v stavbah. Zvočna izolacija	Acoustics in building. Sound insulation

oSIST prEN ISO 10848-5:2019

en

DRAFT INTERNATIONAL STANDARD

ISO/DIS 10848-5

ISO/TC 43/SC 2

Secretariat: DIN

Voting begins on:
2019-10-15Voting terminates on:
2020-01-07

Acoustics — Laboratory and field measurement of the flanking transmission for airborne, impact and building service equipment sound between adjoining rooms —

Part 5:

Radiation efficiencies of building elements

ICS: 91.120.20

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 10848-5:2020

<https://standards.iteh.ai/catalog/standards/sist/4aad5a30-8113-40f9-b6a9-877c0e85d040/sist-en-iso-10848-5-2020>

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

This document is circulated as received from the committee secretariat.

ISO/CEN PARALLEL PROCESSING



Reference number
ISO/DIS 10848-5:2019(E)

© ISO 2019

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN ISO 10848-5:2020

<https://standards.iteh.ai/catalog/standards/sist/4aad5a30-8113-40f9-b6a9-877c0e85d040/sist-en-iso-10848-5-2020>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2019

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Instrumentation	4
5 Test arrangement	5
6 Measurement methods	5
6.1 General.....	5
6.2 Measurement of $L_{\sigma,a}$	5
6.2.1 Generation of sound field in the source room.....	5
6.2.2 Measurement of the average sound pressure level in the receiving room.....	5
6.2.3 Measurement of reverberation time of the room and evaluation of the equivalent sound absorption area.....	5
6.2.4 Measurement of the average velocity level of the element.....	5
6.2.5 Calculation of the radiation index.....	5
6.3 Measurement of $L_{\sigma,s}$	6
6.3.1 Generation of vibration on the source element.....	6
6.3.2 Procedure for Type A and B elements.....	6
6.3.3 Measurement using stationary excitation.....	6
6.3.4 Measurement using transient excitation.....	6
6.3.5 Measurement of reverberation time and evaluation of the equivalent sound absorption area.....	6
6.3.6 Radiation index calculation.....	6
7 Precision	6
8 Expression of results	7
9 Test report	7
Annex A (informative) Measurement of radiation efficiency using sound intensity	8
Bibliography	10

ISO/DIS 10848-5:2019(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by ISO/TC 43, Subcommittee SC 2, *Building Acoustics*.

A list of all parts in the ISO 10848 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document describes the measurement of the radiation efficiency of an element using structure-borne and/or acoustical excitation. Both these radiation efficiencies are required to estimate the sound reduction index due to resonant transmission only, according to ISO 12354-1:2017, Annex B.

For Type B elements as defined in ISO 10848-1:2017 and ISO 12354-1:2017, the radiation efficiency of an element using structure-borne excitation is required to calculate flanking transmission. It is also required to estimate adaptation terms used in predicting service equipment sound according to ISO 12354-5:2009.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN ISO 10848-5:2020

<https://standards.iteh.ai/catalog/standards/sist/4aad5a30-8113-40f9-b6a9-877c0e85d040/sist-en-iso-10848-5-2020>

Acoustics — Laboratory and field measurement of the flanking transmission for airborne, impact and building service equipment sound between adjoining rooms —

Part 5: Radiation efficiencies of building elements

1 Scope

ISO 10848 (all parts) specifies laboratory and field measurement methods to characterize the flanking transmission of one or several building components.

This part of ISO 10848 specifies measurement methods to be performed in the laboratory to characterize the acoustic radiation of a building element when it is directly excited by an airborne or structure-borne source. It is applicable to single-leaf and double-leaf elements (see ISO 12354-1:2017 Annex F, F2). The measured quantity can be used as input data for prediction methods, such as ISO 12354-1 and ISO 12354-2, to compare products, or to express a requirement.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 10140-5, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 5: Requirements for test facilities and equipment*

ISO 10848-1:2017, *Acoustics — Laboratory and field measurement of flanking transmission for airborne, impact and building service equipment sound between adjoining rooms — Part 1: Frame document*

ISO 12999-1, *Acoustics — Determination and application of measurement uncertainties in building acoustics — Part 1: Sound insulation*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1 average velocity level L_v

ISO/DIS 10848-5:2019(E)

ten times the common logarithm of the ratio of the time and space averaged mean-square normal velocity of an element to the squared reference velocity according to [equation \(1\)](#)

$$L_v = 10 \lg \left(\frac{\frac{1}{T_m} \int_0^{T_m} v^2(t) dt}{v_0^2} \right) \quad (1)$$

where

v_0 is the reference velocity, in metres per second; $v_0 = 1 \times 10^{-9}$ m/s

T_m is the integration time, in seconds.

Note 1 to entry: This quantity is expressed in decibels.

Note 2 to entry: When considering sound radiation, using 5×10^{-8} m/s as a reference velocity leads to simpler equations; however, 10^{-9} m/s is the reference used in ISO 10848-1; hence this reference has also been used in this document. As a result, 34 dB has been added in [equation \(11\)](#), [\(12\)](#) and [\(A.3\)](#).

Note 3 to entry: If stationary airborne or structure-borne excitation is used, the spatial averaging is calculated according to [equation \(2\)](#)

$$L_v = 10 \lg \left(\frac{v_1^2 + v_2^2 + \dots + v_n^2}{n \cdot v_0^2} \right) \quad (2)$$

where

v_1, v_2, v_n are root mean square (rms) velocities at n different positions on the element, in metres per second.

3.2

average sound pressure level in a room

L_p

ten times the common logarithm of the ratio of the space and time average of the sound pressure squared to the square of the reference sound pressure, the space average being taken over the entire room with the exception of those parts where the direct radiation of a sound source or the near field of the boundaries (walls, etc.) is of significant influence

Note 1 to entry: This quantity is expressed in decibels.

Note 2 to entry: In the case of stationary airborne or structure-borne excitation and if a continuously moving microphone is used, L_p is determined according to [equation \(3\)](#)

$$L_p = 10 \lg \left(\frac{\frac{1}{T_m} \int_0^{T_m} p^2(t) dt}{p_0^2} \right) \quad (3)$$

where

p is the sound pressure, in pascals;

p_0 is the reference sound pressure, in pascals; $p_0 = 20 \mu\text{Pa}$;

T_m is the integration time, in seconds.

Note 3 to entry: In the case of stationary airborne or structure-borne excitation and if fixed microphone positions are used, L_p is determined according to [equation \(4\)](#)