

---

---

**Building acoustics — Estimation of  
acoustic performance of buildings  
from the performance of elements —**

**Part 3:  
Airborne sound insulation against  
outdoor sound**

*Acoustique du bâtiment — Calcul de la performance acoustique des  
bâtiments à partir de la performance des éléments —*

*Partie 3: Isolement aux bruits aériens venus de l'extérieur*

ISO 12354-3:2017

<https://standards.iteh.ai/catalog/standards/iso/ed11c305-afab-40d7-a5bd-27a018cb484c/iso-12354-3-2017>



iTeh Standards  
(<https://standards.iteh.ai>)  
Document Preview

ISO 12354-3:2017

<https://standards.iteh.ai/catalog/standards/iso/ed11c305-afab-40d7-a5bd-27a018cb484c/iso-12354-3-2017>



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2017, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Ch. de Blandonnet 8 • CP 401  
CH-1214 Vernier, Geneva, Switzerland  
Tel. +41 22 749 01 11  
Fax +41 22 749 09 47  
[copyright@iso.org](mailto:copyright@iso.org)  
[www.iso.org](http://www.iso.org)

# Contents

Page

<b>Foreword</b> .....	<b>iv</b>
<b>Introduction</b> .....	<b>v</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
3.1 Quantities to express building performance.....	1
3.2 Quantities to express element performance.....	3
3.3 Other terms and quantities.....	4
<b>4 Calculation models</b> .....	<b>5</b>
4.1 General principles.....	5
4.2 Determination of direct transmission from acoustic data on elements.....	7
4.2.1 General.....	7
4.2.2 Small technical elements.....	7
4.2.3 Other elements.....	7
4.3 Determination of flanking transmission.....	8
4.4 Limitations.....	8
<b>5 Accuracy</b> .....	<b>8</b>
<b>Annex A (normative) List of symbols</b> .....	<b>10</b>
<b>Annex B (informative) Determination of transmission by elements from composing parts</b> .....	<b>12</b>
<b>Annex C (informative) Influence of façade shape</b> .....	<b>15</b>
<b>Annex D (informative) Sound reduction index of elements</b> .....	<b>20</b>
<b>Annex E (informative) Estimation of indoor sound levels</b> .....	<b>23</b>
<b>Annex F (informative) Guidelines for practical use</b> .....	<b>25</b>
<b>Annex G (informative) Calculation examples</b> .....	<b>26</b>
<b>Bibliography</b> .....	<b>29</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by the European Committee for Standardization (CEN) Technical Committee CEN/TC 126, *Acoustic properties of building elements and of buildings*, in collaboration with ISO Technical Committee TC 43, *Acoustics*, SC 2, *Building acoustics*, in accordance with the agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This first edition cancels and replaces ISO 15712-3:2005, which has been technically revised.

A list of all the parts in the ISO 12354 series can be found on the ISO website.

## Introduction

This document is part of a series specifying calculation models in building acoustics.

Although this document covers the main types of building construction it cannot as yet cover all variations in the construction of buildings. It sets out an approach for gaining experience for future improvements and developments.

The accuracy of this standard can only be specified in detail after widespread comparisons with field data, which can only be gathered over a period of time after establishing the prediction model. To help the user in the meantime, indications of the accuracy have been given, based on earlier comparisons with comparable prediction models. It is the responsibility of the user (i.e. a person, an organization, the authorities) to address the consequences of the accuracy, inherent for all measurement and prediction methods, by specifying requirements for the input data and/or applying a safety margin to the results or applying some other correction.

It is intended for acoustical experts and provides the framework for the development of application documents and tools for other users in the field of building construction, taking into account local circumstances.

The model is based on experience with predictions for dwelling; it can also be used for other types of buildings provided the dimensions of constructions are not too different from those in dwellings.

**iTeh Standards**  
**(<https://standards.itih.ai>)**  
**Document Preview**

[ISO 12354-3:2017](https://standards.itih.ai/catalog/standards/iso/ed11c305-afab-40d7-a5bd-27a018cb484c/iso-12354-3-2017)

<https://standards.itih.ai/catalog/standards/iso/ed11c305-afab-40d7-a5bd-27a018cb484c/iso-12354-3-2017>



# Building acoustics — Estimation of acoustic performance of buildings from the performance of elements —

## Part 3: Airborne sound insulation against outdoor sound

### 1 Scope

This document specifies a calculation model to estimate the sound insulation or the sound pressure level difference of a façade or other external surface of a building. The calculation is based on the sound reduction index of the different elements from which the façade is constructed and it includes direct and flanking transmission. The calculation gives results which correspond approximately to the results from field measurements in accordance with ISO 16283-3. Calculations can be carried out for frequency bands or for single number ratings.

The calculation results can also be used for calculating the indoor sound pressure level due to for instance road traffic (see [Annex E](#)).

This document describes the principles of the calculation model, lists the relevant quantities and defines its applications and restrictions.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 717-1, *Acoustics — Rating of sound insulation in buildings and of building elements — Part 1: Airborne sound insulation*

ISO 10140-1:2016, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 1: Application rules for specific products*

ISO 12354-1:2017, *Building acoustics — Estimation of acoustic performance of buildings from the performance of elements — Part: Airborne sound insulation between rooms (in revision)*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions, and the symbols and units listed in [Annex A](#), apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

#### 3.1 Quantities to express building performance

NOTE The sound insulation of façades in accordance with ISO 16283-3 can be expressed in several quantities. These quantities are determined in frequency bands (one-third-octave bands or octave bands) from which the single number rating for the building performance can be obtained in accordance with ISO 717-1, for instance  $R'_{w}$ ,  $D_{ls,2m,nT,w}$  or  $(R'_{w} + C_{tr})$ .

### 3.1.1

#### apparent sound reduction index

$R'_{45^\circ}$

<loudspeaker> airborne sound insulation of a building element when the sound source is a loudspeaker and the angle of incidence is  $45^\circ$ , which is evaluated from

$$R'_{45^\circ} = L_{1,s} - L_2 + \left( 10 \lg \left( \frac{S}{A} \right) \right) - 1,5 \text{ dB}$$

where

$L_{1,s}$  is the average sound pressure level on the outside surface of the building element including the reflecting effects from the façade, in decibels;

$L_2$  is the average sound pressure level in the receiving room, in decibels;

$S$  is the area of the building element, in square metres;

$A$  is the equivalent sound absorption area in the receiving room, in square metres.

### 3.1.2

#### apparent sound reduction index

$R'_{tr,s}$

<traffic noise> airborne sound insulation of a building element when the sound source is traffic noise, which is evaluated from

$$R'_{tr,s} = L_{eq,1,s} - L_{eq,2} + \left( 10 \lg \left( \frac{S}{A} \right) \right) - 3 \text{ dB}$$

where

$L_{eq,1,s}$  is the average equivalent sound pressure level on the outside surface of the building element including the reflecting effects from the façade, in decibels;

$L_{eq,2}$  is the average equivalent sound pressure level in the receiving room, in decibels.

### 3.1.3

#### standardized level difference

$D_{2m,nT}$

difference between the outdoor sound pressure level at 2 m in front of the façade and the sound pressure level in the receiving room, corresponding to a reference value of the reverberation time, which is evaluated from

$$D_{2m,nT} = L_{1,2m} - L_2 + \left( 10 \lg \left( \frac{T}{T_0} \right) \right) \text{ dB}$$

where

$L_{1,2m}$  is the average sound pressure level at 2 m in front of the façade including the reflecting effects from the façade, in decibels;

$T$  is the reverberation time in the receiving room, in seconds;

$L_2$  is the average sound pressure level in the receiving room, in decibels;

$T_0$  is the reference reverberation time, in seconds; for dwellings given as 0,5 s.



Note 1 to entry: The standardized level difference can be determined either with the prevailing traffic noise or with noise from a loudspeaker. This is indicated by adding the subscript “tr” and “ls” respectively, i.e.  $D_{tr,2m,nT}$  or  $D_{ls,2m,nT}$ .

### 3.1.4

#### normalized level difference

$D_{2m,n}$

difference between the outdoor sound pressure level at 2 m in front of the façade and the sound pressure level in the receiving room, corresponding to a reference value of absorption area, which is evaluated from

$$D_{2m,n} = L_{1,2m} - L_2 - \left( 10 \lg \left( \frac{A}{A_0} \right) \right) \text{dB}$$

where  $A_0$  is the reference equivalent sound absorption area, in square metres for dwellings given as 10 m<sup>2</sup>.

Note 1 to entry: The normalized level difference can be determined either with the prevailing traffic noise or with noise from a loudspeaker. This is indicated by adding the subscript “tr” and “ls” respectively, i.e.  $D_{tr,2m,n}$  or  $D_{ls,2m,n}$ .

## 3.2 Quantities to express element performance

NOTE 1 The quantities expressing the performance of elements are used as part of the input data to estimate building performance. These quantities are determined in one-third-octave bands and can be expressed in octave bands as well. In relevant cases a single number rating for the element performance can be obtained from this, in accordance with ISO 717-1, for instance  $R_w(C;C_{tr})$  and  $D_{n,e,w}(C;C_{tr})$ .

NOTE 2 For the calculations, additional information on constructions could be necessary; for example, the shape of the façade (see [Annex C](#)), the total façade area (see 4.3.1), etc.

### 3.2.1

#### sound reduction index

$R$

ten times the common logarithm of the ratio of the sound power  $W_1$  incident on a test specimen to the sound power  $W_2$  transmitted through the specimen, which is evaluated from

$$R = \left( 10 \lg \frac{W_1}{W_2} \right) \text{dB}$$

Note 1 to entry: This quantity shall be determined in accordance with ISO 10140-1:2016, Annexes A, B, C and D.

### 3.2.2

#### element normalized level difference

$D_{n,e}$

difference in the space and time average sound pressure level produced in two rooms by a source in one room, where sound transmission is only due to a small technical element (e.g. transfer air devices, electrical cable ducts, transit sealing systems), which is evaluated from

$$D_{n,e} = L_1 - L_2 - \left( 10 \lg \left( \frac{A}{A_0} \right) \right) \text{dB}$$

where  $A$  is the equivalent sound absorption area in the receiving room, in square metres.

Note 1 to entry:  $D_{n,e}$  is normalized to the reference equivalent sound absorption area ( $A_0$ ) in the receiving room;  $A_0 = 10 \text{ m}^2$ .

Note 2 to entry: This quantity shall be determined in accordance with ISO 10140-1:2016, Annex E.

### 3.2.3

#### sound reduction improvement index

$\Delta R$

difference in sound reduction index between a basic structural element with an additional layer (e.g. a resilient wall skin, a suspended ceiling, a floating floor) and the basic structural element without this layer

Note 1 to entry: For direct transmission, this quantity shall be determined in accordance with ISO 10140-1:2016, Annex G.

Note 2 to entry: ISO 12354-1:2017, Annex D gives information on the determination and the use of this quantity.

### 3.2.4

#### sound reduction index of joints or slits

$R_s$

difference in the space and time average sound pressure level produced in two rooms by a source in one room, where sound transmission is only through the joint or the slit, which is evaluated from

$$R_s = L_1 - L_2 + \left( 10 \lg \left( \frac{S_o \cdot l}{A \cdot l_o} \right) \right)$$

Note 1 to entry:  $R_s$  is normalized to the length  $l$  of the joint or slit and the equivalent sound absorption area  $A$  in the receiving room, with  $S_o = 1 \text{ m}^2$  and  $l_o = 1 \text{ m}$ .

Note 2 to entry: This quantity shall be determined in accordance with ISO 10140-1:2016, Annex J.

## 3.3 Other terms and quantities

### 3.3.1

#### sound reduction index of façade for diffuse incident sound field

$R'$

sound reduction index of the façade as it hypothetically can be measured with a diffuse incident sound field in the actual field situation

Note 1 to entry: This quantity is used as a common calculation quantity from which the various quantities for the building performance can be obtained.

Note 2 to entry: In some countries the building performance is not expressed in one of the measurable quantities, but in this quantity  $R'$ .

### 3.3.2

#### façade shape level difference

$\Delta L_{fs}$

difference between the sound level of the incident sound,  $L_{1,in}$ , on a shaped façade and the sound level on the surface of the façade plane,  $L_{1,s}$ , plus 6 dB, which can be determined according to

$$\Delta L_{fs} = L_{1,in} - L_{1,s} + 6 \text{ dB}$$

where

$L_{1,in}$  is the average sound pressure level at the position of the façade plane, without the façade being present, in decibels;

$L_{1,s}$  is the average sound pressure level on the outside surface of the actual façade plane, in decibels.

Note 1 to entry: Information on the façade shape level difference and the method to determine its values is given in [Annex C](#).

## 4 Calculation models

### 4.1 General principles

“Façade” is understood to mean the whole outer surface of a room. The façade can consist of different elements, e.g. window, door, wall, roof, ventilation equipment; the sound transmission through the façade is due to the sound transmission by each of these elements. It is assumed that the transmission for each element is independent from the transmission of the other elements. The different types of exterior sound fields used in the various measurement situations defined for the determination of the quantities to express the building performance lead to different values. However, it is a reasonably proven assumption that the transmission for a diffuse incident sound field is sufficiently representative for these varying types of exterior sound fields. Therefore, the apparent sound reduction index of the façade for diffuse incident sound is calculated, from which all other quantities are deduced.

The apparent sound reduction index  $R'$  of the façade for diffuse incident sound is calculated by adding the sound power directly transmitted by each of the elements and the sound power transmitted by flanking transmission. As shown by [Formula \(1\)](#):

$$R' = \left( -10 \lg \left( \sum_{i=1}^n \tau_{e,i} + \sum_{f=1}^m \tau_f \right) \right) \text{dB} \quad (1)$$

where

$\tau_{e,i}$  is the sound power ratio of radiated sound power by a façade element  $i$  due to direct transmission of incident sound on this element, relative to incident sound power on the total façade;

$\tau_f$  is the sound power ratio of radiated sound power by a façade or flanking element  $f$  in the receiving room due to flanking transmission, relative to incident sound power on the total façade;

$n$  is the number of façade elements for direct transmission;

$m$  is the number of flanking façade elements.

NOTE 1 The sound power ratio  $\tau_e$  indicates directly the contribution of the element to the total sound transmission; for this purpose  $R_p = -10 \lg \tau_e$  could be designated as the partial sound reduction index.

NOTE 2 For direct transmission only, [Formulae \(7\) and \(8\)](#) could be integrated in [Formula \(1\)](#), resulting in the often used expression for the sound reduction index of composed elements.

For direct transmission the sound power ratio  $\tau_e$  can be determined for each façade element directly from the acoustic data on that element, including the contribution of each composing part; see [4.2](#). Alternatively this sound power ratio for one or more elements could be estimated from acoustic data on each of the composing parts of that element; see [Annex B](#). The choice depends on regulations and the available acoustic data. Guidelines for the practical use of the model are given in [Annex F](#).

For flanking transmission the sound power ratio  $\tau_f$  can be determined according to [4.3](#).

The apparent sound reduction index of the façade is determined from [Formulae \(2\) and \(3\)](#):

$$R'_{45^\circ} = R' + 1 \text{ dB} \quad (2)$$

$$R'_{tr,s} = R' \text{ dB} \quad (3)$$

NOTE 3 These equations represent the average relation between the quantities. For the single number rating the variation around the average is typically  $\pm 1$  dB. For frequency bands the spread is typically  $\pm 2$  dB for façades composed from various elements. However, in special cases, e.g. where the transmission is completely dominated by single glass panes, the difference between the two quantities at frequencies around and above the coincidence frequency is less systematic and can be much larger.