
**Akustika - Laboratorijsko merjenje zvočne izolirnosti gradbenih elementov - 2. del:
Merjenje izolirnosti pred zvokom v zraku (ISO/DIS 10140-2:2020)**

Acoustics - Laboratory measurement of sound insulation of building elements - Part 2:
Measurement of airborne sound insulation (ISO/DIS 10140-2:2020)

Akustik - Messung der Schalldämmung von Bauteilen im Prüfstand - Teil 2: Messung der
Luftschalldämmung (ISO/DIS 10140-2:2020)

Acoustique - Mesurage en laboratoire de l'isolation acoustique des éléments de
construction - Partie 2: Mesurage de l'isolation au bruit aérien (ISO/DIS 10140-2:2020)

<https://standards.iteh.ai/catalog/standards/sist/f5a6adfd-f868-4188-962a-50d5149d81d3/osist-pr-en-iso-10140-2-2020>

Ta slovenski standard je istoveten z: prEN ISO 10140-2

ICS:

17.140.01	Akustična merjenja in blaženje hrupa na splošno	Acoustic measurements and noise abatement in general
91.060.01	Stavbni elementi na splošno	Elements of buildings in general
91.120.20	Akustika v stavbah. Zvočna izolacija	Acoustics in building. Sound insulation

oSIST prEN ISO 10140-2:2020

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN ISO 10140-2:2020](https://standards.iteh.ai/catalog/standards/sist/f5a6adfd-f868-4188-962a-50d5d49d81d3/osist-pren-iso-10140-2-2020)

<https://standards.iteh.ai/catalog/standards/sist/f5a6adfd-f868-4188-962a-50d5d49d81d3/osist-pren-iso-10140-2-2020>

DRAFT INTERNATIONAL STANDARD

ISO/DIS 10140-2

ISO/TC 43/SC 2

Secretariat: DIN

Voting begins on:
2020-06-19Voting terminates on:
2020-09-11

Acoustics — Laboratory measurement of sound insulation of building elements —

Part 2: Measurement of airborne sound insulation

*Acoustique — Mesurage en laboratoire de l'isolation acoustique des éléments de construction —
Partie 2: Mesurage de l'isolation au bruit aérien*

ICS: 91.120.20

iTeh STANDARD PREVIEW (standards.iteh.ai)

<https://standards.iteh.ai/catalog/standards/sist/f5a6adfd-f868-4188-962a-50d5d49d81d3/osist-pren-iso-10140-2-2020>

THIS DOCUMENT IS A DRAFT CIRCULATED FOR COMMENT AND APPROVAL. IT IS THEREFORE SUBJECT TO CHANGE AND MAY NOT BE REFERRED TO AS AN INTERNATIONAL STANDARD UNTIL PUBLISHED AS SUCH.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

This document is circulated as received from the committee secretariat.

ISO/CEN PARALLEL PROCESSING



Reference number
ISO/DIS 10140-2:2020(E)

© ISO 2020

iTeh STANDARD PREVIEW (standards.iteh.ai)

<https://standards.iteh.ai/catalog/standards/sist/f5a6adfd-f868-4188-962a-50d5d49d81d3/osist-pren-iso-10140-2-2020>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Facilities and equipment	3
5 Test procedure and evaluation	3
5.1 General procedure.....	3
5.2 Sound field in the source room.....	4
5.3 Data processing.....	4
5.4 Expression of results.....	4
6 Test arrangement	5
6.1 General.....	5
6.2 Full-size test opening.....	5
6.3 Reduced-size test opening.....	6
6.4 Reduced-size test elements.....	6
6.5 Small technical elements.....	6
7 Limits of performance	7
7.1 Full-size openings.....	7
7.2 Reduced-size openings.....	7
8 Measurement uncertainty	8
9 Test report	8
Annex A (normative) Measurement of sound transmission through the filler wall and any flanking construction for small-sized or reduced-size test openings	10
Annex B (informative) Form for the expression of results	12
Bibliography	14

ISO/DIS 10140-2:2020(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*.

<https://standards.iteh.ai/catalog/standards/sist/f5a6adfd-f868-4188-962a-563310f11c36/iso-10140-2-2020>

This second edition cancels and replaces the first edition (ISO 10140-2:2010), which has been technically revised.

The main changes compared to the previous edition are as follows:

- normative references updated
- terms and definitions updated
- all references updated
- title of [Clause 8](#) changed to “Measurement uncertainty”

A list of all parts in the ISO 10140 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

ISO 10140 (all parts) concerns laboratory measurement of the sound insulation of building elements (see [Table 1](#)).

ISO 10140-1 specifies the application rules for specific elements and products, including specific requirements for preparation, mounting, operating and test conditions. This part of ISO 10140 and ISO 10140-3 contain the general procedures for airborne and impact sound insulation measurements, respectively, and refer to ISO 10140-4 and ISO 10140-5 where appropriate. For elements and products without a specific application rule described in ISO 10140-1, it is possible to apply this part of ISO 10140 and ISO 10140-3. ISO 10140-4 contains basic measurement techniques and processes. ISO 10140-5 contains requirements for test facilities and equipment. For the structure of ISO 10140 (all parts), see [Table 1](#).

ISO 10140 (all parts) was created to improve the layout for laboratory measurements, ensure consistency and simplify future changes and additions regarding mounting conditions of test elements in laboratory and field measurements. It is intended for ISO 10140 (all parts) to present a well-written and arranged format for laboratory measurements.

It is intended to update ISO 10140-1 with application rules for other products.

Table 1 — Structure and contents of ISO 10140 (all parts)

Relevant part of ISO 10140	Main purpose, contents and use	Detailed content
ISO 10140-1	It indicates the appropriate test procedure for elements and products. For certain types of element/product, it can contain additional and more specific instructions about quantities and test element size and about preparation, mounting and operating conditions. Where no specific details are included, the general guidelines are according to ISO 10140-2 and ISO 10140-3.	Appropriate references to ISO 10140-2 and ISO 10140-3 and product-related, specific and additional instructions on: <ul style="list-style-type: none"> — specific quantities measured; — size of test element; — boundary and mounting conditions; — conditioning, testing and operating conditions; — additional specifics for test report.
ISO 10140-2	It gives a complete procedure for airborne sound insulation measurements according to ISO 10140-4 and ISO 10140-5. For products without specific application rules, it is sufficiently complete and general for the execution of measurements. However, for products with specific application rules, measurements are carried out according to ISO 10140-1, if available.	<ul style="list-style-type: none"> — Definitions of main quantities measured — General mounting and boundary conditions — General measurement procedure — Data processing — Test report (general points)
ISO 10140-3	It gives a complete procedure for impact sound insulation measurements according to ISO 10140-4 and ISO 10140-5. For products without specific application rules, it is sufficiently complete and general for the execution of measurements. However, for products with specific application rules, measurements are carried out according to ISO 10140-1, if available.	<ul style="list-style-type: none"> — Definitions of main quantities measured — General mounting and boundary conditions — General measurement procedure — Data processing — Test report (general points)

ISO/DIS 10140-2:2020(E)

Table 1 (continued)

Relevant part of ISO 10140	Main purpose, contents and use	Detailed content
ISO 10140-4	It gives all the basic measurement techniques and processes for measurement according to ISO 10140-2 and ISO 10140-3 or facility qualifications according to ISO 10140-5. Much of the content is implemented in software.	<ul style="list-style-type: none"> — Definitions — Frequency range — Microphone positions — SPL measurements — Averaging, space and time — Correction for background noise — Reverberation time measurements — Loss factor measurements — Low-frequency measurements — Radiated sound power by velocity measurement
ISO 10140-5	It specifies all information needed to design, construct and qualify the laboratory facility, its additional accessories and measurement equipment (hardware).	<p>Test facilities, design criteria:</p> <ul style="list-style-type: none"> — volumes, dimensions; — flanking transmission; — laboratory loss factor; — maximum achievable sound reduction index; — reverberation time; <p>influence of lack of diffusivity in the laboratory.</p> <p>Test openings:</p> <ul style="list-style-type: none"> — standard openings for walls and floors; — other openings (windows, doors, small technical elements); — filler walls in general. <p>Requirements for equipment:</p> <ul style="list-style-type: none"> — loudspeakers, number, positions; — tapping machine and other impact sources; — measurement equipment. <p>Reference constructions:</p> <ul style="list-style-type: none"> — basic elements for airborne and impact insulation improvement; — corresponding reference performance curves.

Acoustics — Laboratory measurement of sound insulation of building elements —

Part 2: Measurement of airborne sound insulation

1 Scope

This part of ISO 10140 specifies a laboratory method for measuring the airborne sound insulation of building products, such as walls, floors, doors, windows, shutters, façade elements, façades, glazing, small technical elements, for instance transfer air devices, airing panels (ventilation panels), outdoor air intakes, electrical raceways, transit sealing systems and combinations, for example walls or floors with linings, suspended ceilings or floating floors.

The test results can be used to compare the sound insulation properties of building elements, classify elements according to their sound insulation capabilities, help design building products which require certain acoustic properties and estimate the *in situ* performance in complete buildings.

The measurements are performed in laboratory test facilities in which sound transmission via flanking paths is suppressed. The results of measurements made in accordance with this part of ISO 10140 are not applicable directly to the field situation without accounting for other factors affecting sound insulation, such as flanking transmission, boundary conditions and total loss factor.

2 Normative references

oSIST prEN ISO 10140-2:2020

standards.iteh.ai/catalog/standards/sist/f5a6adfd-f868-4188-962a-50d5d49d81d3/osist-pr-en-iso-10140-2-2020

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 12999-1, *Acoustics — Determination and application of measurement uncertainties in building acoustics — Part 1: Sound insulation*

ISO 717-1, *Acoustics — Rating of sound insulation in buildings and of building elements — Part 1: Airborne sound insulation*

ISO 10140-1, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 1: Application rules for specific products*

ISO/DIS 10140-4:2020, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 4: Measurement procedures and requirements*

ISO 10140-5, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 5: Requirements for test facilities and equipment*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

ISO/DIS 10140-2:2020(E)

3.1 sound reduction index

R

ten times the common logarithm of the ratio of the sound power, W_1 , that is incident on the test element to the sound power, W_2 , radiated by the test element to the other side

$$R = 10 \lg \frac{W_1}{W_2} \quad (1)$$

Note 1 to entry: R is expressed in decibels.

For laboratory measurements using sound pressure, the sound reduction index is calculated using:

$$R = L_1 - L_2 + 10 \lg \frac{S}{A} \quad (2)$$

where

L_1 is the energy average sound pressure level in the source room, in decibels;

L_2 is the energy average sound pressure level in the receiving room, in decibels;

S is the area of the free test opening in which the test element is installed, in square metres;

A is the equivalent sound absorption area in the receiving room, in square metres.

Note 2 to entry: The derivation of Equation (2) from Equation (1) assumes that the sound fields are diffuse and that the only sound radiated into the receiving room is from the test element.

Note 3 to entry: The expression "sound transmission loss" (TL) is also in use in English-speaking countries. It is equivalent to "sound reduction index".

Note 4 to entry: Related quantities can be introduced in other documents or test codes, often by adding subscripts, i.e. R_1 for the sound reduction index as measured by intensity methods, R_s as the sound reduction index per unit length of slits or ΔR as the improvement in sound reduction index by linings or suspended ceilings.

3.2 apparent sound reduction index

R'

ten times the common logarithm of the ratio of the sound power, W_1 , that is incident on a test element to the total sound power radiated into the receiving room if, in addition to the sound power, W_2 , radiated by the test element, the sound power, W_3 , radiated by flanking elements or by other components is significant

$$R' = 10 \lg \left(\frac{W_1}{W_2 + W_3} \right) \quad (3)$$

Note 1 to entry: R' is expressed in decibels.

Note 2 to entry: In general, the sound power transmitted into the receiving room consists of the sum of several components. Also, in this case, under the assumption that there are diffuse sound fields in the two rooms, the apparent sound reduction index is evaluated from Equation (4).

$$R' = L_1 - L_2 + 10 \lg \frac{S}{A} \quad (4)$$

Thus, in the apparent sound reduction index, the sound power transmitted into the receiving room is related to the sound power that is incident on the test element, as in Equation (2), irrespective of the actual conditions of transmission.

3.3 element-normalized level difference

$D_{n,e}$
level difference corresponding to a reference value of absorption area in the receiving room with sound transmission through the small technical element only; this level difference is evaluated from [Equation \(5\)](#)

$$D_{n,e} = L_1 - L_2 + 10 \lg \left(\frac{A_0}{A} \right) \quad (5)$$

where

- L_1 is the energy average sound pressure level in the source room, in decibels;
- L_2 is the energy average sound pressure level in the receiving room, in decibels;
- A_0 is the reference absorption area, in square metres (for the laboratory, $A_0 = 10 \text{ m}^2$);
- A is the equivalent absorption area in the receiving room, in square metres.

Note 1 to entry: $D_{n,e}$ is expressed in decibels.

Note 2 to entry: To achieve a better signal-to-noise ratio, simultaneous measurements can be performed on more than one element. When performing simultaneous measurements, replace [Equation \(5\)](#) by [Equation \(6\)](#).

$$D_{n,e} = L_1 - L_2 + 10 \lg \left(\frac{nA_0}{A} \right) \quad (6)$$

where

- $D_{n,e}$ is the element-normalized level difference of an individual element;
- n is the number of installed elements.

3.4 small technical element

building element, excluding windows and doors, with an area of less than 1 m^2 , which occurs in a certain number of discrete sizes and transmits sound between two adjacent rooms or between one room and the outdoors independently of any adjoining building elements

4 Facilities and equipment

Laboratory test facilities shall comply with the requirements given in ISO 10140-5.

The equipment used to generate the sound field shall meet the requirements given in ISO 10140-5.

Requirements for the equipment used to measure the sound level, and for calibration of that equipment, are given in ISO 10140-5.

5 Test procedure and evaluation

5.1 General procedure

Two horizontally or vertically adjacent rooms are used, one being designated the source room and the other the receiving room. The test element is mounted in an opening in the partition between those rooms (see [Clause 6](#)). In the source room, a diffuse sound field is generated by a moving loudspeaker or loudspeakers at two or more fixed positions. The average sound pressure levels are measured in the source and receiving rooms, normally in the frequency range of 100 Hz to 5 000 Hz (optionally