



# SLOVENSKI STANDARD

## SIST EN 54-13:2017+A1:2020

01-februar-2020

Nadomešča:  
SIST EN 54-13:2017

---

### Sistemi za odkrivanje in javljanje požara ter alarmiranje - 13. del: Ocenjevanje združljivosti in povezljivosti sestavnih delov sistemov

Fire detection and fire alarm systems - Part 13: Compatibility and connectability assessment of system components

Brandmeldeanlagen - Teil 13: Bewertung der Kompatibilität und Anschließbarkeit von Systembestandteilen

(standards.iteh.ai)

Systèmes de détection incendie - Partie 13: Évaluation de la compatibilité et de l'aptitude au raccordement des composants d'un système

<https://standards.iteh.ai/catalog/standards/sist/ede272eb-9883-4e0b-858d-6e305588630b/sist-en-54-13-2017a1-2020>

Ta slovenski standard je istoveten z: EN 54-13:2017+A1:2019

---

#### **ICS:**

|           |                               |                           |
|-----------|-------------------------------|---------------------------|
| 13.220.20 | Požarna zaščita               | Fire protection           |
| 13.320    | Alarmni in opozorilni sistemi | Alarm and warning systems |

**SIST EN 54-13:2017+A1:2020** en,fr,de

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 54-13:2017+A1:2020](https://standards.iteh.ai/catalog/standards/sist/ede272eb-9883-4e0b-858d-6e305588630b/sist-en-54-13-2017a1-2020)

<https://standards.iteh.ai/catalog/standards/sist/ede272eb-9883-4e0b-858d-6e305588630b/sist-en-54-13-2017a1-2020>

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN 54-13:2017+A1**

December 2019

ICS 13.220.20

Supersedes EN 54-13:2017

English Version

## Fire detection and fire alarm systems - Part 13: Compatibility and connectability assessment of system components

Systèmes de détection incendie - Partie 13: Évaluation  
de la compatibilité et de l'aptitude au raccordement  
des composants d'un système

Brandmeldeanlagen - Teil 13: Bewertung der  
Kompatibilität und Anschließbarkeit von  
Systembestandteilen

This European Standard was approved by CEN on 14 November 2016 and includes Amendment approved by CEN on 2 October 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

| <b>Contents</b>  | <b>Page</b> |
|--|-------------|
| European foreword.....   | 4           |
| Introduction .....   | 7           |
| <b>1 Scope .....</b>   | <b>8</b>    |
| <b>2 Normative references .....</b>  | <b>8</b>    |
| <b>3 Terms, definitions and abbreviations .....</b>                              | <b>9</b>    |
| <b>3.1 Terms and definitions .....</b>   | <b>9</b>    |
| <b>3.2 Abbreviations .....</b>   | <b>10</b>   |
| <b>4 Requirements .....</b>  | <b>10</b>   |
| <b>4.1 Compliance .....</b>  | <b>10</b>   |
| <b>4.2 Basic requirements .....</b>  | <b>11</b>   |
| <b>4.3 Transmission path(s) .....</b>  | <b>11</b>   |
| <b>4.3.1 General.....</b>  | <b>11</b>   |
| <b>4.3.2 TP using wires .....</b>  | <b>12</b>   |
| <b>4.3.3 TP using radio frequency link .....</b>                                 | <b>12</b>   |
| <b>4.3.4 TP using optical fibre.....</b>   | <b>12</b>   |
| <b>4.3.5 Network TP.....</b>   | <b>12</b>   |
| <b>4.4 Documentation.....</b>  | <b>13</b>   |
| <b>4.4.1 General.....</b>  | <b>13</b>   |
| <b>4.4.2 Documentation for compatibility.....</b>                                | <b>13</b>   |
| <b>4.4.3 Documentation for connectability.....</b>                               | <b>13</b>   |
| <b>4.4.4 Software documentation.....</b>   | <b>14</b>   |
| <b>5 Assessment methods and tests.....</b>                                       | <b>14</b>   |
| <b>5.1 General.....</b>  | <b>14</b>   |
| <b>5.2 Provision of equipment and supporting information and tools .....</b>     | <b>14</b>   |
| <b>5.3 Configuration.....</b>  | <b>15</b>   |
| <b>5.3.1 General.....</b>  | <b>15</b>   |
| <b>5.3.2 Configuration at field level for assessment .....</b>                   | <b>15</b>   |
| <b>5.3.3 Configuration at control level for network assessment.....</b>          | <b>16</b>   |
| <b>5.4 Standard atmospheric conditions for testing .....</b>                     | <b>16</b>   |
| <b>5.5 Functional test for compatibility assessment on field level .....</b>     | <b>16</b>   |
| <b>5.5.1 The objective of the test.....</b>                                      | <b>16</b>   |
| <b>5.5.2 Test schedule .....</b>   | <b>16</b>   |
| <b>5.5.3 Functional tests for compatibility in the different conditions.....</b> | <b>17</b>   |
| <b>5.6 Functional tests for connectability assessment on field level .....</b>   | <b>21</b>   |
| <b>5.6.1 The objective of the test.....</b>                                      | <b>21</b>   |
| <b>5.6.2 Test schedule .....</b>   | <b>21</b>   |
| <b>5.6.3 Functional test for connectability .....</b>                            | <b>21</b>   |
| <b>Annex A (informative) Example of levels used in FDAS .....</b>                | <b>22</b>   |
| <b>Annex B (informative) Classification of functions of the FDAS.....</b>        | <b>23</b>   |
| <b>B.1 General.....</b>  | <b>23</b>   |
| <b>B.2 Fire detection function.....</b>  | <b>23</b>   |
| <b>B.3 Fire alarm to occupants in the premises .....</b>                         | <b>23</b>   |

|             |   |           |
|-------------|---|-----------|
| <b>B.4</b>  | <b>Fire alarm to summon external assistance (usually the fire brigade) .....</b>              | <b>23</b> |
| <b>B.5</b>  | <b>Activation of fire protection function.....</b>  | <b>23</b> |
| <b>B.6</b>  | <b>Remote indication 1 (remote panels, fire brigade panels, etc.).....</b>                    | <b>23</b> |
| <b>B.7</b>  | <b>Remote indication 2 (printers, interface to building management system, etc.).....</b>     | <b>24</b> |
| <b>B.8</b>  | <b>Input function .....</b>   | <b>24</b> |
| <b>B.9</b>  | <b>Output function .....</b>  | <b>24</b> |
| <b>B.10</b> | <b>Devices used to connect transmission paths (gateway, data switch, etc.) .....</b>          | <b>24</b> |
|             | <b>Annex C (informative) Example methodology for theoretical analysis .....</b>               | <b>25</b> |
| <b>C.1</b>  | <b>Introduction.....</b>  | <b>25</b> |
| <b>C.2</b>  | <b>Method of test .....</b>   | <b>25</b> |
|             | <b>Annex D (normative) Software design documentation.....</b>                                 | <b>28</b> |
|             | <b>Annex E (informative) Flowchart for assessment of compatibility / connectability .....</b> | <b>30</b> |

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 54-13:2017+A1:2020](https://standards.iteh.ai/catalog/standards/sist/ede272eb-9883-4e0b-858d-6e305588630b/sist-en-54-13-2017a1-2020)

<https://standards.iteh.ai/catalog/standards/sist/ede272eb-9883-4e0b-858d-6e305588630b/sist-en-54-13-2017a1-2020>

**EN 54-13:2017+A1:2019 (E)****European foreword**

This document (EN 54-13:2017+A1:2019) has been prepared by Technical Committee CEN/TC 72 “Fire detection and fire alarm system”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2020, and conflicting national standards shall be withdrawn at the latest by June 2020.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1 approved by CEN on 2 October 2019.

This document supersedes **A1** EN 54-13:2017 **A1**.

The start and finish of text introduced or altered by amendment is indicated in the text by tags **A1** **A1**.

EN 54-13 has been revised to update the standard by taking into account new techniques of communication and new technologies available on the market.

It includes new clauses and annexes as follows:

- Clause 4.3 Transmission paths **(standards.iteh.ai)**
- Annex A example of levels used in fire detection and alarm system
- Annex D software design documentation <https://standards.iteh.ai/catalog/standards/sist/ede272eb-9883-4e0b-858d-6e305588630b/sist-en-54-13-2017a1-2020>
- Annex E flowchart for assessment

The main technical modifications are the following:

- The standard is applicable to electrical wires, optical fibre or radio frequency connection.
- EN 54-1:2011 is taken into account and leads to delete the flowchart of functions.
- Introduction of levels (field, control and management) and network transmission path to consider new technique of configuration.
- Transfer of product requirements covering partial open and partial short circuits to an optional clause included in EN 54-2.

EN 54 is published in a series of parts. Information on the relationship between this document and other standards of the EN 54 series is given in Annex A of EN 54-1:2011.

EN 54, *Fire detection and fire alarm systems* consists of the following parts:

- *Part 1: Introduction*
- *Part 2: Control and indicating equipment*
- *Part 3: Fire alarm devices – Sounders*

- Part 4: Power supply equipment
- Part 5: Heat detectors – Point detectors
- Part 7: Smoke detectors – Point detectors using scattered light, transmitted light or ionization
- Part 10: Flame detectors – Point detectors
- Part 11: Manual call points
- Part 12: Smoke detectors – Line detectors using an optical beam
- Part 13: Compatibility assessment of system components
- Part 14: Guidelines for planning, design, installation, commissioning, use and maintenance
- Part 15: Point detectors using a combination of detected phenomena
- Part 16: Voice alarm control and indicating equipment
- Part 17: Short-circuit isolators
- Part 18: Input/output devices
- Part 20: Aspirating smoke detectors
- Part 21: Alarm transmission and fault warning routing equipment
- Part 22: Resettable line-type heat detectors
- Part 23: Fire alarm devices – Visual alarm devices
- Part 24: Components of voice alarm systems – Loudspeakers
- Part 25: Components using radio links
- Part 26: Carbon monoxide detectors – Point detectors
- Part 27: Duct smoke detectors
- Part 28: Non-resettable line-type heat detectors
- Part 29: Multi-sensor fire detectors - Point detectors using a combination of smoke and heat sensors
- Part 30: Multi-sensor fire detectors - Point detectors using a combination of carbon monoxide and heat sensors
- Part 31: Multi-sensor fire detectors – Point detectors using a combination of smoke, carbon monoxide and optionally heat sensors
- Part 32: Guidelines for the planning, design, installation, commissioning, use and maintenance of voice alarm systems

NOTE This list includes standards that are in preparation and other standards may be added. For current status of published standards refer to [www.cen.eu](http://www.cen.eu).

**EN 54-13:2017+A1:2019 (E)**

EN 54-1 provides additional information about the components performing the functions of a fire detection and fire alarm system.

EN 54-25 provides additional information and requirements about systems using radio frequency links.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## **iTeh STANDARD PREVIEW** **(standards.iteh.ai)**

[SIST EN 54-13:2017+A1:2020](https://standards.iteh.ai/catalog/standards/sist/ede272eb-9883-4e0b-858d-6e305588630b/sist-en-54-13-2017a1-2020)

<https://standards.iteh.ai/catalog/standards/sist/ede272eb-9883-4e0b-858d-6e305588630b/sist-en-54-13-2017a1-2020>



## Introduction

The fire detection function is to detect a fire at the earliest practicable moment, and to give signals and indications so that appropriate action can be taken.

The fire alarm function is to give, at least, audible and/or visible signals to the occupants of a building who may be at risk from fire.

A fire detection and fire alarm system (including voice alarm system) may combine the functions of detection and alarm in a single system, and typically consists of a number of inter-linked components including automatic fire detectors, manual call points and alarm devices. These components are connected to control and indicating equipment by means of one or more transmission paths. All system components, including the control and indicating equipment, are also directly or indirectly connected to a power supply.

A separate voice alarm system can be assessed for compatibility and connectability independently of the fire detection and alarm system.

A fire detection and fire alarm system may also be linked to remote fault and fire alarm monitoring stations, and to fire protection and/or building management systems. However these systems are not considered as part of the fire detection and fire alarm system.

It is necessary that all the components constituting the fire detection and fire alarm system are compatible or connectable, and that requirements relating to the performance of the overall system are fulfilled.

Differentiation is made between components classified as components type 1 and other components classified as components type 2. (standards.iteh.ai)

As the possible configurations of fire detection and fire alarm systems are unlimited, the assessment is only carried out on the configuration(s) declared by the applicant.

The intended use of this standard is to demonstrate the compatibility and connectability of components even if they are not defined by an EN 54 standard.

**EN 54-13:2017+A1:2019 (E)****1 Scope**

This European Standard specifies the requirements for compatibility and connectability assessment of components of fire detection and fire alarm systems (including voice alarm systems as a subsystem of fire detection and fire alarm system). The components conform to either with the requirements of EN 54 or with a manufacturer's specification where there is no EN 54 standard.

The requirements for the transmission path used for a distributed function are covered by the relevant EN 54 standard and not by this document.

This document also specifies requirements for the integrity of the fire detection and fire alarm system when connected to other systems.

This document does not specify the manner in which the system is designed, installed and used in any particular application.

This document recognizes that it is not practical to assess the compatibility or connectability of components in all possible configurations. Methods of assessment are specified to reach an acceptable degree of confidence within pre-determined operational and environmental conditions.

This document specifies requirements related to compatibility and connectability assessment methods and tests for the components belonging to FDAS or connecting FDAS.

This document does not cover components or functions which are not included in a FDAS like functions achieved by a building management system.

This document is applicable to systems where the components are interconnected by electrical wires or optical fibre or by radio frequency links or by any combination. For other interconnection technology between components this standard may be used as a guidance.

NOTE Other European Standards are expected to cover the requirements of the other systems which may be connected to the fire detection and fire alarm system.

**2 Normative references**

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50130-4, *Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems*

EN 50130-5, *Alarm systems - Part 5: Environmental test methods*

EN 60068-1, *Environmental testing - Part 1: General and guidance*

EN 54-1:2011, *Fire detection and fire alarm systems - Part 1: Introduction*

EN 54-2, *Fire detection and fire alarm systems - Part 2: Control and indicating equipment*

EN 54-4, *Fire detection and fire alarm systems - Part 4: Power supply equipment*

EN 54-16, *Fire detection and fire alarm systems - Part 16: Voice alarm control and indicating equipment*

EN 54-25, *Fire detection and fire alarm systems - Part 25: Components using radio links*

### 3 Terms, definitions and abbreviations

#### 3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 54-1, those given in each relevant part of EN 54 product standard and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

##### 3.1.1 configuration

topological arrangement of components connected through transmission paths to control and indicating equipment

##### 3.1.2 compatibility for component type 1

ability of a component type 1 to operate with other type 1 components of the FDAS:

- within the limits specified for each component given in the documentation;
- within the specified limits given by the relevant parts of EN 54, or given by the applicant; if no EN 54 part applies;
- within specified configurations of systems

##### 3.1.3 component type 1

device performing a function A, B, C, D, E, G, I, L, M for fire detection and fire alarm as defined in EN 54-1 or device performing another function declared as component type 1 by the applicant

Note 1 to entry: For example function N. See Annex B.

##### 3.1.4 component type 2

device other than type 1 and which is connected to a type 1 component

##### 3.1.5 connectability for component type 2

ability of component type 2 to operate without jeopardizing the performance of the fire detection and fire alarm system

##### 3.1.6 control level

level where control and indication functions are provided

Note 1 to entry: See drawing in Annex A.

Note 2 to entry: CIE and VACIE belong to that level.

##### 3.1.7 field level

level where detection, activation and fire alarm functions are provided

Note 1 to entry: See drawing in Annex A.

Note 2 to entry: Detectors, input / output devices and sounders and visual alarm devices belong to that level.

**EN 54-13:2017+A1:2019 (E)****3.1.8****management level**

level where management functions are provided (such as management stations)

Note 1 to entry: See drawing in Annex A

**3.1.9****network topology**

configuration of network including both the categories of node and interconnection of TP between them

**3.1.10****network node**

device with a unique network address

**3.1.11****networked CIE**

Networked CIE comprise more than one CIE (function B in EN 54-1) or more than one VACIE, (function M in EN 54-1) or a combination of both function B and M, which are interconnected on a fault tolerant transmission path which forms the network

**3.1.12****A1 applicant**

organization or other such body requiring an assessment of the compatibility and connectability of system components A1

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)

**3.2 Abbreviations**

|       |  |
|-------|--|
| FDAS  | Fire Detection and Fire Alarm System         |
| TP    | Transmission Path                            |
| CIE   | Control and Indicating Equipment             |
| VACIE | Voice Alarm Control and Indicating Equipment |
| VAS   | Voice Alarm System                           |
| PSE   | Power Supply Equipment                       |
| OEM   | Original Equipment Manufacturer              |

**4 Requirements****4.1 Compliance**

In order to conform to this standard, compatibility of the components type 1 or connectability of the components type 2 within the FDAS shall meet the requirements listed in Clause 4. This shall be verified by theoretical assessment (5.1) with reference to the required documentation (4.4). When this is an outcome of the theoretical assessment, configuration (s) according to (5.3) shall be tested as described using the relevant selection of functional tests defined in 5.5 and 5.6 and shall meet the criteria of acceptance of the tests.