

**SLOVENSKI STANDARD  
oSIST prEN 16583:2020**

**01-april-2020**

---

**Prenosniki toplote - Ventilatorski konvektorji voda/zrak - Ugotavljanje ravni zvočne moči**

Heat exchangers - Hydronic room fan coils units - Determination of the sound power level

Wärmeübertrager - Wasser-Luft-Ventilatorkonvektoren - Bestimmung des Schallleistungspegels

iTeh Standards

Échangeurs thermiques - Ventilo-convecteurs à eau - Détermination du niveau de puissance acoustique

Document Preview

**Ta slovenski standard je istoveten z:** prEN 16583

SIST EN 16583:2022

<https://standards.iteh.si/catalog/standards/iit/0-32-545-d62-41-8-724-280556306500/iit-en-16583-2022>

**ICS:**

27.060.30      Grelniki vode in prenosniki toplote      Boilers and heat exchangers

**oSIST prEN 16583:2020**

**en,fr,de**



**EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM**

**DRAFT  
prEN 16583**

March 2020

ICS

Will supersede EN 16583:2015

English Version

**Heat exchangers - Hydronic room fan coils units -  
Determination of the sound power level**

Échangeurs thermiques - Ventilo-conveuteurs à eau -  
Détermination du niveau de puissance acoustique

Wärmeübertrager - Wasser-Luft-  
Ventilatorkonvektoren - Bestimmung des  
Schallleistungspegels

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 113.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

**Document Preview**

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

**Warning :** This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

## Contents

	Page
<b>European foreword.....</b>	<b>3</b>
<b>1 Scope.....</b>	<b>4</b>
<b>2 Normative references.....</b>	<b>4</b>
<b>3 Terms and definitions .....</b>	<b>5</b>
<b>4 Measuring instruments.....</b>	<b>5</b>
<b>5 Operation of the unit.....</b>	<b>6</b>
<b>6 Installation .....</b>	<b>7</b>
<b>6.1 General.....</b>	<b>7</b>
<b>6.2 Non ducted units.....</b>	<b>7</b>
<b>6.2.1 General.....</b>	<b>7</b>
<b>6.2.2 Floor mounted unit.....</b>	<b>7</b>
<b>6.2.3 Wall mounted unit .....</b>	<b>8</b>
<b>6.2.4 High wall mounted unit .....</b>	<b>9</b>
<b>6.2.5 Cassette and under ceiling mounted units.....</b>	<b>10</b>
<b>6.2.6 Under floor mounted .....</b>	<b>10</b>
<b>6.3 Ducted units .....</b>	<b>10</b>
<b>6.3.1 General.....</b>	<b>10</b>
<b>6.3.2 Discharge or inlet sides.....</b>	<b>11</b>
<b>6.3.3 Sound level radiated by the casing .....</b>	<b>17</b>
<b>7 Acoustic measurement.....</b>	<b>18</b>
<b>7.1 Frequency range.....</b>	<b>18</b>
<b>7.2 Acoustic standard.....</b>	<b>18</b>
<b>7.3 Diffuse field .....</b>	<b>18</b>
<b>7.4 Free field.....</b>	<b>18</b>
<b>7.5 In-duct measurement.....</b>	<b>19</b>
<b>8 Uncertainty.....</b>	<b>19</b>
<b>9 Test report.....</b>	<b>19</b>
<b>9.1 General information.....</b>	<b>19</b>
<b>9.2 Additional information .....</b>	<b>20</b>
<b>9.3 Test results .....</b>	<b>20</b>
<b>10 Data to be recorded .....</b>	<b>21</b>
<b>11 Manufacturer's data .....</b>	<b>21</b>
<b>Annex ZA (informative) Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 2016/2281 aimed to be covered.....</b>	<b>22</b>
<b>Bibliography.....</b>	<b>23</b>

## European foreword

This document (prEN 16583:2020) has been prepared by Technical Committee CEN/TC 113 "Heat pumps and air conditioning units", the secretariat of which is held by UNE.

This document is currently submitted to the CEN Enquiry.

This document will supersede EN 16583:2015.

This document has been prepared under a standardization request given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive.

For relationship with EU Directive, see informative Annex ZA, which is an integral part of this document.

This document was prepared in the framework of the Commission Regulation (EU) 2016/2281 of 30 November 2016 implementing Directive 2009/125/EC of the European Parliament and of the Council establishing a framework for the setting of ecodesign requirements for energy-related products, with regard to ecodesign requirements for air heating products, cooling products, high temperature process chillers and fan coil units.

iTeh Standards  
(<https://standards.iteh.ai>)  
Document Preview

[SIST EN 16583:2022](#)

<https://standards.iteh.ai/catalog/standards/sist/0c32a545-eb63-4dc8-a734-289556d06509/sist-en-16583-2022>

## prEN 16583:2020 (E)

### 1 Scope

This document applies to hydronic fan coil units (FCU) as factory-made single assemblies which provide the functions of cooling and/or heating but do not include the source of cooling or heating.

This document covers both air free delivery and air ducted units with a maximum external static pressure due to duct resistance of 120 Pa max.

This document provides methods for the determination of the acoustical performance of fan coil units, defining standard working condition and installation.

It is not the purpose of this document to specify the tests used for production or field testing.

**NOTE** For the purpose of remaining clauses, the term "unit" is used to mean "fan coil unit" as defined in 3.1 of EN 1397:2015.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1397:2015, *Heat exchangers - Hydronic room fan coil units - Test procedures for establishing the performance*

EN ISO 3741, *Acoustics - Determination of sound power levels and sound energy levels of noise sources using sound pressure - Precision methods for reverberation test rooms (ISO 3741)*

EN ISO 3743-1, *Acoustics - Determination of sound power levels and sound energy levels of noise sources using sound pressure - Engineering methods for small movable sources in reverberant fields - Part 1: Comparison method for a hard-walled test room (ISO 3743-1)*

EN ISO 3743-2, *Acoustics - Determination of sound power levels of noise sources using sound pressure - Engineering methods for small, movable sources in reverberant fields - Part 2: Methods for special reverberation test rooms (ISO 3743-2)*

EN ISO 3744, *Acoustics - Determination of sound power levels and sound energy levels of noise sources using sound pressure - Engineering methods for an essentially free field over a reflecting plane (ISO 3744)*

EN ISO 3745, *Acoustics - Determination of sound power levels and sound energy levels of noise sources using sound pressure - Precision methods for anechoic rooms and hemi-anechoic rooms (ISO 3745)*

EN ISO 9614-1, *Acoustics - Determination of sound power levels of noise sources using sound intensity - Part 1: Measurement at discrete points (ISO 9614-1)*

EN ISO 9614-2, *Acoustics - Determination of sound power levels of noise sources using sound intensity - Part 2: Measurement by scanning (ISO 9614-2)*

EN ISO 9614-3, *Acoustics - Determination of sound power levels of noise sources using sound intensity - Part 3: Precision method for measurement by scanning (ISO 9614-3)*

EN ISO 80000-8:2007, *Quantities and units - Part 8: Acoustics (ISO 80000-8:2007, corrected 2007-08-15)*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN ISO 80000-8:2007 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

#### 3.1

##### **hydronic fan-coil unit**

factory-made single assembly which provides one or more of the functions of forced circulation of air, heating, cooling, dehumidification and filtering of air, but which does not include the source of heating or cooling

Note 1 to entry: This device includes at least a liquid-to-air heat exchanger and a fan, and may be designed for free or ducted intake air and/or for free or ducted delivery of supply air.

#### 3.2

##### **total electric power input**

total electric power absorbed by the unit, including fan(s) and auxiliary devices but excluding any electrical resistance heater

#### 3.3

##### **standard fan speed**

fan speed setting declared by the manufacturer and used for setting the air flow rate conditions of ducted units

Note 1 to entry: The fan speed setting can be declared by the manufacturer as a certain wiring, a switch position or a steering voltage.

#### 3.4

##### **external static pressure**

[SIST EN 16583:2022](#)

positive pressure difference measured between the air outlet and inlet sections of the unit

### 4 Measuring instruments

The acoustic instruments shall fulfil the requirements of the acoustic standard used for the test.

Other measurements can be necessary for the tests:

- Electrical: voltage (V), current (A), total electric power input (W);
- Pressure (Pa);
- Rotation speed ( $\text{min}^{-1}$ ).

**prEN 16583:2020 (E)**

Measurements for the ambient conditions:

- Relative humidity (%);
- Air temperature (°C);
- Atmospheric pressure (kPa).

Table 1 gives the uncertainties allowed for these measurement values.

**Table 1 — Uncertainties of measurement for indicated values**

Measured quantity	Unit	Uncertainty of measurement
Air — static pressure difference	Pa	±3 Pa ( $\Delta P \leq 100$ Pa) ±3 % ( $\Delta P > 100$ Pa)
Electrical quantities — Voltage — Current — Power	V A W	±0,5 % ±0,5 % ±1 % or minimum 1 W
Rotation speed	min <sup>-1</sup>	±1 %
Relative humidity	HR	5 %
Atmospheric pressure	kPa	1 %
Temperature	°C	±0,5 K

## 5 Operation of the unit

## Document Preview

The testing conditions are given in EN 1397:2015 except the following:

- The acoustic test shall be performed without connection to water supply, without water staying in the water circuit, with dry coil surface and an inlet air temperature between 15 °C and 25 °C.
- The control of the relative humidity is not required.

If the unit includes flaps, they shall be adjusted in a fixed position according to the manufacturer instructions. If this information is not available, their position shall correspond to the maximum mechanical open position.

NOTE 1 This maximum mechanical open position might differ from the minimum airflow resistance.


For testing, the unit shall include an air filter but no any other accessory for air inlet or diffusion or others. Dampers for fresh air intake shall be closed.

NOTE 2 No modification such as sealing is made on the unit before testing.

For ducted units, an external static pressure difference of 50 Pa (±1 Pa) shall be applied to the unit for the standard fan speed declared by the manufacturer.

If other speeds are tested, the same network curve resistance shall be used. See Figure 1.

If the resistance is obtained by using an auxiliary fan, preliminary tests shall be done to determine the external static difference for each additional speed.

**Key**

- 1 ductwork load curve
- 2 reference standard speed
- 3 other speeds
- X external static pressure difference
- Y flow rate

**Figure 1 — Setup external static pressure difference of ducted units for other speeds**

iTeh Standards  
<https://standards.iteh.ai>

## 6 Installation

### Document Preview

#### 6.1 General

The typical types of units are presented in the annex of EN 1397:2015.

<https://standards.iteh.ai/catalog/standards/sist/0c32a545-eb63-4dc8-a734-289556d06509/sist-en-16583-2022>

Tests shall be made in suitable acoustic test chambers.

#### 6.2 Non ducted units

##### 6.2.1 General

The target is the sound power level radiated by the whole unit, without distinction of inlet or discharge sides nor casing radiation.


##### 6.2.2 Floor mounted unit

The unit shall be installed on the hard floor at a minimum of 1 500 mm away from any wall out of any symmetry axis.

The feet provided by the manufacturer shall be used.

For aerodynamic purpose, the space between the feet shall be closed in the rear part to simulate the wall, with a rigid and reflective plate, with the same width of the unit and not exceeding its height. See Figure 2.

This plate shall be in chipboard or equivalent, density 600 kg/m<sup>3</sup> to 700 kg/m<sup>3</sup>, and thickness 19 mm to 22 mm.

**prEN 16583:2020 (E)****Key**

- 1 fan coil unit
- 2 feet
- 3 plate to close the space between the feet on the rear side
- 4 front side of the fan coil unit
- 5 rear side of the fan coil unit

**Figure 2 — Floor mounted unit with a closing plate between the feet**

### 6.2.3 Wall mounted unit

For low-wall mounting units, the distance to the floor given by the manufacturer shall be respected. Without information from the manufacturer, this distance shall be 150 mm.

For aerodynamic purpose, the space between the unit and the floor shall be closed in the rear part to simulate the wall, with a rigid and reflective plane, with the same width of the unit and not exceeding its height. See Figure 3.

The characteristics of the frame shall be such that any impact on the acoustic measurement by the frame radiation may be avoided.

This plate shall be in chipboard or equivalent, density 600 kg/m<sup>3</sup> to 700 kg/m<sup>3</sup>, and thickness 19 mm to 22 mm.