

**SLOVENSKI STANDARD
oSIST prEN ISO 16484-6:2020
01-februar-2020**

Sistemi za avtomatizacijo stavb in regulacijo - 6. del: Preskušanje skladnosti protokolov za izmenjavo podatkov (ISO/FDIS 16484-6:2019)

Building automation and control systems (BACS) - Part 6: Data communication conformance testing (ISO/FDIS 16484-6:2019)

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

Systèmes d'automatisation et de gestion technique du bâtiment - Partie 6: Essais de conformité de la communication de données (ISO/FDIS 16484-6:2019)

<https://standards.iteh.ai/catalog/standards/sist/2cab84b3-ab43-4783-b819->

Ta slovenski standard je istoveten z: prEN ISO 16484-6

ICS:

35.240.67	Uporabniške rešitve IT v gradbeništvu	IT applications in building and construction industry
97.120	Avtomatske krmilne naprave za dom	Automatic controls for household use

oSIST prEN ISO 16484-6:2020

en,fr,de

FINAL
DRAFTINTERNATIONAL
STANDARDISO/FDIS
16484-6

ISO/TC 205

Secretariat: ANSI

Voting begins on:
2019-12-10Voting terminates on:
2020-03-03**Building automation and control
systems (BACS) —****Part 6:
Data communication conformance
testing**

iTeh STANDARD REVIEW
*Systèmes d'automatisation et de gestion technique du bâtiment —
 Partie 6: Essais de conformité de la communication de données*
(standards.iteh.ai)

[SIST EN ISO 16484-6:2020](#)

<https://standards.iteh.ai/catalog/standards/sist/2cab84b3-ab43-4783-b819-70daf2a48a15/sist-en-iso-16484-6-2020>

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.

ISO/CEN PARALLEL PROCESSING

Reference number
ISO/FDIS 16484-6:2020(E)

© ISO 2020

ISO/FDIS 16484-6:2020(E)

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN ISO 16484-6:2020

<https://standards.iteh.ai/catalog/standards/sist/2cab84b3-ab43-4783-b819-70daf2a48a15/sist-en-iso-16484-6-2020>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. International Standards are drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 205, *Building environmental design*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 247, *Building Automation, Controls and Building Management*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This fourth edition cancels and replaces the third edition (ISO 16484-6:2014), which has been technically revised. See the detailed list of changes in pages 724 to 728.

A list of all parts in the ISO 16484 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

ISO/FDIS 16484-6:2020(E)**CONTENTS**

CLAUSE		PAGE
Foreword.....		iii
1. PURPOSE.....		1
2. SCOPE.....		1
3. DEFINITIONS.....		1
4. ELECTRONIC PICS FILE FORMAT		1
4.1 Character Encoding		1
4.2 Structure of EPICS Files		2
4.3 Character Strings.....		3
4.4 Notational Rules for Parameter Values.....		3
4.5 Sections of the EPICS File.....		4
5. EPICS CONSISTENCY TESTS.....		10
6. CONVENTIONS FOR SPECIFYING BACnet CONFORMANCE TESTS.....		12
6.1 TCSL Components		12
6.2 TCSL Statements.....		13
6.3 Time Dependencies		18
6.4 BACnet References.....		19
6.5 TD Requirements.....		19
7. OBJECT SUPPORT TESTS		20
7.1 Read Support for Properties in the Test Database		20
7.2 Write Support for Properties in the Test Database		22
7.3 Object Functionality Tests		24
8. APPLICATION SERVICE INITIATION TESTS		186
8.1 AcknowledgeAlarm Service Initiation Tests		186
8.2 ConfirmedCOVNotification Service Initiation Tests.....		187
8.3 UnconfirmedCOVNotification Service Initiation Tests		196
8.4 ConfirmedEventNotification Service Initiation Tests		199
8.5 UnconfirmedEventNotification Service Initiation Tests		241
8.6 GetAlarmSummary Service Initiation Tests		261
8.7 GetEnrollmentSummary Service Initiation Tests		262
8.8 GetEventInformation Service Initiation Tests.....		263
8.9 LifeSafetyOperation Service Initiation Tests		265
8.10 SubscribeCOV Service Initiation Tests		266
8.11 SubscribeCOVProperty Service Initiation Tests		267
8.12 AtomicReadFile Service Initiation Tests.....		268
8.13 AtomicWriteFile Service Initiation Tests		268
8.14 AddListElement Service Initiation Tests		269
8.15 RemoveListElement Service Initiation Tests		270
8.16 CreateObject Service Initiation Tests.....		270
8.17 DeleteObject Service Initiation Tests		271
8.18 ReadProperty Service Initiation Tests.....		271
8.19 ReadPropertyConditional Service Initiation Tests.....		273
8.20 ReadPropertyMultiple Service Initiation Tests.....		274
8.21 ReadRange Service Initiation Tests		276
8.22 WriteProperty Service Initiation Tests		280
8.23 WritePropertyMultiple Service Initiation Tests		282
8.24 DeviceCommunicationControl Service Initiation Tests.....		284
8.25 ConfirmedPrivateTransfer Service Initiation Test		286
8.26 UnconfirmedPrivateTransfer Service Initiation Test.....		286

8.27	ReinitializeDevice Service Initiation Tests.....	286
8.28	ConfirmedTextMessage Service Initiation Tests.....	287
8.29	UnconfirmedTextMessage Service Initiation Tests.....	288
8.30	TimeSynchronization Service Initiation Tests	289
8.31	UTCTimeSynchronization Service Initiation Tests.....	290
8.32	Who-Has Service Initiation Tests.....	290
8.33	I-Have Service Initiation Tests.....	291
8.34	Who-Is Service Initiation Tests.....	291
8.35	I-Am Service Initiation Tests	292
8.36	VT-Open Service Initiation Tests	292
8.37	VT-Close Service Initiation Tests	293
8.38	VT-Data Service Initiation Tests.....	294
8.39	RequestKey Service Initiation Tests.....	296
8.40	Authenticate Service Initiation Tests.....	297
9.	APPLICATION SERVICE EXECUTION TESTS.....	301
9.1	AcknowledgeAlarm Service Execution Tests.....	301
9.2	ConfirmedCOVNotification Service Execution Tests	327
9.3	UnconfirmedCOVNotification Service Execution Tests	332
9.4	ConfirmedEventNotification Service Execution Tests	334
9.5	UnconfirmedEventNotification Service Execution Tests	337
9.6	GetAlarmSummary Service Execution Tests.....	337
9.7	GetEnrollmentSummary Service Execution Tests.....	338
9.8	GetEventInformation Service Execution Tests.....	342
9.9	LifeSafetyOperation Service Execution Test	345
9.10	SubscribeCOV Service Execution Tests	346
9.11	SubscribeCOVProperty Service Execution Tests.....	354
9.12	AtomicReadFile Service Execution Tests.....	361
9.13	AtomicWriteFile Service Execution Tests	368
9.14	AddListElement Service Execution Tests	379
9.15	RemoveListElement Service Execution Tests.....	381
9.16	CreateObject Service Execution Tests.....	383
9.17	DeleteObject Service Execution Tests	388
9.18	ReadProperty Service Execution Tests	389
9.19	ReadPropertyConditional Service Execution Tests.....	391
9.20	ReadPropertyMultiple Service Execution Tests	392
9.21	ReadRange Service Execution Tests	400
9.22	WriteProperty Service Execution Tests	410
9.23	WritePropertyMultiple Service Execution Tests	415
9.24	DeviceCommunicationControl Service Execution Test	424
9.25	ConfirmedPrivateTransfer Service Execution Tests.....	430
9.26	UnconfirmedPrivateTransfer Service Execution Tests.....	431
9.27	ReinitializeDevice Service Execution Tests	431
9.28	ConfirmedTextMessage Service Execution Tests.....	434
9.29	UnconfirmedTextMessage Service Execution Tests.....	435
9.30	TimeSynchronization Service Execution Tests	435
9.31	UTCTimeSynchronization Service Execution Tests	437
9.32	Who-Has Service Execution Tests	437
9.33	Who-Is Service Execution Tests	444
9.34	VT-Open Service Execution Tests	447
9.35	VT-Close Service Execution Tests.....	449

ISO/FDIS 16484-6:2020(E)

9.36	VT-Data Service Execution Tests	450
9.37	RequestKey Service Execution Test.....	450
9.38	Authenticate Service Execution Tests.....	452
9.39	General Testing of Service Execution.....	456
10.	NETWORK LAYER PROTOCOL TESTS.....	458
10.1	General Network Layer Tests.....	458
10.2	Router Functionality Tests	459
10.3	Half-Router Functionality Tests	483
10.4	B/IP PAD Tests	490
10.5	Initiating Network Layer Messages	492
10.6	Non-Router Functionality Tests	494
10.7	Route Binding Tests	496
10.8	Virtual Routing Functionality Tests.....	501
11.	LOGICAL LINK LAYER PROTOCOL TESTS.....	520
11.1	UI Command and Response	520
11.2	XID Command and Response.....	520
11.3	TEST Command and Response	521
12.	DATA LINK LAYER PROTOCOLS TESTS	523
12.1	MS/TP State Machine Tests.....	523
12.2	PTP State Machine Tests	587
13.	SPECIAL FUNCTIONALITY TESTS.....	626
13.1	Segmentation	626
13.2	Time Master.....	635
13.3	Character Sets	640
13.4	Malformed PDUs	640
13.5	Slave Proxy Tests.....	642
13.6	Automatic Network Mapping	644
13.7	Automatic Device Mapping.....	645
13.8	Backup and Restore Procedure Tests	645
13.9	Application State Machine Tests	657
13.10	Workstation Scheduling Tests	658
14.	BACnet/IP Functionality Tests.....	676
14.1	Non-BBMD B/IP Device	676
14.2	BBMD B/IP Device with a Server Application	678
14.3	Broadcast Distribution Table Operations	682
14.4	Foreign Device Table Operations (Negative Tests).....	686
14.5	BACnet Broadcast Management (No Foreign Device Table, No Applications)	687
14.6	Foreign Device Management	689
14.7	Broadcast Management (BBMD, Foreign Devices, Local Application).....	693
14.8	Registering as a Foreign Device.....	701
14.9	Initiating BVLL Service Requests Conveying an NPDU.....	702
15.	Reporting Test Results	704
	ANNEX A – EXAMPLE EPICS (INFORMATIVE).....	705
	HISTORY OF REVISIONS.....	724

1. PURPOSE

To define a standard method for verifying that an implementation of the BACnet protocol provides each capability claimed in its Protocol Implementation Conformance Statement (PICS) in conformance with the BACnet standard.

2. SCOPE

This standard provides a comprehensive set of procedures for verifying the correct implementation of each capability claimed on a BACnet PICS including:

- (a) support of each claimed BACnet service, either as an initiator, executor, or both,
- (b) support of each claimed BACnet object-type, including both required properties and each claimed optional property,
- (c) support of the BACnet network layer protocol,
- (d) support of each claimed data link option, and
- (e) support of all claimed special functionality.

3. DEFINITIONS

All definitions from ANSI/ASHRAE Standard 135-2016 also apply to this addendum.

3.1 local network: the network to which a BACnet device is directly connected.

3.2 remote network: a network that is accessible from a BACnet device only by passing through one or more routers.

3.3 test database: a database of BACnet functionality and objects created by reading the contents of an EPICS.

3.4 Abbreviations and Acronyms Used in the Standard

BNF Backus-Naur Form syntax

EPICS electronic protocol implementation conformance statement

IUT implementation under test

TCSL testing and conformance scripting language

TD testing device

TPI text protocol information

4. ELECTRONIC PICS FILE FORMAT

An electronic protocol implementation conformance statement (EPICS) file contains a BACnet protocol implementation conformance statement expressed in a standardized text form. EPICS files are machine and human readable representations of the implementation of BACnet objects and services within a given device. EPICS files shall use the extension ".TPI" (text protocol information) and contain normal editable text lines consisting of text character codes ending in carriage return/linefeed pairs (X'0D', X'0A').

EPICS files are used by software testing tools to conduct and interpret the results of tests defined in this standard. An EPICS file shall accompany any device tested according to the procedures of this standard.

4.1 Character Encoding

BACnet provides for a variety of possible character encodings. The character encodings in BACnet fall into three groups: octet streams, double octet streams and quad octet streams. Octet streams represent characters as single octet values. In some cases, such as Microsoft DBCS and JIS C 6226, certain octet values signal that the second octet which follows should be viewed along with the leading octet as a single value, thus extending the range to greater than 256 possible characters. In contrast, double octet streams view pairs of octets as representing single characters. The ISO 10646 UCS-2 encoding is an example. The first or leading octet of the pair is the most significant part of the value. Quad octet streams, such as ISO 10646 UCS-4, treat tuples of four octets at a time as single characters with the first or leading octet being the most significant.

ISO/FDIS 16484-6:2020(E)

4. ELECTRONIC PICS FILE FORMAT

To accommodate the various encodings that may be used with BACnet device descriptions, EPICS files begin with a header that serves both to identify the file as an EPICS file, and to identify the particular encoding used. The header begins with the string "PICS #" where # is replaced by a numeral representing the character set as shown in Table 4-1.

Table 4-1. Character Set Codes

code	character set
0	ANSI X3.4
1	Microsoft DBCS
2	JIS C 6226
3	ISO 10646 (UCS-4)
4	ISO 10646 (UCS-2)
5	ISO 8859-1

An octet stream format can be recognized by examining the first eight octets of the EPICS file. Using ANSI X3.4 encoding as an example these eight octets will contain: X'50' X'49' X'43' X'53' X'20' X'30' X'0D' X'0A'. This represents the text "PICS 0" followed by carriage return and linefeed.

A double octet stream format can be recognized by examining the first 16 octets of the EPICS file. Using ISO 10646 UCS-2 encoding as an example these 16 octets will contain:

```
X'00' X'50' X'00' X'49' X'00' X'43' X'00' X'53'  
X'00' X'20' X'00' X'34' X'00' X'0D' X'00' X'0A'
```

This represents the text "PICS 4" followed by carriage return and linefeed.

A quad octet stream format can be recognized by examining the first 32 octets of the EPICS file. Using ISO 10646 UCS-4 as an example these 32 octets will contain:

```
X'00' X'00' X'00' X'50' X'00' X'00' X'00' X'49'  
X'00' X'00' X'00' X'43' X'00' X'00' X'00' X'53'  
X'00' X'00' X'00' X'20' X'00' X'00' X'00' X'33'  
X'00' X'00' X'00' X'0D' X'00' X'00' X'00' X'0A'
```

This represents the text "PICS 3" followed by carriage return and linefeed.

4.2 Structure of EPICS Files

EPICS files consist of text lines ending in carriage return/linefeed pairs (X'0D', X'0A') encoded as octet, double octet or quad octet streams as defined in 4.1. In the rest of this standard, the term "character" will be used to mean one symbol encoded as one, two, or four octets based on the character encoding used in the EPICS file header. For example, the character space may be encoded as X'20' or X'0020' or X'00000020'. In this standard all characters will be shown in their single octet form.

The special symbol ↴ is used in this Clause to signify the presence of a carriage return/linefeed pair (X'0D0A'). Except within character strings, the character codes tab (X'09'), space (X'20'), carriage return (X'0D') and linefeed (X'0A') shall be considered to be white space. Any sequence of 1 or more white space characters shall be equivalent to a single white space character. Except within a character string, a sequence of two dashes (X'2D') shall signify the beginning of a comment which shall end with the next carriage return/linefeed pair, i.e., the end of the line upon which the -- appears. Comments shall be considered to be white space, and may thus be inserted freely.

EPICS files shall have, as their first line following the header, the literal text:

BACnet Protocol Implementation Conformance Statement ↴

This text serves as a signature identifying the EPICS file format.

Lines that define the sections of the EPICS (see 4.5) and the particular implementation data for a given device follow the signature line.

The EPICS file ends with a line containing the following literal text:

End of BACnet Protocol Implementation Conformance Statement ↴

4.3 Character Strings

The occurrence of a double quote (X'22'), single quote (X'27') or accent grave (X'60') shall signify character strings. For double quotes, the end of the string shall be signified by the next occurrence of a double quote, or the end of the line. For single quote or accent grave, the end of the string shall be signified by the next occurrence of a single quote (X'27'), or the end of the line. Thus strings which need to include a single quote or accent grave as a literal character in the string shall use the double quote quoting method, while strings which need to include double quote shall use the single quote or accent grave quoting method.

4.4 Notational Rules for Parameter Values

Within each section, parameters may need to be expressed in one of several forms. The following rules govern the format for parameters:

- (a) key words are case insensitive so that X'41' through X'5A' are equivalent to X'61' through X'7A';
- (b) null values are shown by the string "NULL";
- (c) Boolean values are shown by the strings "T" or "TRUE" if the value is true, or "F" or "FALSE" if the value is false;
- (d) integer values are shown as strings of digits, possibly with a leading minus (-): 12345 or -111;
- (e) real values are shown with a decimal point, which may not be the first or last character: 1.23, 0.02, 1.0 but not .02;
- (f) octet strings are shown as pairs of hex digits enclosed in either single quotes (X'2D') or accent graves (X'60'), and preceded by the letter "X": X'001122';
- (g) character strings are represented as one or more characters enclosed in double, single or accent grave quotes as defined in 4.3: 'text' or 'text' or "text";
- (h) bitstrings are shown as a list, enclosed by curly brackets ({} or X'7B' and X'7D'), of true and false values: {T,T,F} or {TRUE, TRUE, FALSE}. When the actual value of a bit does not matter, a question mark is used: {T,T,?};
- (i) enumerated values are represented as named, rather than numeric, values. Enumeration names are case insensitive so that X'41' through X'5A' are equivalent to X'61' through X'7A'. The underscore (X'5F') and dash (X'2D') are considered equivalent in enumeration names. Proprietary values are shown as a named text with no whitespace and ending in a non-negative decimal numeric. Each must start with the word "proprietary": Object_Type, proprietary-object-type-653; 12a48a13/sist-en-iso-16484-6-2020
- (j) dates are represented enclosed in parenthesis: (Monday, 24-January-1998). Any "wild card" or unspecified field is shown by an asterisk (X'2A'): (Monday, *-January-1998). The omission of day of week implies that the day is unspecified: (24-January-1998);
- (k) times are represented as hours, minutes, seconds, hundredths in the format hh:mm:ss.xx: 2:05:44.00, 16:54:59.99. Any "wild card" field is shown by an asterisk (X'2A'): 16:54:*.*;
- (l) object identifiers are shown enclosed by parentheses, with commas separating the object type and the instance number: (analog-input, 56). Proprietary object types replace the object type enumeration with the word "proprietary" followed by the numeric value of the object type: (proprietary 700,1);
- (m) constructed data items are represented enclosed by curly brackets ({} or X'7B' and X'7D'), with elements separated by commas. If an element is itself a constructed value, then that element shall be enclosed in curly brackets.

4.4.1 Complex Parameter Values

Some parameter values, notably property values for constructed or CHOICE types of encoded values, need to use a more complex notation to represent their values. This notation is tied to the ASN.1 encoding for those property values and may appear obscure out of context. These additional rules govern the presentation of those types of parameter values:

- (a) values which are a CHOICE of application-tagged values are represented by the value of the chosen item encoded as described in 4.4;
- (b) values which are a CHOICE of context-tagged values are represented by the context tag number enclosed in square brackets, followed by the representation of the value of the chosen item;
- (c) list values (ASN.1 "SEQUENCE OF") are represented enclosed in parenthesis, with the elements of the list separated by commas. If an element is itself a constructed value, then that element shall be enclosed in curly brackets;

ISO/FDIS 16484-6:2020(E)

4. ELECTRONIC PICS FILE FORMAT

- (d) array values are represented enclosed in curly brackets, with the elements of the array separated by commas. If an element is itself a constructed value, then that element shall be enclosed in curly brackets.

4.4.2 Specifying Limits on Parameter Values

Some properties may have restrictions on the range or resolution of their values. In order to correctly interpret the results of tests in which the value of a property is changed using WriteProperty, WritePropertyMultiple, or AddListElement then read back using ReadProperty or ReadPropertyMultiple, it is necessary to know what these restrictions are. The test database may contain restriction statements that define these constraints. The permissible restrictions and the datatypes they apply to are:

- (a) **minimum** - the minimum value for Unsigned, Integer, Real, or Double datatypes. The earliest date for the Date datatype;
- (b) **maximum** - the maximum value for Unsigned, Integer, Real, or Double datatypes. The latest date for the Date datatype;
- (c) **resolution** - the minimum guaranteed resolution for Real and Double datatypes. The minimum time resolution in seconds for the Time datatype;
- (d) **maximum length string** - the maximum length of a CharacterString or OctetString;
- (e) **maximum length list** - the maximum number of elements guaranteed to fit in a list;
- (f) **maximum length array** - the maximum number of elements in an array;
- (g) **allowed values** - a comma-delimited list of supported enumerations for an Enumerated datatype. A comma-delimited list of object types for properties that reference an external object identifier.

Restriction statements shall be listed within pointed brackets (< and >) following the default value. If there are multiple restrictions within a single set of angle brackets, then the restrictions shall be separated by a semicolon (;). A restriction statement consists of the restriction name followed by a colon (:) followed by the restriction value or, where appropriate, a comma-delimited list of possible values. (standards.iteh.ai)

Here are some examples of property values with restriction statements as they could appear in the test database.

```
present-value: 13.4 <minimum: 0.0; maximum: 20.0; resolution: 0.1>
description: "this is a description" <maximum length string: 30>
units: milliamperes <allowed values: milliamperes, amperes>-16484-6-2020
object-property-reference: (analog input, 12) <allowed values: analog input, analog value>
```

The Units property is a special case, because changing the units can change the value of the Present_Value property as well as any restrictions on its value. Therefore, minimum, maximum, and resolution restrictions are only valid for the default value of the Units property.

It is possible to specify default restrictions for most datatypes as described in 4.5.8. Restriction statements in the test database override the default restrictions for the individual property that contains the restriction statement.

4.5 Sections of the EPICS File

Each section of the EPICS file begins with a section name followed by a colon (: or X'3A'). After the colon is a set of one or more parameters delimited by a set of curly braces ({ } or X'7B' X'7D').

The following symbols are used as placeholders to indicate the presence of parameter information:

- (a) the open box symbol inside quotation marks, "□", is used to indicate that a character string parameter shall be present;
- (b) the open box symbol with no quotation marks, □, is used to indicate that a parameter with a datatype other than a character string shall be present;
- (c) a question mark, ?, is used in the test database to indicate that the property is present but the value is unknown because it depends on hardware input or is being changed by an internal algorithm.

An example EPICS file may be found in Annex A.

4.5.1 General Information Sections

These sections provide general information about the BACnet device. The syntax for these sections is shown below.

```
Vendor Name: "□"↵
Product Name: "□"↵
Product Model Number: "□"↵
Product Description: "□"↵
```

4.5.2 Conformance Sections

These sections provide information about the BACnet functionality that the device claims to support.

4.5.2.1 BIBBs Supported

This section indicates which BIBBs are supported. The syntax is shown below. Each BIBB shall be listed, one per line between the curly braces. An empty list indicates that no BIBBs are supported.

```
BIBBs Supported: ↵
{↵
    □↵
}↵
```

The BIBBs may be any of those BIBBs described in Annex K. The format in the EPICS shall be to use the short acronym described in the title for each BIBB. For example: A device which supports 'Data Sharing - ReadProperty - B' should include 'DS-RP-B' in this section.

The STANDARD PREVIEW (standards.iteh.ai)

For example:

```
BIBBs Supported: ↵
{↵
    DS-RP-B↵
    DS-WP-B↵
    DS-RPM-B↵
    DM-DOB-B↵
    DM-DDB-B↵
    DM-DDB-A↵
}↵
```

[SIST EN ISO 16484-6:2020](https://standards.iteh.ai/catalog/standards/sist/2cab84b3-ab43-4783-b819-70daf2a48a15/sist-en-iso-16484-6-2020)

4.5.3 Application Services Supported

This section indicates which standard application services are supported. The syntax is shown below. Each supported service shall be listed between curly braces one service per line, followed by the words "Initiate" or "Execute" to indicate whether the service can be initiated, executed, or both.

```
BACnet Standard Application Services Supported: ↵
{↵
    □ Initiate↵
    □ Execute↵
    □ Initiate Execute↵
}
```

The standard services may be any of the services listed in the Clause 21 production BACnetServicesSupported.

The format should match the title of each corresponding services section in the standard minus the text 'Service'. For example, if the device supports the AcknowledgeAlarm service, the text 'AcknowledgeAlarm' should be included in this section of the EPICS.

ISO/FDIS 16484-6:2020(E)**4. ELECTRONIC PICS FILE FORMAT**

For example:

```
BACnet Standard Application Services Supported: ↴
{ ↴
  Who-Is           Initiate Execute↵
  I-Am             Initiate Execute↵
  Who-Has          Execute↵
  I-Have           Initiate ↴
  ReadProperty     Execute↵
  ReadPropertyMultiple Execute↵
  WriteProperty    Execute↵
}
}
```

4.5.4 Object Types Supported

This section indicates which standard object types are supported. The syntax is shown below. Each supported object type shall be listed between curly braces one object type per line, optionally followed by the words "Createable", "Deleteable", or both to indicate that dynamic creation or deletion is supported.

```
Standard Object Types Supported: ↴
{ ↴
  ↳ ↴
  □ Createable↵
  □ Deleteable↵
  □ Createable Deleteable↵
}
}
```

iTeh STANDARD PREVIEW
(standards.iteh.ai)

The standard objects may be any of the objects listed in the Clause 21 production, BACnetObjectTypesSupported.

The format should be the title of each corresponding object section in the standard minus the text Object Type. For example, if the device supports the object access door, the text 'Access Door' should be included in this section.

For example:

```
BACnet Standard Application Services Supported: ↴
{ ↴
  Analog Value Createable Deleteable↵
  Analog Input↵
  Device↵
}
}
```

4.5.5 Data Link Layer Options

This section indicates which standard data link layer options are supported. The syntax is shown below. Each supported data link layer type shall be listed between the curly braces one per line. MS/TP and Point-To-Point data links shall also specify supported baud rate(s).

```
Data Link Layer Option: ↴
{ ↴
  ISO 8802-3, 10BASE5↵
  ISO 8802-3, 10BASE2↵
  ISO 8802-3, 10BASET↵
  ISO 8802-3, fiber↵
  ARCNET, coax star↵
  ARCNET, coax bus
}
```

ARCNET, twisted pair star.
 ARCNET, twisted pair bus.
 ARCNET, fiber star.
 ARCNET, twisted pair, EIA-485, Baud rate(s): □.
 MS/TP master, Baud rate(s): 9600, □.
 MS/TP slave, Baud rate(s): 9600, □.
 Point-To-Point, EIA 232, Baud rate(s): □.
 Point-To-Point, Modem, Baud rate(s): □.
 Point-To-Point, Modem, Autobaud range: □ to □.
 BACnet/IP, 'DIX' Ethernet.
 BACnet/IP, Other.
 Other.
 }.

4.5.6 Character Sets

This section indicates which BACnet character sets are supported. The syntax is shown below. Each supported character set shall be listed one per line between the curly braces.

Character Sets Supported:
 {
 ANSI X3.4.
 IBM/Microsoft DBCS.
 JIS C 6226.
 ISO 8859-1.
 ISO 10646 (UCS-4).
 ISO 10646 (UCS2).
 }.

4.5.7 Special Functionality

This section indicates which BACnet special functionalities are supported. The syntax is shown below. Each special functionality supported shall be listed one per line between the curly braces. The maximum APDU size and window sizes shall be specified as integers.

Special Functionality:
 {
 Maximum APDU size in octets: □.
 Segmented Requests Supported, window size: □.
 Segmented Responses Supported, window size: □.
 Router.
 BACnet/IP BBMD.
 }.

4.5.8 Property Value Restrictions

This section defines default restrictions on the values of writable properties. Restrictions listed for a particular datatype apply to every writable property or component of a writable property of that datatype. The restriction may be overridden for a particular property by adding a new restriction specifically for that property in the test database section of the EPICS. See 4.4.2. Only those datatypes for which default restrictions are being defined should be listed, one datatype per line. An empty list indicates that no default restrictions apply.

Default Property Value Restrictions:
 {
 unsigned-integer: <minimum: □; maximum: □>.
 signed-integer: <minimum: □; maximum: □>.
 real: <minimum: □; maximum: □; resolution: □>.