



Designation: E 164 – 97

Standard Practice for Ultrasonic Contact Examination of Weldments¹

This standard is issued under the fixed designation E 164; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

1. Scope

1.1 This practice covers techniques for the ultrasonic A-scan examination of specific weld configurations joining wrought ferrous or aluminum alloy materials to detect weld discontinuities (Note 1). The reflection method using pulsed waves is specified. Manual techniques are described employing contact of the search unit through a couplant film or water column.

1.2 This practice utilizes angle beams or straight beams, or both, depending upon the specific weld configurations. Practices for special geometries such as fillet welds and spot welds are not included. The practice is intended to be used on thicknesses of 0.250 to 8 in. (6.4 to 203 mm).

NOTE 1—This practice is based on experience with ferrous and aluminum alloys. Other metallic materials can be examined using this practice provided reference standards can be developed that demonstrate that the particular material and weld can be successfully penetrated by an ultrasonic beam.

NOTE 2—For additional pertinent information see Practice E 317, Terminology E 1316, and Practice E 587.

1.3 Values stated in inch-pound units are to be regarded as the standard. SI units are given for information only.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:

E 317 Practice for Evaluating Performance Characteristics of Ultrasonic Pulse-Echo Testing Systems Without the Use of Electronic Measurement Instruments²

E 543 Practice for Evaluating Agencies that Perform Non-destructive Testing²

E 587 Practice for Ultrasonic Angle-Beam Examination by

the Contact Method²

E 1316 Terminology for Nondestructive Examinations²

2.2 ASNT Standard:

Practice SNT-TC-1A Personnel Qualification and Certification in Nondestructive Testing³

3. Significance and Use

3.1 The techniques for ultrasonic examination of welds described in this practice are intended to provide a means of weld examination for both internal and surface discontinuities within the weld and the heat-affected zone. The practice is limited to the examination of specific weld geometries in wrought or forged material.

3.2 The techniques provide a practical method of weld examination for internal and surface discontinuities and are well suited to the task of in-process quality control. The practice is especially suited to the detection of discontinuities that present planar surfaces perpendicular to the sound beam. Other nondestructive tests may be used when porosity and slag inclusions must be critically evaluated.

3.3 When ultrasonic examination is used as a basis of acceptance of welds, there should be agreement between the manufacturer and the purchaser as to the specific reference standards and limits to be used. Examples of reference standards are given in Section 6. A detailed procedure for weld examination describing allowable discontinuity limits should be written and agreed upon.

3.4 *Personnel Qualification*—In order to meet the intent of this recommended practice, it is essential that evaluation be performed by properly trained and qualified testing personnel. The user is referred to Practice SNT-TC-1A published by American Society of Nondestructive Testing (ASNT) or other equivalent programs.

3.5 *Nondestructive Testing Agency Evaluation*—Use of an NDT agency (as defined in Practice E 543) to perform the examination may be agreed upon by the using parties. If a systematic assessment of the capability of the agency is specified, a documented procedure such as Practice E 543 shall be used as the basis for evaluation.

¹ This practice is under the jurisdiction of ASTM Committee E-7 on Nondestructive Testing and is the direct responsibility of Subcommittee E07.06 on Ultrasonic Method.

Current edition approved Dec. 10, 1997. Published February 1998. Originally published as E 164 – 60 T. Last previous edition E 164 – 94a.

² *Annual Book of ASTM Standards*, Vol 03.03.

³ Available from American Society for Nondestructive Testing (ASNT), 4153 Arlington Plaza, Columbus, OH 43228-0518.

4. Search Units

4.1 Angle-Beam requirements for angle-beam search units are determined by the test variables. The inspection procedure should be established by taking into consideration variables such as weld thickness, available test surface, maximum allowable flaw size, flaw orientation, and the acoustic properties of the material. Consideration should also be given to the desirability of using comparable wave lengths within the test materials where both a longitudinal-wave test and an angle-beam shear-wave test are employed. This can be accomplished by conducting the straight-beam (longitudinal-wave) examination at approximately two times the frequency of the angle-beam (shear-wave) examination.

4.2 Frequencies of 1.0 to 5 MHz are generally employed for angle-beam (shear-wave) and for straight-beam (longitudinal-wave) testing.

4.3 Transducer sizes recommended for weld testing range from a minimum of ¼-in. (6.4-mm) diameter or ¼-in. square to 1 in. (25.4 mm) square or 1½-in. (28.6-mm) diameter.

5. Calibration

5.1 Two methods of angle-beam calibration are in general use: the polar, and the rectangular, coordinate methods.

5.1.1 The polar coordinate method requires measurements of the beam centerline at the search unit/work interface and the beam angle in a test block, and the instrument sweep is calibrated along the beam line. Test information is graphically converted into position and depth coordinates for reflector location. The polar method is detailed in Annex A1.

5.1.2 The rectangular coordinate method requires measurement of the position of the reflector from the front of the search unit, and the instrument sweep is calibrated for depth to the reflector as it is moved to different positions in the beam providing a distance-amplitude curve. Test information is read directly for position and depth to the reflector. The rectangular coordinate method is detailed in Annex A2.

6. Reference Standards

6.1 IIW-type test blocks are a class of reference blocks for checking and calibrating ultrasonic testing instrumentation, which meet the basic geometrical configuration described in ISO 2400 but which may deviate in such aspects as non-metric dimensioning, alternate materials, additional reflectors, and differences of scale details. IIW-type blocks are primarily intended for characterizing and calibrating angle-beam test systems, but also provide features for such uses as straight-beam resolution and sensitivity checks.

NOTE 3—Discussion of the differences among various versions of “IIW-Type” calibration blocks, illustrations of typical configurations and an extensive bibliography can be found in a published reference.⁴

6.1.1 Only blocks fully meeting all the requirements of ISO 2400 should be referred to as IIW reference blocks.

6.1.2 Blocks qualified to certain other national standards may also satisfy all the requirements of ISO 2400 but have additional features.

6.1.3 The term *IIW Block Type I* should be used only to describe blocks meeting the standard cited. The term *IIW Block Type II* is reserved for the miniature angle-beam block recognized by ISO.

6.1.4 All other blocks derived from the basic ISO 2400 configuration, but not fully meeting all its requirements should be referred to as *IIW-Type* blocks.

6.1.5 Suppliers and users of such blocks should identify the specifications which are met, or provide detailed documentation.

6.1.6 Because of the possible differences noted, not all IIW-type blocks may be suited for every application for which qualified ISO 2400 blocks may be acceptable.

6.1.7 Unless the blocks have also been checked by prescribed ultrasonic procedures, they may also produce non-uniform or misleading test results.

6.2 Distance Calibration:

6.2.1 An equal-radius reflecting surface subtending an arc of 90° is recommended for distance calibration because it is equally responsive to all beam angles. Other reflector configurations may be used. Equal-radius reflecting surfaces are incorporated into IIW-Type Blocks and several other reference blocks (see Annex A1) (Note 3). Distance calibration on a square-notch corner reflector with a depth of 1 to 3 % of thickness may be used. However, full beam reflections from the square corner of the block will produce erroneous results when calibrating angle beams near 60°, due to mode conversion. The square corner of the block should not be used for distance calibration.

NOTE 4—Small errors of beam index location are indigenous to the calibration procedure using the an IIW-Type Block. Where extremely accurate calibration is necessary, a procedure such as that outlined in 6.2.2 should be used.

6.2.2 For testing of welds, a side-drilled hole may be used for distance, amplitude, position, and depth calibration. An example is shown in Fig. 1. Move the reflector through the beam to 1/8, 3/8, 5/8, 7/8, and 9/8 of the Vee path. Adjust the delay to place indication 1 at sweep division 1. Adjust the range to place indication 9 at sweep division 9. Since these controls interact, repeat the delay and range adjustments until indications 1 and 9 are placed at sweep divisions 1 and 9. Adjust sensitivity to provide an 80 %-of-full-screen indication from the highest of the 1, 3, 5, 7, or 9 indications. At this sensitivity,




FIG. 1 Side-Drilled Hole

⁴ Hotchkiss, F.H.C., “Guide to designs of IIW-type blocks”, *NDT International*, Vol. 23, n. 6, December 1990, pp. 319-331.

mark the maximum amplitudes on the screen from the reflector at 1, 3, 5, 7, and 9. Connect these points for the distance amplitude curve (DA Curve). Corner reflections from the hole to the surface may be observed at 4 and 8 divisions on the sweep; these indications will not be used in the DA Curve. Measure the position of the reflector on the surface from the front of the search unit to the surface projection of the hole centerline. Since the depth to the hole is known, the calibration provides means for estimating the position, depth, and relative size of an unknown reflector.

6.3 Sensitivity-Amplitude Calibration:

6.3.1 Reference standards for sensitivity-amplitude calibration should be designed so that sensitivity does not vary with beam angle when angle-beam testing is used. Sensitivity-amplitude calibration standards that accomplish this end are side-drilled holes parallel to the major surfaces of the plate and perpendicular to the sound path, flat-bottomed holes drilled at the testing angle, and equal-radius reflectors. Surface notches can also accomplish this end under some circumstances. These reference reflectors are described in Table 1.

6.3.2 Under certain circumstances, sensitivity-amplitude calibration must be corrected for coupling variations (Section 7) and distance amplitude effects (Section 8).

7. Coupling Conditions

7.1 Preparation:

7.1.1 Where accessible, prepare the surface of the deposited weld metal so that it merges into the surfaces of the adjacent base materials; however, the weld may be examined in the as-welded condition, provided the surface condition does not interfere with valid interpretation of indications.

7.1.2 Free the scanning surfaces on the base material of weld spatter, scale, dirt, rust, and any extreme roughness on each side of the weld for a distance equal to several times the thickness of the production material, this distance to be governed by the size of the search unit and refracted angle of the sound beam. Where scanning is to be performed along the top or across this weld, the weld reinforcement may be ground to provide a flat scanning surface. It is important to produce a surface that is as flat as possible. Generally, the surfaces do not require polishing; light sanding with a disk or belt sander will usually provide a satisfactory surface for examination.

7.1.3 The area of the base material through which the sound will travel in the angle-beam examination should be completely scanned with a straight-beam search unit to detect reflectors that might affect the interpretation of angle-beam results by obstructing the sound beam. Consideration must be given to these reflectors during interpretation of weld exami-

nation results, but their detection is not necessarily a basis for rejection of the base material.

7.2 Couplant:

7.2.1 A couplant, usually a liquid or semi-liquid, is required between the face of the search unit and the test surface to permit transmission of the acoustic energy from the search unit to the material under test. The couplant should wet the surfaces of the search unit and the test piece, and eliminate any air space between the two. Typical couplants include water, oil, grease, glycerin, and cellulose gum. The couplant used should not be injurious to the material to be tested, should form a thin film, and, with the exception of water, should be used sparingly. When glycerin is used, a small amount of wetting agent is often added, such as an aerosol, to improve the coupling properties. When water is used, it should be clean and air-free. Inhibitors or wetting agents, or both, may be used.

7.2.2 The coupling medium should be selected so that its viscosity is appropriate for the surface finish of the material to be inspected. The following table is presented as a guide:

| Roughness Average (Ra μ in.) | Equivalent Couplant Viscosity |
|----------------------------------|-------------------------------|
| 5 to 100 | SAE 10 wt. motor oil |
| 50 to 200 | SAE 20 wt. motor oil |
| 80 to 600 | glycerin |
| 100 to 400 | SAE 30 wt. motor oil |

7.2.3 In performing the examination, it is important that the same couplant, at the same temperature, be used for comparing the responses between the calibration blocks and the production material. Attenuation in couplants and wedge materials varies with temperature so that a calibration performed in a comfortable room is not valid for examination of either hotter or colder materials.

8. Distance-Amplitude Correction

8.1 Use calibration blocks of similar surface finish, nominal thickness and metallurgically similar in terms of alloy and thermal treatment to the weldment.

8.2 Alternative methods of correction may be used provided the results are as reliable as those obtained by the acceptable method. In addition, the alternative method and its equipment shall meet all the performance requirements of this standard.

8.3 Calibration Reflectors:

8.3.1 *Straight-Beam Calibration*—Correction for straight-beam examination may be determined by means of a side-drilled hole reflector at $\frac{1}{4}$ and $\frac{3}{4}$ of the thickness. For thickness less than 2 in. (51 mm), the $\frac{1}{4}$ thickness reflector may not be resolved. If this is the case, drill another hole at $\frac{1}{2}$ thickness and use the $\frac{1}{2}$ and $\frac{3}{4}$ -thickness reflectors for correction.

TABLE 1 Reference Reflectors and Their Attributes

| Reference Reflector | Attributes and Limitations |
|-----------------------------------|--|
| Side-drilled holes | Easily manufactured and reproducible. Equally reflective to different beam angles. However, they bear negligible size relationship to most critical defects. |
| Flat-bottom hole at testing angle | Difficult to manufacture and requires good angular agreement of drilled hole with testing angle. |
| Surface notches | Square notches simulate cracks at surface. V-notch half-angle should complement beam angle for maximum response. |

8.3.2 *Angle-Beam Calibration*—Correction for angle-beam examination may be determined by means of side-drilled hole reflectors at $\frac{1}{4}$ and $\frac{3}{4}$ of the thickness. The $\frac{1}{2}$ -thickness depth to a side-drilled hole may be added to the calibration or used alone at thicknesses less than 1 in. (25.4 mm).

8.4 *Acceptable Techniques:*

8.4.1 *Distance-Amplitude Curve*—This method makes use of calibration blocks representing the minimum and maximum thickness to be tested. Additional calibration blocks of intermediate thicknesses can be used to obtain additional data points. The ultrasonic instrument, search unit, angle beam wedge, and couplant used for the distance-amplitude calibration must also be used for the weld examination.

8.4.1.1 Set the instrument to give an 80 % signal on the cathode ray screen from the highest amplitude obtained from the calibration reflectors. Test the other calibration reflectors with the same instrument settings, and either record or mark on the screen the percent of screen height of the indication.

8.4.1.2 Then use these recorded percentages to draw a distance-amplitude curve of percent screen height versus depth or thickness on a chart or on the screen. During examination the distance amplitude curve may be used to estimate indication amplitude in percent of the DA Curve.

8.4.2 *Electronic Distance Amplitude Correction*—This method can be used only if the instrument is provided with electronic distance amplitude compensation circuitry. Use is made of all reflectors in the calibration range. The testing equipment, search unit, couplant, etc., to be used in the ultrasonic examination are to be used for this attenuation adjustment.

8.4.2.1 Set the instrument to give a 50 % amplitude on the cathode ray screen from the reference reflector that gives the highest amplitude.

8.4.2.2 Test each reflector at other distances with the same instrument settings, but adjust electronic distance amplitude correction controls to give a 50 % screen height from the reference reflector for each successive thickness. Means of




FIG. 3 Supplementary Technique 2, for Inspecting Butt Welds for Suspected Cross-Cracking when the Weld Bead is Ground Flush




FIG. 4 Supplementary Technique 3, for Inspecting Butt Welds for Suspected Cross-Cracking when the Weld Bead is not Ground Flush




FIG. 5 Two-Search-Unit Technique 4, for Use with Thick Weldments





FIG. 2 Technique 1, for Inspecting Butt Welds with Angle Beams




FIG. 6 Technique 5, for Inspecting the Weld Volume of T-Welds

accomplishing the equalization of amplitude from equal-size reflectors over the distance range is best described for each instrument in the operating manual for that instrument.

9. Examination Procedures

9.1 Examination procedures recommended for common weld configurations are detailed in Table 2.

9.1.1 Special attention should be given to curved or contoured surfaces to ensure consistent ultrasonic beam entry angle and adequate coupling. Inspect circumferential welds using Techniques 12 and 13 (Fig. 12 and Fig. 13); inspect longitudinal welds using Techniques 14 and 15 (Fig. 14 and




FIG. 7 Technique 6, for Inspecting the Fusion Zone of T-Welds





FIG. 9 Technique 8, for Inspecting the Weld Volume of Double-Vee Corner Welds



8(a) Technique 7, for Searching T-Welds for Discontinuities




FIG. 8 (b) Alternative Technique 7, for Searching T-Welds for Discontinuities




FIG. 10 Technique 9, for Inspecting the Fusion Zone of Double-Vee Corner Welds

Fig. 15). Base choice of angle both on the radius of curvature and the thickness of the material in order to provide a beam that will travel through the material and reflect from the opposite surface.

9.1.2 When more than one technique is given for a particular weld geometry or thickness or both, the first technique is considered primary, while the additional techniques are supplementary and may be added to the inspection procedure.

10. Reflector Evaluation

10.1 *Reflector Location*—When distance calibration has been achieved in accordance with 6.1, approximate reflector location can be accomplished using the method of 6.1.2 or a chart of the type shown in Fig. 16.

10.2 Reflector Size and Orientation:

10.2.1 *Geometrical Methods*—Reflector length $\frac{1}{4}$ in. (6.4 mm) minimum can be measured by determining the points at which half (6 dB) of the amplitude is lost at the extremities of the reflector and measuring between them. Reflector height $\frac{1}{8}$ in. (3.2 mm) minimum can be measured by determining Δ SR (the change in sweep reading) at which half (6 dB) of the amplitude is lost as the search unit is moved to and from the reflector. The Δ SR \times 100 divided by tSR (through thickness sweep reading) approximates the reflector height in percent of thickness. Only the area of the reflector that reflects energy to the search unit is measured. See Fig. 17. This method is appropriate for reflectors with dimensions greater than the beam diameter. For reflectors smaller than the beam, significant errors may occur.

10.2.2 *Amplitude Methods*—Signal amplitude can be used as a measure of defect severity. Amplitude evaluation should be based upon experience with actual defects since artificially produced reflectors are not always directly relatable to real defect shapes or sizes. For adversely oriented planar defects, the amplitude may not indicate defect severity.

10.3 *Reflector Type*—In addition to the evaluation of location and size of reflectors, there are several other attributes




FIG. 11 Techniques 10 and 11, for Inspecting Full-Penetration Double-Fillet Corner Welds

which can be used to identify other types of reflectors. It must be emphasized that these methods are dependent on operator skill to such a degree that acceptance of welds based upon this type of information alone is not recommended.

10.3.1 *Reflector Orientation*—Reflector orientation can be deduced from relative signal amplitudes obtained from the reflector with the search unit placed at various locations on the weldment. An example is shown in Fig. 18.

10.3.2 *Reflector Shape*—Reflector shape and roughness will result in a characteristic degree of sharpness of the CRT trace deflection depending upon the nature of the defect, the instrument, and search-unit combination used.

11. Report

11.1 Each weld examination should be recorded on a report form which includes at least the following information:

11.1.1 Weld types and configurations tested, including thickness dimensions. Descriptive sketches are usually recommended.

11.1.2 Automatic defect alarm or recording equipment or both, if used.

11.1.3 Special search units, wedges, shoes, or saddles, if used.

11.1.4 Rotating, revolving scanning mechanisms, if used.

11.1.5 Stage of manufacture at which test was made.

11.1.6 Surface or surfaces from which the test was performed.

11.1.7 Surface finish.

11.1.8 Couplant.

11.1.9 Method used.

11.1.10 Technique used.

11.1.11 Description of the calibration method and method of correlating indications with defects.

11.1.12 Scanning.

11.1.13 Mode of transmission.

11.1.14 Type and size of transducer.

11.1.15 Test frequency.

11.1.16 Instrument identification information.

11.1.17 Defect description (depth, location, length, height, amplitude, and character).

11.1.18 Name of operator.

11.1.19 Date of inspection.

12. Keywords

12.1 NDT of weldments; nondestructive testing; ultrasonic contact examination; ultrasonic inspection; ultrasonic NDT of weldments; weldments

<https://standards.iteh.ai/catalog/standards/sist/a1a7e6a1-39fc-4996-81a3-cadc3c879291/astm-e164-97>

TABLE 2 Procedures Recommended for Common Weld Configurations


| Weld Type | Weld Throat Thickness | | | | | | | | | |
|-----------------------------------|----------------------------|----------|------------------------------|----------|-------------------------------|----------|-------------------------------|----------|-------------------------------|-------|
| | Less than ½ in. (12 mm) | | ½ to 1½ in. (12 to 38 mm) | | 1½ to 2½ in. (38 to 63 mm) | | 2½ to 5 in. (63 to 127 mm) | | 5 to 8 in. (127 to 200 mm) | |
| | Primary | Top ¼ | Primary | Top ¼ | Primary | Top ¼ | Primary | Top ¼ | Primary | Top ¼ |
| <i>Butt:</i> | | | | | | | | | | |
| Recommended angle, deg | 70 | 70 | 70 or 60 | 45 or 60 | 70, 60, or 45 | 45 or 60 | 60 or 45 | 45 or 60 | 60 or 45 | 45 |
| Suggested technique ^A | 1, (2 or 3) | 1 | 1, (2 or 3) | 1 | 1, (2 or 3) | 1 | 1, (2 or 3), 4 | 1 | 1, (2 or 3), 4 | 1 |
| <i>Tee:</i> | | | | | | | | | | |
| <i>Face A^B:</i> | | | | | | | | | | |
| Recommended angle, deg | 70 | | 70 or 60 | | 70, 60, or 45 | | 60 or 45 | | 45 | |
| Suggested technique | 5 | | 5 | | 5 | | 5, 4 | | 5, 4 | |
| <i>Face B^B:</i> | | | | | | | | | | |
| Recommended angle, deg | 70 | | 70 or 60 | | 70, 60, or 45 | | 60 or 45 | | 45 | |
| Suggested technique | 5 | | 5 | | 5 | | 5, 4 | | 5, 4 | |
| <i>Face C^B:</i> | | | | | | | | | | |
| Recommended angle, deg | straight, 70 | | straight (70 or 45) | | straight, 45 | | straight, 45 | | straight, 45 | |
| Suggested technique | 6, 7 | | 6, 7 | | 6, 7 | | 6, 7 | | 6, 7 | |
| <i>Corner:</i> | | | | | | | | | | |
| <i>Face A^C:</i> | | | | | | | | | | |
| Recommended angle, deg | 70 | | 70 or 60 | | 70, 60, or 45 | | 60 or 45 | | 45 | |
| Suggested technique | 8 | | 8 | | 8 | | 8 | | 8 | |
| <i>Face B^C:</i> | | | | | | | | | | |
| Recommended angle, deg | 70 | | 70 or 60 | | 70, 60, or 45 | | 60 or 45 | | 45 | |
| Suggested technique | 8 | | 8 | | 8 | | 8 | | 8 | |
| <i>Face C^C:</i> | | | | | | | | | | |
| Recommended angle, deg | straight | | straight | | straight | | straight | | straight | |
| Suggested technique | 9 | | 9 | | 9 | | 9 | | 9 | |
| <i>Double Fillet Corner Weld:</i> | | | | | | | | | | |
| <i>Face A^D:</i> | | | | | | | | | | |
| Recommended angle, deg | 45 | | 45 | | 45 | | 45 | | 45 | |
| Suggested technique | 10, 11 | | 10, 11 | | 10, 11 | | 10, 11 | | 10, 11 | |
| <i>Face B^D:</i> | | | | | | | | | | |
| Recommended angle, deg | 45 | | 45 | | 45 | | 45 | | 45 | |
| Suggested technique | 10,11 | | 10, 11 | | 10, 11 | | 10, 11 | | 10, 11 | |

^A See Figs. Figs. 2-11 for illustration of the techniques listed below.

^B Faces A, B, and C for tee welds are shown in Fig. 6.


^C Faces A, B, and C for corner welds are shown in Fig. 9.

^D Faces A and B for double fillet corner welds are shown in Fig. 11.



NOTE 1—Search-unit shoes are machined to match the curvature of the work piece when diameter is less than 20 in. (500 mm).


FIG. 12 Technique 12, for Inspecting Circumferential Welds



ARROWS INDICATE THE DIRECTION OF INSPECTION

NOTE 1—Search-unit shoes are machined to match the curvature of the work piece when diameter is less than 20 in. (500 mm).


FIG. 13 Supplementary Technique 13, for Inspecting Circumferential Welds, for Welds Ground Flush



ARROWS INDICATE THE DIRECTION OF INSPECTION

NOTE 1—Search-unit shoes are machined to match the curvature of the work piece when diameter is less than 20 in. (500 mm).

FIG. 15 Supplementary Technique 15, for Inspecting Longitudinal Welds, for Welds Ground Flush



ARROWS INDICATE THE DIRECTION OF INSPECTION

NOTE 1—Search-unit shoes are machined to match the curvature of the work piece when diameter is less than 20 in. (500 mm).

FIG. 14 Technique 14, for Inspecting Longitudinal Welds

Defect Distance Ahead of Sound Source Point




FIG. 16 Defect Location Chart

ASTM E 164 - 97




FIG. 17 Reflector Size Evaluation



- Testing from both sides of weld reveals defect orientation.

FIG. 18 Determination of Reflector Orientation

ANNEXES

(Mandatory Information)

A1. INSTRUCTIONS FOR USE OF INTERNATIONAL INSTITUTE OF WELDING (IIW) TYPE TEST BLOCKS AND OTHER CALIBRATION BLOCKS FOR ULTRASONIC TESTING

A1.1 Purpose

A1.1.1 *IIW Type Calibration Blocks*—To facilitate the adjustment and calibration of ultrasonic flaw-detecting equipment. The blocks can also be used to:

- A1.1.1.1 Calibrate the sweep length,
- A1.1.1.2 Adjust the pulse energy and amplification,

A1.1.1.3 Confirm the stability and proper operation of the equipment, or

A1.1.1.4 Determine transducer characteristics, such as their sensitivity, and in the case of angle-beam search units, the location of the beam exit point (beam index), the path length in the wedge, and the angle of refraction.

A1.1.2 *Supplementary Blocks*—Blocks other than those derived from the IIW Calibration Block 1, can be used for distance and sensitivity calibration. For details, see A1.5.

A1.2 Description

A1.2.1 The recommended configuration for an IIW-Type calibration block for use in this practice is shown in Fig. A1.1. Dimensions are given for a version in U.S. customary units, and for a metric version based on IIW, ISO, and some national standards. Material must be selected by the using parties. Unless otherwise specified, a low carbon steel such as UNS G10180 is suggested. An optional cylindrical acrylic plastic disk may be permanently mounted in the 2 in. (50 mm) diameter hole; it is not required for this practice.

NOTE A1.1—If the disk is provided it shall meet these requirements:
material—polymethylmethacrylate resin
thickness— 0.920 ± 0.005 in. (23 ± 0.1 mm)
surfaces—polished, flat within 0.002 in. (0.5 mm)
one surface to be mounted flush with a block face

A1.3 Distance Calibration

A1.3.1 *Straight-Beam Longitudinal Wave:*

A1.3.1.1 When calibrating the horizontal distance or sweep-length scale, adjust the multiple echoes obtained from a known length of the test block in such a way that the leading edges of the echoes (the left-hand side) coincide with the required divisions of the horizontal scale. In most instances, utilization of the highest possible frequency is recommended to produce sharp indications, thereby improving the accuracy of the distance calibration.

A1.3.1.2 As previously mentioned, the calibration is only valid if the materials to be tested are fabricated from a material with the same or approximately the same velocity of sound as the test block; for instance, a carbon steel calibration block should not be used when testing certain stainless steels. Furthermore, it should be realized that the initial pulse indication may not be a true representation of the entrant surface. When using the double search unit technique, it should be realized that the distances between the multiple echoes are not completely equal because of the different path lengths, which are inherent to this technique. When using the double search unit technique combined with another medium between transducer and specimen, an even larger distance between the initial pulse indication and the first echo, compared to the distance between the multiple echoes, will be observed. The two screen images for a 4-in. (100-mm) range setting, obtained when using the single search unit and the double search unit techniques are illustrated in Fig. A1.2.

A1.3.1.3 *Single Search Unit Technique*—To calibrate the sweep length when using a straight-beam longitudinal-wave search unit for a distance less than 10 in. (250 mm), place the search unit as indicated in Fig. A1.3 and adjust the distance between the multiple echoes to 4 in. (100 mm). To calibrate the sweep length when using a straight-beam longitudinal wave search unit for a distance greater than 10 in. (250 mm), place the search unit in the position indicated in Fig. A1.3. For the 20-in. (500-mm) range, a screen pattern will appear as shown in Fig. A1.4. This screen pattern also shows the indications

caused by shear waves generated by the mode conversion of the longitudinal waves and other reflections.

A1.3.2 *Using an Angle-Beam Search Unit for a Sweep Length from 4 to 10 in. (100 to 250 mm):*

A1.3.2.1 Place the search unit in the position indicated in Fig. A1.5 and use the echoes obtained from the curved surface (with a radius of 4 in. (100 mm) and the groove with a radius of 1 in. (25 mm). The sweep-length setting most commonly used is 10 in. (250 mm), whereby the screen pattern must be calibrated in such a way that the indication of the curved surface appears at 4 in. and the pulse indication of the groove appears at 9 in. (225 mm). The indication from the curved surface will be at its maximum amplitude when the beam index coincides with the center point of the curvature; verify this by moving the search unit back and forth, parallel to the sides of the calibration block. In this case, the groove echo can be received by slightly rotating the search unit. In most instances, the initial pulse indication will appear to the left of the scale zeropoint, caused by the delay in the wedge.

A1.3.2.2 It is also possible to calibrate the time base for shear waves for any material whose shear to longitudinal velocity ratio is 0.55 by placing a straight-beam longitudinal-wave search unit in the position indicated in Fig. A1.6. The multiple echoes obtained in this way will appear at distances that coincide with a sound path of 2 in. (50 mm) for shear waves. If the sweep length is calibrated in this manner, it is essential that subsequently the zeropoint be corrected if angle-beam search units are used, because of the time delay caused by the wedge. The above method can be used, for example, for calibrating a distance of 4 in. (100 mm), whereby the two multiple echoes obtained from the 3.64-in. (91-mm) distance are positioned at respectively 2 in. (50 mm) and 4 in. (100 mm) on the scale. After the angle beam shear wave search unit has been connected, correct the zeropoint by adjusting the sweep-delay control to position echo from 4-in. (100-mm) radius reflector, at position of second back reflections of the straight beam.

A1.3.3 *Using an Angle-Beam Search Unit for a Sweep Length Larger than 10 in. (250 mm)*—The same method can be used as described in A1.3.2; position a straight-beam longitudinal-wave search unit as illustrated in Fig. A1.6 and thereafter correct the zeropoint in a manner similar to A1.3.2.2.

A1.3.4 *Distance Calibration for the Sound Path, Projected on the Surface to be Scanned*—Place the search unit on the calibration block as indicated in Fig. A1.7 and correct the signal obtained from the edge of the block to coincide with the distance between the beam index and the edge of the block. A standard ruler may be used to measure the skip distances. For inch-dimensioned blocks, the ruler should be a minimum of 12 in. long with 0.1-in. or smaller divisions; for SI unit blocks, the ruler should be a minimum of 300 mm long with 2-mm or smaller divisions. Make adjustments for the skip distance and half of the skip distance. It should be noted that when utilizing angle-beam search units of approximately 60° , this calibration may be erroneous due to mode conversion.

A1.3.5 *Adjustment of Sensitivity*—When adjusting the sensitivity, take into consideration the following points:

A1.3.5.1 The frequency used.