



SLOVENSKI STANDARD

SIST EN 13126-3:2023

01-maj-2023

Nadomešča:
SIST EN 13126-3:2012

Stavbno okovje - Okovje za okna in zastekljena vrata - Zahteve in preskusne metode - 3. del: Ročaji, namenjeni predvsem za vrtljivo-nagibno, nagibno-vrtljivo in vrtljivo okovje

Building hardware - Hardware for windows and door-height windows - Requirements and test methods - Part 3: Handles, primarily for Tilt and Turn, Tilt-First and Turn-Only hardware

Baubeschläge - Beschläge für Fenster und Fenstertüren - Anforderungen und Prüfverfahren - Teil 3: Betätigungsgriffe, insbesondere für Drehkipp-, Kippdreh- und Drehbeschläge

Quincaillerie pour le bâtiment - Exigences et méthodes d'essai des ferrures de fenêtres et portes-fenêtres - Partie 3 : Poignées, ferrures d'oscillo-battant, de battant-oscillant et d'ouvrant pivotant

Ta slovenski standard je istoveten z: EN 13126-3:2023

ICS:

91.190 Stavbna oprema Building accessories

SIST EN 13126-3:2023 en,fr,de

EUROPEAN STANDARD

EN 13126-3

NORME EUROPÉENNE

EUROPÄISCHE NORM

February 2023

ICS 91.190

Supersedes EN 13126-3:2011

English Version

Building hardware - Hardware for windows and door-
height windows - Requirements and test methods - Part 3:
Handles, primarily for Tilt and Turn, Tilt-First and Turn-
Only hardware

Quincaillerie pour le bâtiment - Exigences et méthodes
d'essai des ferrures de fenêtres et portes-fenêtres -
Partie 3 : Poignées, ferrures d'oscillo-battant, de
battant-oscillant et d'ouvrant pivotant

Baubeschläge - Beschläge für Fenster und Fenstertüren
- Anforderungen und Prüfverfahren - Teil 3:
Betätigungsgriffe, insbesondere für Drehkipp-,
Kippdreh- und Drehbeschläge

This European Standard was approved by CEN on 2 January 2023.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

	Page
European foreword.....	4
Introduction	6
1 Scope.....	7
2 Normative references.....	7
3 Terms and definitions	7
4 Classification.....	9
4.1 General.....	9
4.2 Durability (1 - first box).....	9
4.3 Mass (2 - second box).....	9
4.4 Corrosion resistance (3 - third box)	9
4.5 Test sizes (4 - fourth box).....	10
4.6 Security against burglar attack (5 - fifth box)	10
4.7 Key related security (6 - sixth box).....	10
4.8 Handle type (7 - seventh box)	10
4.9 Category of use (8 - eighth box).....	10
4.10 Example of classification for window handles (EN 13126-3)	11
4.11 Transfer of the previous 7 th digit into the new classification system.....	11
5 Requirements.....	12
5.1 Dangerous substances.....	12
5.2 Category of use requirements	12
5.3 Operating torques, between-clicks torques, click torques and differential values	14
5.4 Durability	14
5.5 Fixed spindle connection (after durability test).....	14
5.6 Free play (after durability test)	14
5.7 Torsional strength	14
5.8 Tensile strength - eccentric.....	14
5.9 Corrosion resistance.....	15
5.10 Security	15
5.10.1 General.....	15
5.10.2 Durability of the locking mechanism.....	15
5.10.3 Torque resistance of the locking mechanism / Solid fixing.....	16
5.10.4 Twist-off resistance.....	16
5.10.5 Forcing off resistance	16
5.10.6 Locking variations / key related security	16
5.10.7 Spindle tensile strength.....	17
6 Test equipment and preparation of the test	17
7 Test procedure.....	17
7.1 General.....	17
7.2 Test specimens.....	17
7.3 Operating torques and click torques test.....	18
7.3.1 Preparation of samples.....	18
7.3.2 Test procedure	18
7.4 Durability test.....	18
7.5 Operating torques and click torques repeat test.....	18

7.6	Test of fixed spindle connection	19
7.7	Free play test.....	19
7.7.1	General	19
7.7.2	Free play – Perpendicular to the mounting plane	19
7.7.3	Free play – Parallel to the mounting plane	19
7.8	Torsional strength test.....	19
7.9	Tensile strength test – eccentric	19
7.10	Corrosion resistance test.....	20
7.11	Locking mechanism durability test.....	20
7.12	Torque resistance of the locking mechanism / Solid fixing test.....	20
7.13	Test - Resistance against twisting-off and forcing-off	20
7.14	Spindle tensile strength test.....	21
8	Marking	21
Annex A (normative) Test flow charts		22
Annex B (informative) Figures.....		24
Bibliography		28

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 13126-3:2023](https://standards.iteh.ai/catalog/standards/sist/f7b4a78e-e0bc-43d3-98c5-58d7882a6954/sist-en-13126-3-2023)

<https://standards.iteh.ai/catalog/standards/sist/f7b4a78e-e0bc-43d3-98c5-58d7882a6954/sist-en-13126-3-2023>

EN 13126-3:2023 (E)**European foreword**

This document (EN 13126-3:2023) has been prepared by Technical Committee CEN/TC 33 “Doors, windows, shutters, building hardware and curtain walling”, the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2023, and conflicting national standards shall be withdrawn at the latest by August 2023.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 13126-3:2011.

In comparison with the previous edition, the following technical modifications have been made:

- EN 13126-3 is now independent from EN 13126-1; all necessary information is included without the need of any further information from EN 13126-1;
- several editorial changings in the wording were made for a better understanding;
- terms 3.5 'locking mechanism', 3.6 'non-key-operated locking mechanism', 3.15 'sample' and 3.16 'test rig' were added and term 3.6 'key-operated locking mechanism' was modified for better understanding;
- in 4.1, the classification system changed completely; former digits 1 (Category of use), 4 (Fire resistance), 5 (Safety in use) and 8 (Application) were deleted; former digit 2 changed into box 1 (Durability), former digit 3 changed into box 2 (Mass), former digit 6 changed into box 3 (Corrosion resistance), former digit 9 changed into box 4 (Test sizes); former digit 7 changed into box 5 (Security against burglar attack) and a new box 6 (Key related security) was added;
- in 4.2, new Grades for the number of cycles are defined; H1 (5 000), H2 (10 000) and H3 (20 000), see also 5.4;
- in 4.10, a new example was added for the new classification;
- in 5.4, new Grades for the number of cycles are defined; H1 (5 000), H2 (10 000) and H3 (20 000) in accordance with 4.2 established;
- in 5.4, the number of cycles were adapted to the newly defined Grades for the durability;
- in 5.10.6, the subclause 'Locking variations / key related security' was modified in accordance with 4.7 (requirement in grade 2 changed from ' ≤ 99 ' into ' ≥ 25 and ≤ 99 ');;
- in Clause 6, the title has been modified to “...and preparation for the test”;
- in Clause 8, a new clause was added regarding marking with information from the current version of EN 13126-1.

The EN 13126 series, *Building hardware — Hardware for windows and door height windows — Requirements and test methods* consists of the following parts:

- *Part 1: Requirements common to all types of hardware;*
- *Part 2: Window fastener handles;*
- *Part 3: Handles, primarily for Tilt and Turn, Tilt-First and Turn-Only hardware;*
- *Part 4: Espagnolettes;*
- *Part 5: Devices that restrict the opening of windows and door height windows;*
- *Part 6: Variable geometry stay hinges (with or without a friction stay);*
- *Part 7: Finger catches;*
- *Part 8: Requirements and test methods for Tilt and Turn, Tilt-First and Turn-Only hardware;*
- *Part 9: Hardware for horizontal and vertical pivot windows;*
- *Part 10: Arm-balancing systems;*
- *Part 11: Top hung projecting reversible hardware;*
- *Part 12: Side hung projecting reversible hardware;*
- *Part 13: Sash balances;*
- *Part 14: Sash fasteners;*
- *Part 15: Rollers for horizontal sliding and hardware for sliding folding windows;*
- *Part 16: Hardware for Lift and Slide windows;*
- *Part 17: Hardware for Tilt and Slide windows;*
- *Part 19: Sliding Closing Devices.*

A full contribution to the preparation of this document series has been made by the European manufacturers' organization "ARGE" and national standards bodies.

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

EN 13126-3:2023 (E)

Introduction

The performance tests incorporated in this document are considered to be reproducible and as such will provide a consistent and objective assessment of the performance of these products throughout CEN Member States.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 13126-3:2023](https://standards.iteh.ai/catalog/standards/sist/f7b4a78e-e0bc-43d3-98c5-58d7882a6954/sist-en-13126-3-2023)

<https://standards.iteh.ai/catalog/standards/sist/f7b4a78e-e0bc-43d3-98c5-58d7882a6954/sist-en-13126-3-2023>

1 Scope

This part of the EN 13126 series specifies the requirements and test procedures for durability, strength, security and functionality of handles.

This document is applicable to Tilt and Turn, Tilt-First and Turn-Only hardware for use on windows and door-height windows.

Handles can also be used on other opening types, e.g. on In-line Sliding, Tilt and Slide, Sliding Folding, horizontal and vertical-pivoting windows.

This document is not applicable to:

- a) operation devices, door handles for door latches and door locks (for this, refer to EN 1906);
- b) handles with handle length > 170 mm (refer to Figure B.1).

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1627, *Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglar resistance - Requirements and classification*

EN 1670, *Building hardware - Corrosion resistance - Requirements and test methods*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp/ui>

3.1

handle

operating device with or without click mechanism, and where applicable with locking mechanism, with which the window hardware can be mechanically operated

3.2

window handle

operating mechanism with which the window hardware can be mechanically operated and a spindle that serves as the connecting element

3.3

geared-handle

operating mechanism with which the window hardware can be mechanically operated and a connector or fork that serves as the connecting element

3.4

click mechanism

assembly of components to position the handle in the defined click positions that correspond with the Tilt and Turn hardware's operation positions

EN 13126-3:2023 (E)

3.5

locking mechanism

assembly of components for securing the handle in a set position by preventing a further movement

3.6

non-key-operated locking mechanism

assembly of components for securing the handle's set position, enabling the further operation without appropriate means

Note 1 to entry: Some examples of non-key-operated locking mechanisms are designs with the deactivation of the locking mechanism by 'push-to-open', button- or thumb-operation.

3.7

key-operated locking mechanism

assembly of components for securing the handle's set position, enabling the further operation only with appropriate means (e.g. a key)

3.8

operating torque

M

required torque to rotate a handle without click mechanism

3.9

click-out torque

M_a

required torque to rotate a handle out of a click position

3.10

between-clicks torque

M_0

required torque to rotate a handle between the click positions

3.11

differential value

M_d

difference between the minimum "click-out torque" and the maximum "between-clicks torque"

Note 1 to entry: The equation is: $M_d = M_{a \min} - M_{0 \max}$

3.12

rosette

<for windows> screw-fixed base body located on the window profile that serves as a rotatable window handle mounting

3.13

spindle

connecting element to transfer the torque from the window handle to the rotatable part of the window espagnolette

Note 1 to entry: Square spindles are very common, but other shaped spindles are also permissible.

3.14 connector fork

connecting element, which transfers the torque from the handle to the slidable part of the window hardware

Note 1 to entry: Otherwise known as engaging piece, tongue or slider.

3.15 sample

hardware component to be tested

3.16 test-rig

testing device onto which the sample is mounted

4 Classification

4.1 General

Window handles, primarily for Tilt and Turn, Tilt-First and Turn-Only hardware shall be classified with the eight-box classification system (see Table 1).

Table 1 — Classification system

Box	1	2	3	4	5	6	7	8
Characteristic	Durability	Mass	Corrosion resistance	Test sizes	Security against burglar attack	Key related security	Handle Type	Category of use

4.2 Durability (1 – first box)

The first box shall display the Grade applied to the durability test with an extension for the designated operational cycle. “90” for the Turn-Only cycle and “180” for the Tilt and Turn cycle in accordance with the following requirements:

- Grade H1/90 5 000 Turn-Only cycles
- Grade H2/90 10 000 Turn-Only cycles
- Grade H3/90 20 000 Turn-Only cycles
- Grade H1/180 5 000 Tilt and Turn cycles
- Grade H2/180 10 000 Tilt and Turn cycles
- Grade H3/180 20 000 Tilt and Turn cycles

4.3 Mass (2 – second box)

No requirements, the second box shall display the digit 0.

4.4 Corrosion resistance (3 – third box)

The third box shall display the Grade regarding corrosion resistance in accordance with 5.9.

EN 13126-3:2023 (E)**4.5 Test sizes (4 – fourth box)**

No requirements, the fourth box shall display the digit 0.

4.6 Security against burglar attack (5 – fifth box)

The fifth box shall display the Grade of the security against burglar attack:

- Grade 0: without security against burglar attack
- Grade 1: 35 Nm resistance against twisting-off and forcing-off
- Grade 2: 100 Nm resistance against twisting-off and forcing-off
- Grade 3: 200 Nm resistance against twisting-off and forcing-off

4.7 Key related security (6 – sixth box)

The sixth box shall display the Grade of the key related security:

- Grade 0: no locking mechanism
- Grade 1: non-key-operated locking mechanism (e.g. 'PTO': Push-to-open)
- Grade 2: key-operated locking mechanism with ≥ 25 and ≤ 99 locking variations
- Grade 3: key-operated locking mechanism with ≥ 100 locking variations

4.8 Handle type (7 – seventh box)

The seventh box shall display the handle type as described following and in Table 2.

- Application N: Non-clickable
- Application C: Clickable
- Handle design 1: Window handle
- Handle design 2: Geared handle

Table 2 — Handle Type

Grade	Application C = Clickable / N = Non-clickable	Handle design 1 = window handle / 2 = geared handle
N1	N	1
N2	N	2
C1	C	1
C2	C	2

4.9 Category of use (8 – eighth box)

The eighth box shall display the Grade in accordance with Table 5.