



**SLOVENSKI STANDARD**  
**SIST EN 16925:2019/AC:2020**

**01-julij-2020**

---

**Vgrajeni gasilni sistemi - Avtomatski sprinklerski sistemi za bivalne površine -  
Načrtovanje, vgradnja in vzdrževanje**

Fixed firefighting systems - Automatic residential sprinkler systems - Design, installation and maintenance

Ortsfeste Brandbekämpfungsanlagen - Automatische Sprinkleranlagen für Wohnbereiche - Planung, Installation und Instandhaltung

Installations fixes de lutte contre l'incendie - Systèmes d'extinction automatiques du type sprinkleur résidentiel - Conception, installation et maintenance

<https://standards.iteh.ai/catalog/standards/sist/9a43eee2-4c64-4853-94b3-118bb0d92d7a/sist-en-16925:2019/AC:2020>

**Ta slovenski standard je istoveten z: EN 16925:2018/AC:2020**

---

**ICS:**

13.220.20      Požarna zaščita      Fire protection

**SIST EN 16925:2019/AC:2020**      **en,fr,de**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

SIST EN 16925:2019/AC:2020

<https://standards.iteh.ai/catalog/standards/sist/9a43eee2-4c64-4853-94b3-1b8bb0d92d7a/sist-en-16925-2019-ac-2020>

EUROPEAN STANDARD

EN 16925:2018/AC

NORME EUROPÉENNE

April 2020

EUROPÄISCHE NORM

ICS 13.220.20

English version

Fixed firefighting systems - Automatic residential sprinkler systems - Design,  
installation and maintenance

Installations fixes de lutte contre l'incendie -  
Systèmes d'extinction automatiques du type  
sprinkleur résidentiel - Conception,  
installation et maintenance

Ortsfeste Brandbekämpfungsanlagen -  
Automatische Sprinkleranlagen für  
Wohnbereiche - Planung, Installation und  
Instandhaltung

This corrigendum becomes effective on 29 April 2020 for incorporation in the official English version of the EN.

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 16925:2019/AC:2020](https://standards.iteh.ai/catalog/standards/sist/9a43eee2-4c64-4853-94b3-1b8bb0d92d7a/sist-en-16925-2019-ac-2020)

<https://standards.iteh.ai/catalog/standards/sist/9a43eee2-4c64-4853-94b3-1b8bb0d92d7a/sist-en-16925-2019-ac-2020>



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

© 2020 CEN All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.  
Tous droits d'exploitation sous quelque forme et de quelque manière que ce soit réservés dans le monde entier  
aux membres nationaux du CEN.  
Alle Rechte der Verwertung, gleich in welcher Form und in welchem Verfahren, sind weltweit den nationalen  
Mitgliedern von CEN vorbehalten.

Ref. No.: EN 16925:2018/AC:2020 E

EN 16925:2018/AC:2020 (E)

## 1 Modification to Table 6 — Sidewall sprinkler distances and maximum depth of an obstruction located perpendicular to the direction of throw

Replace Table 6 with the following: “

Distance from sidewall sprinkler to side of obstruction (A)	Maximum allowable distance of deflector above bottom of obstruction (B)
Less than 450 mm	0
450 mm to less than 900 mm	25 mm
900 mm to less than 1 200 mm	75 mm
1 200 mm to less than 1 350 mm	125 mm
1 350 mm to less than 1 800 mm	175 mm
1 800 mm to less than 1 950 mm	225 mm
1 950 mm to less than 2 100 mm	275 mm
2 100 mm to less than 2 250 mm	350 mm

”.

## 2 Modification to Table 7 — Position of sidewall sprinklers to avoid obstacles to discharge

Replace Table 7 with the following: “

Distance from sidewall sprinkler to side of obstruction (A)	Maximum allowable distance of deflector above bottom of obstruction (B)
Less than 2,4 m	Not allowed
2,4 m to less than 3 m	25 mm
3 m to less than 3,3 m	50 mm
3,3 m to less than 3,6 m	75 mm
3,6 m to less than 3,9 m	100 mm
3,9 m to less than 4,2 m	150 mm
4,2 m to less than 4,5 m	175 mm
4,5 m to less than 4,8 m	225 mm
4,8 m to less than 5,1 m	275 mm
5,1 m or greater	350 mm

”.