



SLOVENSKI STANDARD SIST ISO 21741:2021

01-maj-2021

Emisije nepremičnih virov - Vzorčenje in določevanje živosrebrih spojin v odpadnih plinih z amalgamacijo na zlatih pasteh

Stationary source emissions - Sampling and determination of mercury compounds in flue gas using gold amalgamation trap

iTeh STANDARD PREVIEW

Émissions de sources fixes - Échantillonnage et détermination de la teneur en mercure dans les gaz de combustion en utilisant un piège d'amalgamation de l'or

[SIST ISO 21741:2021](http://standards.itih.si/catalog/stanards/SIST_ISO/21741-2021)

Ta slovenski standard je istoveten z: [SIST ISO 21741:2021](http://standards.itih.si/catalog/stanards/SIST_ISO/21741-2021) [ISO 21741:2020](http://standards.itih.si/catalog/stanards/SIST_ISO/21741-2021)
http://standards.itih.si/catalog/stanards/SIST_ISO/21741-2021 <https://doi.org/10.25504/2501-4125-aaba-6c3fa72b9a52/sist-iso-21741-2021>

ICS:

13.040.40 Emisije nepremičnih virov Stationary source emissions

SIST ISO 21741:2021

en,fr

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST ISO 21741:2021](#)

<https://standards.iteh.ai/catalog/standards/sist/3d9edf94-36fe-4125-aaba-6c3fa72b9a52/sist-iso-21741-2021>

INTERNATIONAL
STANDARD

ISO
21741

First edition
2020-11

**Stationary source emissions —
Sampling and determination of
mercury compounds in flue gas using
gold amalgamation trap**

*Émissions de sources fixes — Échantillonnage et détermination de la
teneur en mercure dans les gaz de combustion en utilisant un piège
d'amalgamation de l'or*

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST ISO 21741:2021](https://standards.iteh.ai/catalog/standards/sist/3d9edf94-36fe-4125-aaba-6c3fa72b9a52/sist-iso-21741-2021)

<https://standards.iteh.ai/catalog/standards/sist/3d9edf94-36fe-4125-aaba-6c3fa72b9a52/sist-iso-21741-2021>



Reference number
ISO 21741:2020(E)

© ISO 2020

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST ISO 21741:2021

<https://standards.iteh.ai/catalog/standards/sist/3d9edf94-36fe-4125-aaba-6c3fa72b9a52/sist-iso-21741-2021>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	v
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Symbols and abbreviated terms	2
4.1 Symbols.....	2
4.2 Abbreviated terms.....	4
5 Principle	4
6 Reagents	4
6.1 General.....	4
6.2 Water.....	5
6.3 Nitric acid.....	5
6.4 Sulfuric acid.....	5
6.5 Stannous chloride solution.....	5
6.6 Phosphate buffer solution.....	5
6.7 Hydrofluoric acid.....	5
6.8 Hydrochloric acid.....	5
6.9 Mercury stock solution.....	5
6.10 Rinse solution.....	5
6.11 Sample gas drying agent.....	5
6.12 Trapping agent of mercury.....	6
7 Apparatus	6
7.1 General.....	6
7.1.1 Main-stream sampling.....	6
7.1.2 Side-stream sampling.....	8
7.2 Nozzle.....	9
7.3 Filter and filter housing.....	9
7.4 Transfer line.....	10
7.5 Pretreatment unit.....	10
7.6 Gold amalgamation trap.....	11
7.7 Drying unit.....	11
7.8 Suction unit.....	11
7.9 Thermometer.....	11
7.10 Manometer.....	12
7.11 Gas meter.....	12
7.12 Flowmeter.....	12
7.13 Barometer.....	12
8 Sampling	12
8.1 General.....	12
8.2 Sampling position and sampling point.....	12
8.3 Sampling duration and sample volume.....	12
8.4 Other measurements to be made prior to sampling.....	13
8.4.1 Volumetric gas flow through duct at the sampling plane.....	13
8.4.2 Moisture content of gas.....	13
8.4.3 Oxygen content of gas.....	13
8.5 Assembly of sampling apparatus.....	13
8.6 Sampling.....	13
8.7 Checking for leaks.....	14
8.8 Quality assurance.....	14
8.9 Sample recovery.....	14

ISO 21741:2020(E)

8.10	Reagent blank.....	15
8.11	Field blank.....	15
9	Sample preparation.....	15
9.1	General.....	15
9.2	Sample preparation for particulate mercury analysis.....	15
10	Analytical procedure.....	16
10.1	Analytical procedure for mercury collected with gold amalgamation trap.....	16
10.2	Analytical procedure for mercury in rinse solution and digested solution.....	17
11	Expression of results.....	17
11.1	Calculation of the volume of dry flue gas sampled at sampling conditions.....	17
11.2	Calculation of the volume of dry flue gas sample normalized to standard temperature and pressure.....	18
11.3	Mass concentration of mercury expressed as elemental mercury in the flue gas on a dry basis at STP.....	18
11.4	Mass concentration of mercury expressed as elemental mercury in the flue gas on a dry basis at STP and reference oxygen volume fraction.....	20
11.5	Rate of mass discharge of mercury expressed as elemental mercury.....	20
11.6	Mass concentration of mercury expressed as elemental mercury in the flue gas on a wet basis at STP.....	20
11.7	Mass concentration of mercury expressed as elemental mercury in the flue gas on a wet basis at STP and reference oxygen concentration.....	21
12	Performance characteristics.....	21
12.1	Detection limits.....	21
12.2	Evaluation of measurement uncertainty.....	21
13	Test report.....	22
Annex A (informative)	Preparation of mercury reference gas.....	24
Annex B (informative)	Results of evaluation of measurement uncertainties.....	27
Annex C (informative)	Comparison of analytical results obtained with heated solid catalytic reduction unit and stannous chloride solution unit.....	29
Annex D (informative)	Comparison of analytical results obtained with this method and EN 13211.....	31
Annex E (informative)	Interference from sulfur dioxide (SO₂) on the recovery of elemental mercury and oxidized mercury.....	33
	Bibliography.....	35

iTech STANDARD PREVIEW
(standards.iteh.ai)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html (standards.iteh.ai)

This document was prepared by Technical Committee ISO/TC 146, *Air quality*, Subcommittee SC 1, *Stationary source emissions*.

<https://standards.iteh.ai/catalog/standards/sist/3d9edf94-36fe-4125-aaba-d367319f3710-iso-21741-2021>

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Because mercury is exhausted from stationary sources such as coal combustion plants, cement kilns, non-ferrous metal smelting operations and roasting plants, and waste incineration facilities, the monitoring of the stationary source mercury mass emissions is increasingly important for preventing global environmental pollution and health damage caused by mercury.

This document describes a method for the sampling and determination of mercury concentrations in a flue gas passing through ducts or chimney stacks. Mercury generally exists as elemental (Hg^0) and oxidized (Hg^{2+}) forms, both in vapour and in solid phases in flue gases, this method allows the determination of both total vapour-phase mercury and total solid-phase mercury concentrations in flue gases.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST ISO 21741:2021](https://standards.iteh.ai/catalog/standards/sist/3d9edf94-36fe-4125-aaba-6c3fa72b9a52/sist-iso-21741-2021)

<https://standards.iteh.ai/catalog/standards/sist/3d9edf94-36fe-4125-aaba-6c3fa72b9a52/sist-iso-21741-2021>

Stationary source emissions — Sampling and determination of mercury compounds in flue gas using gold amalgamation trap

1 Scope

This document describes a method for the sampling and measurement of mercury of both vapour and solid phases on stationary source flue gas streams. Mercury generally exists as elemental (Hg^0) and oxidized (Hg^{2+}) forms, both in the vapour and solid phases in flue gases. The vapour-phase (gaseous) mercury is captured either isokinetically or non-isokinetically with a gold amalgamation trap after removing solid-phase (particulate) mercury with a filter. Because gold amalgamation trap captures only gaseous elemental mercury, the oxidized mercury (Hg^{2+}) in the vapour phase is converted to elemental mercury (Hg^0) prior to the gold amalgamation trap. The concentration of gaseous mercury is determined using atomic absorption spectrometry (AAS) or atomic fluorescence spectrometry (AFS) after releasing mercury by heating the gold amalgamation trap. Separately, particulate mercury is collected isokinetically on a filter and the concentration is determined using cold vapour AAS or cold vapour AFS after dissolving the particulate mercury into solution.

The total concentration of mercury in flue gas is expressed as the sum of both gaseous and particulate mercury concentrations.

The gold amalgamation method is intended for short-term (periodic) measurements of gaseous mercury ranging from $0,01 \mu\text{g}/\text{m}^3$ to $100 \mu\text{g}/\text{m}^3$ with sampling volumes from $0,005 \text{ m}^3$ to $0,1 \text{ m}^3$ and sample gas flow rate between $0,2 \text{ l}/\text{min}$ to $1 \text{ l}/\text{min}$. The measurement range of particulate mercury is typically from $0,01 \mu\text{g}/\text{m}^3$ to $100 \mu\text{g}/\text{m}^3$ with sampling volume from $0,05 \text{ m}^3$ to 1 m^3 .

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3696, *Water for analytical laboratory use — Specification and test methods*

ISO 9096, *Stationary source emissions — Manual determination of mass concentration of particulate matter*

ISO 10396, *Stationary source emissions — Sampling for the automated determination of gas emission concentrations for permanently-installed monitoring systems*

ISO 12141, *Stationary source emissions — Determination of mass concentration of particulate matter (dust) at low concentrations — Manual gravimetric method*

ISO 12846:2012, *Water quality — Determination of mercury — Method using atomic absorption spectrometry (AAS) with and without enrichment*

ISO 16911-1, *Stationary source emissions — Manual and automatic determination of velocity and volume flow rate in ducts — Part 1: Manual reference method*

ISO 17852:2006, *Water quality — Determination of mercury — Method using atomic fluorescence spectrometry*

ISO 20988, *Air quality — Guidelines for estimating measurement uncertainty*

ISO 21741:2020(E)

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1
gaseous mercury
mercury existing both as elemental and oxidized forms passing through a filter having at least 99,5 % collection efficiency for 0,3 µm diameter particles

3.2
particulate mercury
mercury existing both as elemental and oxidized forms contained in a solid phase particle collected by a filter having at least 99,5 % collection efficiency for 0,3 µm diameter particles

3.3
isokinetic sampling
sampling at a flow rate such that the velocity and direction of the gas entering the sampling nozzle are the same as those of the gas in the duct at the *sampling point* (3.4)

3.4
sampling point
specific position on the sampling section at which a sample is extracted

3.5
STP
standard conditions for temperature, 273,15 K, and pressure, 101,325 kPa

4 Symbols and abbreviated terms

4.1 Symbols

$M_{A1,Hg}$	amounts of mercury in the first gold amalgamation trap (µg)
$M_{A2,Hg}$	amounts of mercury in the second gold amalgamation trap (µg)
$C_{R,Hg}$	concentration of mercury in a prepared sample of rinse solution that washed the transfer line from the filter housing to the impinger nozzle of stannous chloride solution or the inlet of catalytic reduction unit in main-stream sampling (µg/ml). Ref. Figure 1 and 2 .
$C_{R1,Hg}$	concentration of mercury in a prepared sample of rinse solution that washed transfer line from the filter housing to the T-piece in side-stream sampling (µg/ml). Ref. Figure 3 .
$C_{R2,Hg}$	concentration of mercury in a prepared sample of rinse solution that washed transfer line after the T-piece to the impinger nozzle of stannous chloride solution or the inlet of catalytic reduction unit in side-stream sampling (µg/ml). Ref. Figure 3 .
$C_{S,Hg}$	concentration of mercury in a prepared sample solution for particulate mercury analysis (µg/ml)
d	density of reagent solution (g/ml)
p_{atm}	atmospheric pressure (kPa)

p_{av}	average pressure difference between the sample gas before the gas meter and the atmosphere (kPa)
$q_{m,Hg}$	rate of mass discharge of mercury expressed as elemental mercury (mg/s)
$q_{V,fg,i}$	volume flow rate of flue gas through the sampling plane at conditions <i>i</i> of temperature, pressure, moisture and oxygen content (m ³ /s)
T_{av}	average temperature of the sample gas before the gas meter (K)
$u(y)$	standard uncertainty (µg/m ³)
V_d	volume of dry flue gas sample normalized to STP (m ³)
V_f	final gas meter reading at the end of sampling (m ³)
$V_{G,d}$	volume of dry flue gas sample for gaseous mercury analysis normalized to STP (m ³)
V_i	initial gas meter reading at the beginning of sampling (m ³)
V_l	volume of air drawn through the gas meter during any intermediate leak tests (m ³)
V_m	volume of dry flue gas sample (m ³)
$V_{main,d}$	volume of dry flue gas sample in main stream, normalized to STP, in side-stream sampling (m ³)
$V_{S,d}$	volume of dry flue gas sample for particulate mercury analysis normalized to STP (m ³)
$V_{side,d}$	volume of dry flue gas sampled in side stream, normalized to STP, in side-stream sampling (m ³)
v_R	volume of a recovered sample of rinse solution that washed transfer line from the filter housing to the impinger nozzle of stannous chloride solution or the inlet of catalytic reduction unit in main-stream sampling (ml). Ref. Figure 1 and 2 .
v_{R1}	volume of a recovered sample of rinse solution that washed transfer line from the filter housing to the T-piece in side-stream sampling (ml). Ref. Figure 3 .
v_{R2}	volume of a recovered sample of rinse solution that washed transfer line after the T-piece to the impinger nozzle of stannous chloride solution or the inlet of catalytic reduction unit in side-stream sampling (ml). Ref. Figure 3 .
v_S	volume of a prepared sample solution for particulate mercury analysis (ml)
w_W	average moisture content of the flue gas at the sampling plane during the sampling period (%)
$y_{1,j}$	<i>j</i> th concentration value of the first measuring system (µg/m ³)
$y_{2,j}$	<i>j</i> th concentration value of the second measuring system (µg/m ³)
$\rho_{G,Hg,dry}$	mass concentration of gaseous mercury expressed as elemental mercury in the flue gas on a dry basis at STP (µg/m ³)
$\rho_{S,Hg,dry}$	mass concentration of particulate mercury expressed as elemental mercury in the flue gas on a dry basis at STP (µg/m ³)
$\rho_{Hg,dry}$	mass concentration of total mercury expressed as elemental mercury in the flue gas on a dry basis at STP (µg/m ³)

ISO 21741:2020(E)

$\rho_{\text{Hg,dry},0}$	mass concentration of mercury expressed as elemental mercury in the flue gas on a dry basis at STP and reference oxygen concentration ($\mu\text{g}/\text{m}^3$)
$\rho_{\text{Hg},i}$	mass concentration of mercury expressed as elemental mercury at conditions i of temperature, pressure, oxygen and moisture conditions ($\mu\text{g}/\text{m}^3$)
$\rho_{\text{Hg,wet}}$	mass concentration of mercury expressed as elemental mercury in the flue gas on a wet basis at STP ($\mu\text{g}/\text{m}^3$)
$\rho_{\text{Hg,wet},0}$	mass concentration of mercury expressed as elemental mercury in the flue gas on a wet basis at STP and reference oxygen concentration ($\mu\text{g}/\text{m}^3$)
$\varphi_{\text{O},d}$	volume fraction of the oxygen on a dry basis measured during the sampling (%)
$\varphi_{\text{O},\text{ref}}$	volume fraction of the reference oxygen for the process (%)

4.2 Abbreviated terms

AAS	atomic absorption spectrometry
AFS	atomic fluorescence spectrometry
FEP	perfluoro(ethylene/propylene), tetrafluoroethylene/hexafluoropropylene
PFA	perfluoroalkoxy alkane
PTFE	polytetrafluoroethylene

Iteh STANDARD PREVIEW
(standards.iteh.ai)

5 Principle

SIST ISO 21741:2021

<https://standards.iteh.ai/catalog/standards/sist/3d9edf94-36fe-4125-aaba-6e5fa726a52/sist-iso-21741-2021>

In flue gases, mercury commonly exists in both the vapour phase and solid phase. In this method, particulate mercury is captured on a filter, and gaseous mercury is captured on a gold amalgamation trap. The total concentration of mercury in a flue gas is expressed as the sum of both concentrations.

To determine particulate mercury contents in a flue gas, a sample is taken isokinetically and particles are collected on a filter in accordance with ISO 9096 or ISO 12141. The particulate mercury on the filter is dissolved into solution from the filter and the mercury concentration is determined using cold vapour atomic absorption spectrometry (CV AAS, ISO 12846) or cold vapour atomic fluorescence spectrometry (CV AFS, ISO 17852). The described digestion step for the liquid solutions in ISO 12846:2012, Clause 5, and ISO 17852:2006, Clause 7, is unnecessary and shall be omitted. After sample preparation (see 9.2 in this document), the samples are analysed immediately.

To determine gaseous mercury contents in a flue gas, a sample is taken either isokinetically or non-isokinetically. Gaseous elemental mercury that passes through the filter is captured on a gold amalgamation trap and gaseous oxidized mercury is converted to elemental mercury using either a stannous chloride solution or a heated catalytic reduction unit, and then collected on the gold amalgamation trap. The mercury amalgamated with the gold trap is released by heating the trap and determined using atomic absorption spectrometry (AAS) or atomic fluorescence spectrometry (AFS).

Particulate and gaseous sampling is performed simultaneously by the isokinetic sampling procedure if the flow rates and the total sampling volumes for the measurements of particulate and gaseous mercury are the same.

6 Reagents**6.1 General**

To carry out the method, the following reagents are required to be of a recognized analytical grade.

6.2 Water

Conforming with grade 1 specified in ISO 3696 for all sample preparation and dilutions.

6.3 Nitric acid

$w(\text{HNO}_3) = 65\%$, $d(\text{HNO}_3) = 1,4 \text{ g/ml}$.

NOTE Nitric acid is available both as $d(\text{HNO}_3) = 1,40 \text{ g/ml}$ [$w(\text{HNO}_3) = 650 \text{ g/kg}$] and $d(\text{HNO}_3) = 1,42 \text{ g/ml}$ [$w(\text{HNO}_3) = 690 \text{ g/kg}$].

6.4 Sulfuric acid

$c(\text{H}_2\text{SO}_4) = 0,5 \text{ mol/l}$.

Add slowly 28 ml of concentrated sulfuric acid [$d(\text{H}_2\text{SO}_4) = 1,84 \text{ g/ml}$] to a 1 000 ml volumetric flask containing approximately 500 ml of water while cooling and stirring, and then add water with stirring to make a volume of 1 000 ml.

6.5 Stannous chloride solution

$\rho(\text{SnCl}_2) = 100 \text{ g/l}$.

Add 60 ml of sulfuric acid (6.4) onto 10 g of tin (II) chloride dehydrate and heat it to dissolve while stirring them. After cooling, add sulfuric acid (6.4) to make a volume of 100 ml. This solution should be purged with inert gas such as argon and nitrogen prior to use to remove traces of Hg. This solution shall be used up within one week from preparation.

6.6 Phosphate buffer solution

$c(\text{KH}_2\text{PO}_4) = 0,025 \text{ mol/l}$ and $c(\text{Na}_2\text{HPO}_4) = 0,025 \text{ mol/l}$, pH6,86 at 298 K.

Take 3,39 g of potassium dihydrogen phosphate and 3,54 g of disodium hydrogen phosphate in a beaker and add water to dissolve them. Transfer the solution from the beaker to a 1 000 ml volumetric flask and add water to make a volume of 1 000 ml. Store it in a fluoroplastic bottle made of PTFE, PFA or FEP.

6.7 Hydrofluoric acid

$w(\text{HF}) = 40 \%$, $d(\text{HF}) = 1,16 \text{ g/ml}$.

6.8 Hydrochloric acid

$w(\text{HCl}) = 37 \%$, $d(\text{HCl}) = 1,19 \text{ g/ml}$.

6.9 Mercury stock solution

Conforming with mercury standard solutions as specified in ISO 12846 and ISO 17852.

6.10 Rinse solution

$w(\text{HNO}_3) = 50 \text{ g/kg}$.

Take 77 g of nitric acid [$w(\text{HNO}_3) = 650 \text{ g/kg}$] or 72 g of nitric acid [$w(\text{HNO}_3) = 690 \text{ g/kg}$] in a fluoroplastic bottle made of PTFE, PFA or FEP, and add water to make a total weight of 1 kg.

6.11 Sample gas drying agent

Self-indicating coarse grade silica gel.