

---

---

## Facility smart grid information model

*Modèle d'informations des réseaux électriques intelligents des installations*

iTeh Standards  
(<https://standards.iteh.ai>)  
Document Preview

ISO 17800:2017

<https://standards.iteh.ai/catalog/standards/iso/c14316bb-590b-4576-948a-8e950b8478d4/iso-17800-2017>



iTeh Standards  
(<https://standards.iteh.ai>)  
Document Preview

ISO 17800:2017

<https://standards.iteh.ai/catalog/standards/iso/c14316bb-590b-4576-948a-8e950b8478d4/iso-17800-2017>



**COPYRIGHT PROTECTED DOCUMENT**

© ISO 2017, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Ch. de Blandonnet 8 • CP 401  
CH-1214 Vernier, Geneva, Switzerland  
Tel. +41 22 749 01 11  
Fax +41 22 749 09 47  
[copyright@iso.org](mailto:copyright@iso.org)  
[www.iso.org](http://www.iso.org)

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. International Standards are drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by Technical Committee ISO/TC 205, *Building environment design*.

ISO 17800:2017

<https://standards.iteh.ai/catalog/standards/iso/c14316bb-590b-4576-948a-8e950b8478d4/iso-17800-2017>

**ASHRAE Standard Project Committee 201**  
**Cognizant TC 1.4 Control Theory and Application**  
**TC 7.5 Smart Building Systems**  
**SPLS Liaisons: Steven Bruning, Hoy R. Bohanon, John Clark**

Steven T Bushby, <i>Chair*</i>	Mike Gibson	David R. Pospisil*
Stephen D. Kennedy, <i>Co-Vice Chair*</i>	Matt Gillmore	Bin Qui
Sharon Dinges, <i>Co-Vice Chair*</i>	Krishnan Gowri	Devin Rauss
Robert Hick, <i>Co-Vice Chair*</i>	David W. Guelfo	Steven Ray*
Robert J. Alvord	Jason M. Hanna	Tobin Richardson
Chandrashekhar Appanna*	Richard Harwell	Jeremy Roberts
Peter A. Baselici	Howard Holms	David Robin*
Timothy O. Beight	Joseph W. Hughes	Steven Rosenstock
Joel Bender*	Christopher Johnson	John I Ruiz*
Roger L. Boydston	Allen Jones*	Chantipal Sourignavong
James Butler	David Kaufman	Don Sturek
Matthew Bye	Christopher Kotting*	John Teeter*
Michael Coop	Chuck McParland	Natarajan Venkatakrishnan
Abigail Daken*	Richard Morgan	Kenneth Wacks*
Gregory M. Dobbs	John Nunneley	Eric Winkler*
Jonathan D. Douglas	Robert L. Old	Jacob Yackenovitch*
Amr E. Gado*	Mary Ann Piette	Scott Ziegenfus*

\* Denotes voting members at time of approval for publication.

**Consultants to the Project Committee**

Martin Burns	Jerald Martocci	Evan Wallace
Francis Cleveland		

ISO 17800:2017

<https://standards.iteh.ai/catalog/standards/iso/6143165b-590b-4576-948a-8e950b8478d4/iso-17800-2017>

**ASHRAE STANDARDS COMMITTEE 2015-2016**

Douglass T. Reindl, <i>Chair</i>	Steven J. Emmerich	Cyrus H. Nasser
Rita M. Harrold, <i>Vice-Chair</i>	Julie M. Ferguson	Heather L. Platt
James Dale Aswegan	Walter T. Grondzik	David Robin
Niels Bidstrup	Roger L. Hedrick	Peter Simmonds
Donald M. Brundage	Srinivas Katipamula	Dennis A. Stanke
John A. Clark	Rick A. Larson	Wayne H. Stoppelmoor, Jr.
Waller S. Clements	Lawrence C. Markel	Jack H. Zarour
John F. Dunlap	Arsen K. Melikov	Julia A. Keen, <i>BOD ExO</i>
James W. Earley, Jr.	Mark P. Modera	James K. Vallort, <i>CO</i>
Keith I. Emerson		

Stephanie C. Reiniche, *Senior Manager of Standards*

**SPECIAL NOTE**

This American National Standard (ANS) is a national voluntary consensus standard developed under the auspices of the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Consensus is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other members may or may not be members of ASHRAE, all must be technically qualified in the subject area of the standard. Every effort is made to balance the concerned interests on all Project Committees.

The Manager of Standards of ASHRAE should be contacted for:

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard,
- d. permission to reprint portions of the Standard.

#### OASIS DISCLAIMER

Excerpts from OASIS [WS-Calendar v1.0 Committee Specification 01] [and] [OASIS Energy Market Information Exchange (EMIX) v1.0 Committee Specification] are reprinted with permission from OASIS Open, and are Copyright © OASIS Open 2009-2012. All Rights Reserved.

[WS-Calendar][and][EMIX] [is]/[are] subject to the terms of the OASIS IPR Policy, and all capitalized terms in the following text have the meanings assigned to them in that Policy, which may be found at the OASIS website: <http://www.oasis-open.org/who/intellectualproperty.php>.

[WS-Calendar][and][EMIX] and translations thereof may be copied and furnished to others, and derivative works that comment on or otherwise explain it or assist in its implementation may be prepared, copied, published, and distributed, in whole or in part, without restriction of any kind, provided that the above copyright notice and this section are included on all such copies and derivative works.

[WS-Calendar][and][EMIX] and the information contained therein is provided on an "AS IS" basis and OASIS DISCLAIMS ALL WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY WARRANTY THAT THE USE OF THE INFORMATION HEREIN WILL NOT INFRINGE ANY OWNERSHIP RIGHTS OR ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. "

ISO 17800:2017

<https://standards.iteh.ai/catalog/standards/iso/c14316bb-590b-4576-948a-8e950b8478d4/iso-17800-2017>

**iTeh Standards**  
**(<https://standards.itih.ai>)**  
**Document Preview**

ISO 17800:2017

<https://standards.itih.ai/catalog/standards/iso/c14316bb-590b-4576-948a-8e950b8478d4/iso-17800-2017>

## CONTENTS

<b>FOREWORD</b> .....	iii
<b>INTRODUCTION</b> .....	viii
1. Purpose .....	1
2. Scope .....	1
3. Definitions .....	2
3.1. Terms Adopted from External Sources .....	2
3.2. Terms Defined for this Standard .....	3
3.3. Abbreviations and Acronyms Used in this Standard .....	5
4. FSGIM Structure and Usage .....	7
4.1. Overview .....	7
4.2. How the FSGIM Component Model can be Applied to Real-World Examples .....	9
5. Device and Model Components .....	14
5.1. Facility Model Overview Diagram .....	14
5.2. Device .....	18
5.3. Meter Component .....	29
5.4. Load Component .....	36
5.5. Generator Component .....	59
5.6. Energy Manager Component .....	94
5.7. Model Elements from External Sources .....	241
6. Common Primitive Types, Classes, and Enumerations .....	509
6.1. Time .....	509
6.2. Enumerations .....	510
6.3. Primitive Data Types .....	515
6.4. Measurements .....	516
6.5. Other Common Classes .....	548
6.6. Elements Defined in the Common Primitive Types, Classes, and Enumerations Model .....	551
7. Conformance Requirements .....	595
7.1. Introduction .....	595
7.2. Conformance Requirements .....	596
7.3. Conformance Blocks .....	599
8. References .....	815
9. Annex A – UML Model (Normative) .....	816

## INTRODUCTION

*The effort to substantially modernize and transform the national electric grid and create what has become known as a "smart grid" is an enormous undertaking that reflects both the size and importance of the electric grid. Viewed in its entirety, it is an international effort involving hundreds of organizations and companies, and it will impact billions of people. The standards infrastructure that will be needed to support this transformation may include over one hundred standards by the time that it is fully in place. This standard is one part of that infrastructure.*

*Almost all electricity is consumed in a building of some kind – homes, retail establishments, offices, schools, factories, hospitals – the list goes on. This standard attempts to capture the breadth and diversity of these consumers by using the term "facility." A facility is any kind of building or collection of buildings, and all of the electrical loads or local generation sources contained within them or controlled by the facility owner.*

*Historically, electricity consumption has been viewed as a collection of dumb loads at the end of a distribution system. There has been almost no interaction between the "loads" and those responsible for electricity generations and distribution. The vision of the smart grid changes this picture radically. In a smart grid world, facilities become full partners in supporting and managing the electric grid. Facilities become generators using local renewable or other generation capacity. Facilities moderate electrical demand in response to fluctuations in the price or availability of electricity. Facilities communicate and negotiate with energy providers, sharing information about the facility's projected electrical demand or ability to respond to the energy provider's needs for maintaining grid stability and reliability.*

*In some respects all facilities have common characteristics and needs with respect to interactions with a smart grid, regardless of whether the facility is a commercial, institutional, or industrial building, or a private home. The Facility Smart Grid Information Model (FSGIM) standard attempts to capture this commonality and standardize the content of the information that a facility manager needs to have, or, in some cases, needs to exchange with the energy provider, in order to manage the facility. Energy providers benefit from the FSGIM standard because it enables interaction with all different types of facilities in a common way. Facility owners benefit because products can be designed for use in multiple facility types and products designed primarily for one type of facility, a home for example, can more easily be used in another, say a commercial building.*

*An information model is an abstraction, not an implementation. This abstract representation is a way to account for the reality that the technology used to manage a facility may be quite different depending on the type of facility. It is intended that the FSGIM will be used to develop or enhance other standards that define technology and communication protocol specific implementations of the model for particular markets.*

*The FSGIM was developed in the context of a much larger framework of smart grid standards. It builds on some of those standards in a way that is intended to maintain consistency and harmony with established and developing standards that impact the information needed to managing the facility, while at the same time capturing all of the key information needed in one place.*

*If the smart grid is to become a reality there must be smart facilities of all types that interact with it. The considerable time and talent that went into developing the FSGIM was invested in order to lay a solid foundation upon which to fulfill this vision.*



## 1. PURPOSE

The purpose of this standard is to define an abstract, object-oriented information model to enable appliances and control systems in homes, buildings, and industrial facilities to manage electrical loads and generation sources in response to communication with a “smart” electrical grid and to communicate information about those electrical loads to utility and other electrical service providers.

## 2. SCOPE

This model provides the basis for common information exchange between control systems and end use devices found in single - and multi-family homes, commercial and institutional buildings, and industrial facilities that is independent of the communication protocol in use. It provides a common basis for electrical energy consumers to describe, manage, and communicate about electrical energy consumption and forecasts.

The model defines a comprehensive set of data objects and actions that support a wide range of energy management applications and electrical service provider interactions including:

- a) on-site generation,
- b) demand response,
- c) electrical storage,
- d) peak demand management,
- e) forward power usage estimation,
- f) load shedding capability estimation,
- g) end load monitoring (sub metering),
- h) power quality of service monitoring,
- i) utilization of historical energy consumption data, and
- j) direct load control.

**iTeh Standards**  
**(<https://standards.itih.ai>)**  
**Document Preview**

ISO 17800:2017

<https://standards.itih.ai/catalog/standards/iso/c14316bb-590b-4576-948a-8e950b8478d4/iso-17800-2017>

## 3. DEFINITIONS

See Clause 8 for external standards that are referenced by this standard.

### 3.1. Terms Adopted from External Sources

The following terms used in this standard are drawn from other standards or published reference sources. The definitions are repeated here and a reference to the appropriate standard or document is provided. Words or phrases in italics refer to terms defined elsewhere in this clause.

#### **asset**

A logical entity with measurable and reportable consumption, e.g., an *asset* may be a physical device with its own meter, or the main meter at the *service delivery point* of a service location.  
(NAESB 2010a).

#### **baseline**

A method of estimating the electricity that would have been consumed by a customer or *demand resource* in the absence of a *demand response event*. It may be calculated using interval metering and/or statistical sampling techniques.  
(NAESB 2010a).

#### **combined heat and power**

Combined heat and power (CHP), also known as cogeneration, is the simultaneous production of electricity and heat from a single fuel source, such as: natural gas, biomass, biogas, coal, waste heat, or oil.  
(<http://www.epa.gov/chp/basic/index.html>).

#### **electrical coupling point**

Point of electrical connection between the DER source of energy (generation or storage) and any electric power system (EPS). Each DER (generation or storage) unit has an ECP connecting it to its local power system; groups of DER units have an ECP where they interconnect to the power system at a specific site or plant; a group of DER units plus local loads have an ECP where they are interconnected to the utility power system.  
(IEC 61850 Part 7-420).

#### **energy management system**

A system used to monitor and control the energy consuming devices in a building. Within this standard, "energy management system" always refers to a customer/facility energy management system and not a utility energy management system.  
(EIS Alliance Use-Cases).

#### **non-spinning reserve**

1. That generating reserve not connected to the system but capable of serving demand within a specified time.  
2. Interruptible load that can be removed from the system in a specified time.  
(NERC Glossary).

#### **peak load**

The maximum amount of power delivered (*load*) for a given time period.  
(NEMA glossary (<http://www.nema.org/gov/energy/glossary/>)).

#### **power quality**

Characteristics of the electricity at a given point on an electrical system, evaluated against a set of reference technical parameters.

NOTE: These parameters might, in some cases, relate to the compatibility between electricity supplied on a network and the loads connected to that network.  
(IEC 61000-4-30 (2008)).

#### **pricing node (Pnode)**

A single network Node or subset of networked Nodes where a physical injection or withdrawal is modeled and for which a Locational Marginal Price is calculated and used for financial settlements.  
(CAISO Tariff).

#### **program administrator**

An investor-owned, governmental or cooperative distribution company with the responsibility for developing and operating specific programs.  
(NAESB REQ.0.2.179).

**spinning reserve**

Unloaded generation that is synchronized and ready to serve additional demand.  
(NERC Glossary).

**3.2. Terms Defined for this Standard****aggregated pricing node**

An *aggregated pricing node* is a location in the electric grid where the locational marginal price is calculated by a weighted average of one or more underlying *pricing nodes*.

**capacity restraint**

A limitation in the generating capacity or transmission capacity of an energy supplier that constrains the amount of electricity that is available to be bought or sold.

**Commercial Buildings Energy Consumption Survey**

A national sample survey that collects information on the stock of U.S. commercial buildings.

**control system**

A device or set of devices used to manage, command, direct, or regulate the behavior of other devices or systems.

**critical loads**

Individual *loads* deemed to be critical to the operation of the facility or process.

**critical peak period**

A time period during which a special high price for electricity is applied as a way to reduce demand.

**curtailable load**

Loads whose power consumption can be increased or decreased for the purpose of increasing or decreasing the total electrical demand on the grid.

**demand**

The rate at which energy is delivered to or used by a system or part of a system at a given instant in time or averaged over any designated interval of time.

**demand forecast**

Predictions regarding future electrical demand.

**demand interval**

The period of time over which an energy supplier calculates demand. Typical values range from five minutes to 60 minutes.

**demand resource**

A *load*, aggregation of loads, behind-the-meter generator, electrical storage system, or thermal storage system capable of providing measurable and verifiable *demand response*.

**demand response**

A temporary change in electricity usage by a *demand resource* in response to market or reliability conditions.

**demand response event**

A period of time defined by the *program administrator*, including notifications, deadlines, and transitions, during which *demand resources* provide *demand response*. All notifications, deadlines, and transitions may not be applicable to all *demand response* products or services.

**demand target**

Target in *demand* management; *peak demand* is a key factor in contract charges for electricity use.

**direct load control**

A *demand response* activity by which the *program administrator* remotely shuts down or cycles a customer's electrical equipment (e.g., air conditioner, water heater). Direct load control programs are primarily offered to residential or small commercial retail customers.

**dispatchable generator**

Generators whose power supply may be increased or decreased for the purpose of decreasing or increasing the total electrical demand on the grid.

**distributed energy resource**

A small, modular, energy generation or storage device located within the electrical distribution system at or near the end user. Distributed energy resources may be connected to the local electrical power grid (e.g., for voltage support) or isolated from the grid in standalone applications, such as part of a micro grid.

**emergency standby generation**

The provision of capacity deployed by the balancing authority to meet NERC and regional reliability organization contingency requirements.

**end device**

A physical end-use device that consumes or supplies electricity.

**energy consumption**

A measure of the quantity of electricity used in a given time period, measured in kilowatt hours.

**energy cost**

That portion of the charge for electric service based upon the electric energy (kWh) consumed or billed.

**energy emissions**

The pollution emissions associated with generating a quantity of electrical energy.

**energy information provider**

A business that provide energy supply or *demand* information to customers or authorized third parties.

**energy services company**

A business providing *energy* savings, efficiency, and *generation* solutions.

**energy services interface**

An abstract representation of a bi-directional communication interface between devices within a facility and an external electric *service provider*. This interface enables exchange of information including pricing, energy consumption, demand response interactions, load forecasts, energy production forecasts, and weather information.

**energy supplier**

An entity that delivers electricity to end use customers. Examples include investor-owned utilities, municipal utilities, and private companies.

**forward pricing forecast**

The compilation of prices of actual transactions for forward (future) delivery periods that are executed today.

**independent system operator**

An independent system operator maintains balance of the grid system by controlling the dispatch of plants and ensuring that loads match system resources. As such, the operator must be neutral and independent.

**intelligent end point**

A system that internally measures, collects, and analyzes its *energy cost*/consumption.

**load**

A device, system or process that consumes electrical energy.

**local codes**

Local laws, regulations, and building codes that determine building operation and capabilities.

**measurement and verification**

Energy measurements that can be determined to a degree of accuracy and trust that is acceptable to all stakeholders.

**net demand**

Total demand minus total supply. Net demand is determined at the facility interconnection point, billing meter, or internal location, and may be positive or negative.

**peak demand**

The highest measured *demand* encountered during a specified period of time (e.g., month, year, or finite set of time intervals).

**plug load**

A device that is powered by means of an electrical plug and matching socket or receptacle. This excludes devices that are accounted for as part of major building end uses such as HVAC, lighting systems, and water heating.

**present demand**

*Demand* occurring during the present *demand interval* or subinterval (e.g., Watts or VA).

**present subinterval demand**

Average rate of energy used over a small portion of a *demand interval*.

**present subinterval net demand**

Average net rate of energy used over a small portion of a *demand interval*.

**present subinterval supply**

Average rate of energy supplied over a small portion of a *demand interval*.

**ramp rate**

The rate at which a generator changes its output or a *demand resource* changes its demand.

**service delivery point**

The location where electric service is delivered to the facility.

**service level agreement**

A part of a service contract where the level of service is formally agreed upon.

**smart power distribution unit**

A device that measures and distributes electric power to an electrical circuit.

**smart power strip**

A power strip that measures electrical power being drawn by the connected equipment.

**supply**

The rate of energy generation or storage output that is used to serve facility load and possibly provided to the grid as a generation resource.

**time of use pricing**

A rate structure characterized by different prices for electricity use in a 24-hour time frame. Time of use pricing is generally used to encourage electricity use during periods of lower demand and discourage electricity use during periods of high demand.

**use case**

A story, told in structured and detailed steps, about how participants in an Application collaborate to reach a goal.

**variable generation**

Variable generation comprises any power generating device in which the source of the energy is not dispatchable and that the resource does not have control over its net power output. Variable generating devices include those powered by wind, solar, run of river hydro, tidal, wave, ocean thermal and other renewable resources.

**3.3. Abbreviations and Acronyms Used in this Standard**

<b>ASHRAE</b>	American Society of Heating, Refrigerating and Air-Conditioning Engineers
<b>CBECS</b>	<i>Commercial Buildings Energy Consumption Survey</i>
<b>CHP</b>	combined heat and power
<b>DER</b>	distributed energy resource
<b>ECP</b>	electrical coupling point
<b>EIP</b>	Energy Information Provider
<b>EM</b>	Energy Manager
<b>EMS</b>	energy management system
<b>ESCO</b>	energy services company

## ISO 17800:2017(E)

<b>ESI</b>	Energy Services Interface
<b>ESI EM</b>	Energy Services Interface Energy Manager
<b>ESP</b>	Energy Service Provider
<b>HMI</b>	human machine interface
<b>HVAC</b>	Heating, ventilating, and air conditioning
<b>IEP</b>	Intelligent End Point
<b>ISO</b>	International Organization for Standardization
<b>kW</b>	kilowatt
<b>M&amp;V</b>	Measurement and Verification
<b>OASIS</b>	(Organization for the Advancement of Structured Information Standards) is a not-for-profit consortium that drives the development, convergence and adoption of open standards for the global information society.
<b>RTO</b>	Regional Transmission Operator
<b>SCADA</b>	supervisory control and data acquisition
<b>SLA</b>	Service Level Agreement
<b>SP</b>	Service Provider
<b>SPDU</b>	Smart Power Distribution Unit
<b>SPS</b>	Smart Power Strip

**iTeh Standards**  
**(<https://standards.iteh.ai>)**  
**Document Preview**

[ISO 17800:2017](https://standards.iteh.ai/catalog/standards/iso/c14316bb-590b-4576-948a-8e950b8478d4/iso-17800-2017)

<https://standards.iteh.ai/catalog/standards/iso/c14316bb-590b-4576-948a-8e950b8478d4/iso-17800-2017>