

FINAL
DRAFT

INTERNATIONAL
STANDARD

ISO/FDIS
20560-2

ISO/TC 145/SC 2

Secretariat: DIN

Voting begins on:
2022-11-14

Voting terminates on:
2023-01-09

Safety information for the content of piping systems and tanks —

Part 2: Tanks

*Consignes de sécurité concernant le contenu des tuyauteries et des
réservoirs —*

Partie 2: Réservoirs

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 20560-2

<https://standards.iteh.ai/catalog/standards/sist/a80e92b9-a9cc-4e19-8a0f-afc6870fc760/iso-20560-2>

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.



Reference number
ISO/FDIS 20560-2:2022(E)

© ISO 2022

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 20560-2

<https://standards.iteh.ai/catalog/standards/sist/a80e92b9-a9cc-4e19-8a0f-afc6870fc760/iso-20560-2>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2022

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 General requirements	2
5 Elements of safety information systems for tanks	3
5.1 General.....	3
5.2 Content name.....	3
5.3 Warning signs and/or GHS pictograms.....	4
5.4 Tank identification.....	5
5.5 Capacity of the tank.....	5
5.6 Surface area of liquid in a tank.....	6
5.7 NFPA diamond.....	6
5.8 Hazard identification number (HIN) and UN number.....	7
5.9 Other codes or information.....	7
6 Dimensions of the tank marking elements	7
7 Installation of safety information system for tanks	7
7.1 General.....	7
7.2 Large tanks.....	8
7.3 Horizontal tanks.....	9
7.4 Multiple tanks.....	10
8 Maintenance, inspection and revision	10
Annex A (informative) Intervention service information	11
Annex B (informative) Basic identification colours	13
Annex C (informative) Examples of safety information systems for tanks	14
Annex D (informative) Distance factor for observing normal to the safety information system	16
Bibliography	17

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 145, *Graphical symbols*, Subcommittee SC 2, *Safety identification, signs, shapes, symbols and colours*.

A list of all parts in the ISO 20560 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Continuous growth in mobility of labour has resulted in a need to standardize a safety information system and form a coherent system for non-verbal exchange of information that consists of distinct elements to identify hazards related to the content of piping systems and tanks. Every element of the safety information system defined in this document communicates specific information. When combined on tanks, these elements inform the viewer, in a unique and simplified way, of potential hazards so accidents can be prevented and an appropriate response to emergency situations can be efficiently accomplished.

The use of this document is expected to reduce risk by providing a means of improved training and education to reduce possible confusion for people working with and near tanks in both normal and emergency situations.

The use of a standardized safety information system does not replace proper work methods, instructions or accident-prevention training or measures. Education is an essential part of any system that provides safety information.

NOTE Some countries' statutory regulations possibly differ in some respect from the requirements given in this document.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 20560-2

<https://standards.iteh.ai/catalog/standards/sist/a80e92b9-a9cc-4e19-8a0f-afc6870fc760/iso-20560-2>

Safety information for the content of piping systems and tanks —

Part 2: Tanks

IMPORTANT — The colours represented in the electronic file of this document can be neither viewed on screen nor printed as true representations. For the purposes of colour matching, see ISO 20560-1:2020, Annex A, which provides references from colour order systems.

1 Scope

This document specifies a safety information system for tanks made by combining several elements onto a single marking to communicate health and hazard safety information and information in case of an emergency for the purpose of accident prevention.

The organization's risk assessment will determine when and where this safety information system for tanks will be used. Possible applications include, but are not limited to:

- markings installed on or near fixed above-ground tanks;
- markings installed on portable tanks;
- markings installed on or near tanks used in production facilities, marine structures and ships;
- markings posted on or near interchangeable containers with fixed connection;
- markings installed on or near overground elements of underground tanks.

This document establishes additional principles to ISO 3864-1 for the purpose of establishing design principles for the display of safety information on tanks typically found in workplaces, industry and other facilities with tanks and containers. It covers safety information for tanks only. It is not intended for use on products.

This document does not cover tanks that are moved or transported. It does not apply to the labelling according to the United Nations' *Globally harmonized system of classification and labelling of chemicals (GHS)*.^[6]

Safety signing of the hazards in an area is not part of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3864-1:2011, *Graphical symbols — Safety colours and safety signs — Part 1: Design principles for safety signs and safety markings*

ISO 7010, *Graphical symbols — Safety colours and safety signs — Registered safety signs*

ISO 20560-1:2020, *Safety information for the content of piping systems and tanks — Part 1: Piping systems*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 20560-1 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1

GHS hazard pictogram

graphical composition defined by the United Nations' *Globally harmonized system of classification and labelling of chemicals (GHS)*^[6] that can include a symbol plus other graphic elements, such as a border, background pattern or colour, intended to convey specific information as given by the GHS

3.2

safe observation distance

minimum observation distance to avoid harm in the event of potentially damaging or emergency situations

Note 1 to entry: The safe observation distance is determined as part of the risk assessment.

3.3

safety data sheet

SDS

standardized information template for a medium which identifies the medium and contains information about its potential health, physical and chemical hazards, and emergency and firefighting procedures

3.4

safety information system

series of markings that consistently uses standardized elements to visually communicate information necessary for reliable recognition, identification and understanding of hazards

3.5

warning sign

safety sign that indicates a specific source of potential harm

[SOURCE: ISO 3864-1:2011, 3.16]

4 General requirements

A safety information system for tanks visually communicates information necessary for the reliable recognition, identification and understanding of any hazard related to the type and character of the content of a tank. This safety information system shall be installed on site and near any place that might require operation, maintenance or manipulation of a tank's contents, or intervention in the case of an emergency situation.

This safety information system provides critical information that serves to assist in:

- the correct operation and use of tanks;
- the safe maintenance of the tanks;
- conveying critical information to trained personnel in emergency situations.

The safety information system shall, in a comprehensive and uniform manner, accurately identify the contents and hazards associated with the contents of tanks in conformity with the contents' safety data sheets (SDSs). In some cases, the safety information system shall provide, in an integrated, coherent visual manner, specific hazard information related to the tank's contents. Examples of this information

include the exact nature of the substance, temperature, toxicity and the risk of asphyxiation if a release of the tank's contents occurs.

The safety information system shall consistently use multiple visual elements to accurately convey its information, identification and safety signs and GHS hazard pictograms. The information conveyed by the safety information system shall be consistent with the organization's risk assessment and its operation and safety plans.

All elements of a safety information system shall be distinguishable and contrasting from any neighbouring information and shall be visible from the observation distance intended for safe operation, intervention or manipulation. When the contents of tanks include hazardous substances (see GHS), the safety information system shall include distinctive, unambiguous elements and the corresponding warning signs, GHS hazard pictograms or both.

To avoid confusion, the same safety information system elements shall be consistently used and installed throughout all of an organization's tanks, whether it is a single unit, multiple units on the same site or a multi-plant operation.

The design of the safety information system shall consider and identify the different target audiences (e.g. workforce and intervention services) under normal operational conditions and emergency conditions.

5 Elements of safety information systems for tanks

5.1 General

The safety information system for tank marking shall consist of the following three key elements:

- a) content name;
- b) when applicable, warning signs, GHS pictograms or both;
- c) when applicable, tank identification.

The safety information system for tanks can include other information, such as:

- capacity of the tank in volume units;
- surface area of liquid in a tank;
- National Fire Protection Association (NFPA) diamond;
- hazard identification number (HIN), also known as the Kemmler code;
- United Nations number of the content (UN number);
- basic identification colour;
- other codes or information.

See [Annex C](#) for examples of different safety information systems for tanks.

5.2 Content name

The tank's content name shall be displayed in the local language or in multiple languages, see [Figure 1](#). This text element may be the content name, its chemical formula or numbers in accordance with national standards. Longer words may be abbreviated using standard approved abbreviations, known by operators, as found in the organization's operation safety manuals.



Figure 1 — Example of a safety information system displaying the content name

The content name shall be the contrast colour, black, on a white background, except when using the basic identification colour as defined in [Annex B, Table B.1](#). For more information about the use of the basic identification colour, see ISO 20560-1:2020, 5.3. The safety colour yellow, warning of hazardous content in piping systems, should not be used as a contrast colour to the content name.

When using the basic identification colour, it shall be on the entire top of the safety information system behind the content name. The content name shall be displayed in the contrast colour on the basic identification colour area. See [Figure 2](#).



Figure 2 — Example of a safety information system displaying the basic identification colour with content name

5.3 Warning signs and/or GHS pictograms

Warning signs and graphical symbols are elements of the safety information system used to symbolically communicate specific safety meanings. The SDSs, the organization's risk assessment or both shall identify the specific warning signs, according to ISO 7010 or GHS pictograms needed to communicate hazards associated with the contents of tanks, or both. The safety information system's warning signs and/or GHS pictograms shall be displayed on a white background.

As a result of an organization's risk assessment, safety information systems on tanks may use safety signs, supplementary text or both to communicate potential hazards not defined in SDSs (see [Figure 3](#)). Such potential hazards include, but are not limited to:

- temperature extremes of the contents;
- biohazards;
- radiation;
- asphyxiation by oxygen displacement;
- hazards related to pressurized content;

— gas blanket with high pressure.

NOTE There are ranking systems that allow for the reduction of the number of GHS pictograms that need to be displayed.




Figure 3 — Example of a safety information system displaying warning signs and/or GHS pictograms

Supplementary safety information as text and/or in the form of a graphical symbol may be used to describe, supplement or clarify the meaning of a warning sign. GHS pictograms and warning signs may be supplemented with text as shown in [Annex C](#), [Figures C.5](#) and [C.6](#) and, for warning signs, in accordance with ISO 3864-1:2011, Clauses 7 and 8.

5.4 Tank identification

When applicable, the tank identification in letters and/or numbers shall be displayed on the marking (see [Figure 4](#)).




Figure 4 — Example of a safety information system displaying the tank identification

5.5 Capacity of the tank

If there is a need to communicate tank capacity information for operational aspect reasons or to provide this information to intervention services in the event of an emergency situation, the capacity of the tank in m³ may be displayed on the safety information system (see [Figure 5](#)).