

TECHNICAL SPECIFICATION

ISO/TS
21805

First edition
2018-12

Guidance on design, selection and installation of vents to safeguard the structural integrity of enclosures protected by gaseous fire- extinguishing systems

iT *Lignes directrices pour la conception, la sélection et l'installation
d'évents pour préserver l'intégrité structurelle des enceintes protégées
par des systèmes fixes de lutte contre l'incendie à gaz*
[\(<https://standards.iteh.ai>\)](https://standards.iteh.ai)
Document Preview

[ISO/TS 21805:2018](#)

<https://standards.iteh.ai/catalog/standards/iso/1d54089d-f16b-4a18-a320-f174ab52bf9c/iso-ts-21805-2018>



Reference number
ISO/TS 21805:2018(E)

© ISO 2018

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO/TS 21805:2018](#)

<https://standards.iteh.ai/catalog/standards/iso/1d54089d-f16b-4a18-a320-f174ab52bf9c/iso-ts-21805-2018>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2018

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Symbols and abbreviated terms	2
5 Use and limitations	3
6 Safety	4
6.1 Structural safety	4
6.2 Personnel safety	4
7 System design — Pressure-relief venting	4
7.1 General	4
7.2 Extinguishant characteristics	4
7.2.1 Pressure graphs	5
7.3 Enclosure characteristics	7
7.4 Pressure-relief vent paths	7
7.5 Types of pressure-relief vents	7
7.5.1 General	7
7.5.2 Gravity vents	7
7.5.3 Counter weighted flap vent	8
7.5.4 Electrically operated vents	8
7.5.5 Pneumatically operated vent	9
7.5.6 Vent accessories	9
7.6 Pressure-relief vent characteristics	10
7.6.1 Vent efficiency	10
7.6.2 Minimum opening pressure	11
7.6.3 Minimum closing pressure	11
7.6.4 Fire rating	11
7.7 Vent location and mounting	11
7.7.1 Vent location	11
7.7.2 Vent mounting	12
7.8 Pressure-relief vent area calculations	13
7.8.1 Use of agent-specific equations	13
7.8.2 Vent area requirement (non-liquefiable gases and CO ₂)	14
7.8.3 Vent area requirements (liquefiable gases)	18
7.8.4 Leakage	22
7.9 Cascade venting calculations	23
7.9.1 Example calculation 3	24
7.9.2 Cascade vent arrangements	25
7.9.3 Venting into adjacent enclosures	26
8 System design — Post discharge venting	28
9 Acceptance	28
10 Service and maintenance	28
Bibliography	30

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html. **(<https://standards.iteh.ai>)**

This document was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 8, *Gaseous media and firefighting systems using gas*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

<https://standards.iteh.ai/catalog/standards/iso/1d54089d-fb6b-4a18-a320-f174ab52bf9c/iso-ts-21805-2018>

Introduction

The guidance presented here is based on the results of a joint research program conducted in 2006 and 2007 by several fire protection system manufacturers and interested parties. The program of work consisted of several series of tests to evaluate the peak pressure response and pressure-relief vent area effects for each agent addressed in this document. The key data used in the development of this document were the values of peak enclosure pressure response (P_{MAX}) at each value of the volume-normalized pressure-relief vent area of the test enclosure, hereinafter referred to as the "leakage-to-volume ratio" or LVR. Other test parameters (enclosure temperature, agent quantity, discharge time, and humidity) were held constant or varied in a specified manner. For each test series employing a single agent, the several pairs of LVR and resultant P_{MAX} values were graphically analysed and a best-fit correlation curve was determined.

The LVR vs. P_{MAX} correlation curve for each agent or system forms the basis of the associated equations in cases where discharge of the agent results in cooling the air temperature below its dew point. (See Humidity effects and humidity correction factor below.) In most cases, only halocarbon agents cause sufficient cooling to cause humidity related effects on the peak enclosure pressure. Thus, a correction for humidity effects is included in the equations for estimating vent area and maximum pressure on the discharge of the following agents:

- FK-5-1-12
- HFC-23
- HFC-125
- HFC-227ea

iTeh Standards

<https://standards.iteh.ai>

Document Preview

The humidity corrections used in this document are based on the results of tests conducted with HFC-227ea at different conditions of humidity.

The resulting values for humidity correction will be assumed to be equally applicable to the agents FK-5-1-12, HFC-125 and HFC-23 until further data or analysis indicates otherwise.

The correlations of LVR to maximum negative pressure and maximum positive pressure were based on test work performed in a test chamber at a relative humidity (RH) of approximately 38 %. If the RH in a protected enclosure differs from 38 % then a correction to the estimated maximum negative and positive pressures may be required. See [7.8](#) and [7.9](#) for further information on the effect of humidity. The temperature of the test enclosure was 21°C (nominal) for all tests that form the basis of the estimating methods given in this document.

In conducting the research program, described above, a large number of different venting arrangements were created in the test enclosure. The equivalent leakage area (ELA) for each test was determined by a "door fan test" and data analysis. The average enclosure pressure in effect during the many door fan tests varied from test to test. All values of ELA were normalized to an equivalent enclosure differential pressure of 125 Pa. The resulting enclosure correlations of peak pressure vs. LVR, and any resulting estimate of enclosure pressure-relief vent area, reflect a pressure-relief vent area calculated at an effective enclosure pressure of 125 Pa for a vent with discharge coefficient of 0,61.

The effectiveness of a gaseous total flooding firefighting system depends, in part, on retention of the air-extinguishant mixture within the protected volume for a period of time. Retention of the extinguishant-air mixture requires that gas exchange ("leakage") between the enclosure and the ambient environment be restricted. In order to limit the rate of gas exchange the enclosure boundary should have a high degree of integrity. To put it another way, the sum total of the areas of the various penetrations in an enclosure's bounding surfaces should be low, at least during the gas-retention period (hold time) after the end of extinguishant discharge.

Addition of a gaseous firefighting extinguishant to an enclosure having limited pressure-relief vent area will naturally result in a change of pressure therein. If the enclosure is sealed too tightly during the extinguishant discharge, i.e., too little pressure-relief vent area, the pressure change could exceed the

structural strength of one or more of its bounding surfaces — windows, doors, walls, ceiling. Conversely, if the enclosure has too much pressure-relief vent area then gas exchange with the ambient atmosphere will occur rapidly, leading to short retention time of the extinguishant within the protected volume.

Thus, the use of gaseous firefighting systems should address two performance considerations:

- a) Pressure management within the protected volume during the period of extinguishant discharge, and
- b) Retention of the extinguishant-air mixture within the enclosure for a specified period of time after the completion of the discharge.

This document provides guidance for limiting pressure extremes in an enclosure during the discharge of a clean agent fire extinguishing system. This document does not provide the information necessary to determine all of the requirements related to the design, installation, service, maintenance, inspection, test, and/or requalification of fire suppression systems.

Some limitations and restrictions apply to the use of the equations contained in this document. Please refer to the text and notes that follow.

The information in this document does not supersede the manufacturer's guidance. The information contained in this document is presented as supplementary to the guidance provided by the respective system manufacturers. Guidance from the system manufacturer should always be followed and used for purposes of system design, installation, operation and maintenance.

It has been assumed in the preparation of this document that the execution of its provisions is entrusted to people appropriately qualified and experienced in the specification, design, installation, testing, approval, inspection, operation and maintenance of systems and equipment, for whose guidance it has been prepared, and who can be expected to exercise a duty of care to avoid unnecessary release of extinguishant.

Document Preview

[ISO/TS 21805:2018](https://standards.iteh.ai/catalog/standards/iso/1d54089d-f16b-4a18-a320-f174ab52bf9c/iso-ts-21805-2018)

<https://standards.iteh.ai/catalog/standards/iso/1d54089d-f16b-4a18-a320-f174ab52bf9c/iso-ts-21805-2018>

Guidance on design, selection and installation of vents to safeguard the structural integrity of enclosures protected by gaseous fire-extinguishing systems

1 Scope

This document provides guidance on fulfilling the requirements contained in ISO 6183:2009, 6.4.1 and 7.4.1 and ISO 14520-1:2015, 5.2.1 h and 5.3 h, in respect to over and under pressurisation venting and post discharge extract.

It considers the design, selection and installation of vents to safeguard the structural integrity of enclosures protected by fixed gaseous extinguishing systems and the post discharge venting provisions where used.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

NOTE For the purposes of this document, the term "bar" signifies "gauge", unless otherwise indicated. Concentrations or quantities expressed in percentages (%) signify by volume, unless otherwise indicated.

3.1

back pressure

pressure downstream of a vent

3.2

fire damper

device designed to prevent the spread of fire

3.3

free pressure-relief vent area

sum of the free pressure-relief vent areas of the pressure-relief vents provided

Note 1 to entry: This is determined by the gross pressure-relief vent area x the vent efficiency.

3.4

gross pressure-relief vent area

total area of the pressure-relief vent

3.5

negative pressure

pressure in the protected room which is lower than the pressure immediately outside the enclosure boundary

3.6

peak pressure

The maximum pressure (positive and negative) generated within a an enclosure caused by the discharge of the gaseous agent

3.7

positive pressure

pressure in the protected room which is higher than the pressure immediately outside the enclosure boundary

3.8

enclosure strength

specified differential pressure limit for the protected enclosure

3.9

pressure-relief area

sum of the free pressure-relief vent area and the enclosure leakage area

3.10

pressure-relief vent

device that provides a flow path through an enclosure boundary to limit the pressure therein

4 Symbols and abbreviated terms

A_N pressure-relief vent area to limit negative pressure to a specified P_N , cm^2 (in^2)

A_P pressure-relief vent area to limit positive pressure to a specified P_P , cm^2 (in^2)

C agent design concentration, in percent by volume

M_{AIR} is the molecular weight of air = 0,029 (kg/mol)

M_{AGT} molecular weight of the agent, (kg/mol)

Q <https://standards.itcsh.ai/catalog/standards/iso/1d54089d-f16b-4a18-a320-f174ab52bf9c/iso-ts-21805-2018>

P pressure (Pa)

P_N negative pressure, psf (Pa)

P_P positive pressure, psf (Pa)

P_N and P_P represent either

- Design pressure limits for estimating A_N or A_P , or
- Estimates of maximum values of P_N or P_P for given values of A_N or A_P

R gas law constant, 8,314 (J/mol-K)

% RH relative humidity in hazard space at 21 °C (70 °F), %

s specific volume of the agent at the design temperature (m^3/kg)

s_H specific volume of the homogenous agent-air mixture (m^3/kg), which is the inverse of the density

t	agent discharge time, s
V	volume of the protected space (m ³)
ρ_H	agent-air mixture density at the specified temperature and pressure (kg/m ³)

5 Use and limitations

This document is for the use by those competent in the design, installation, servicing and maintenance of fixed gaseous firefighting systems. It also serves as guidance for those involved in the design, construction and operation of buildings in which such systems are installed.

It does not replace the need for the person responsible for the design, construction and operation of the building to fulfil their obligations in respect to providing adequate structural provisions.

There may be other trades and services involved in the complete system and the document is limited to providing the guidance outlined in the document and does not purport to be expert in all areas.

After applying the enclosure peak pressure and pressure-relief vent area analysis of this document, the user may conclude that an enclosure may require additional pressure-relief vent area in order to avoid exceeding specified maximum pressure values upon discharge of a gaseous agent system. If that is the case, it is recommended that the user advise the supplier of a supplemental venting device that such device be specified and selected by use of this document.

The maximum pressure developed in an enclosure on discharge of a clean agent fire extinguishing system is affected by several characteristics of the system itself and the enclosure being protected. Of particular importance are the thermodynamic properties of the agent and the discharge characteristics of the hardware. Each of the following sections contains correlation equations that are specific to the agent type and manufacturer's hardware. The equations can be used to make estimates of the following:

- a) enclosure pressure-relief vent area given a specified enclosure pressure limit;
- b) maximum positive or negative pressure developed in an enclosure given a stated or calculated pressure-relief vent area.

<https://standards.iea.org/catalog/standards/iso/1d54089d-f16b-4a18-a320-f174ab52bf9c/iso-ts-21805-2018>

NOTE The formulae in this document for halocarbon agents have a limited range of applicability based on the parametric limitations of the data from which they were derived. [Table 1](#) indicates the applicable limits of design concentration, discharge time, and enclosure pressure response for the use of this document. The maximum peak pressure estimates (both positive and negative) based on data obtained for each agent are given in [Table 1](#).

Caution — It is physically possible to develop pressures greater than those covered by this document during system discharges.

Table 1 — Summary of equation application limits

Agent	Minimum agent Conc % vol	Maximum agent Conc % vol	Minimum discharge time	Maximum discharge time	Maximum over-pressure pfs (Pa)	Maximum under pressure pfs (Pa)
FK-5-1-12	4,2	6	6	10	5 (239)	25 (1 197)
HFC-23	18	30	6	10	30 (1 437)	n/a
HFC-125	8	10,5	6	10	10 (479)	10 (479)
HFC-227ea	6,25	10,5	6	10	8 (383)	20 (958)

6 Safety

6.1 Structural safety

The provision of correctly designed and engineered pressure venting of enclosures protected by gaseous fire-extinguishing systems is essential in order to prevent the possibility of failure of structural integrity. This is essential to mitigate forces exerted by the changes in enclosure pressure when gaseous fighting media are discharged into an enclosure.

6.2 Personnel safety

The operation of pressure-relief vents or extract systems, requires the displacement of mixtures of air/gaseous media from a protected enclosure to atmosphere or another area not necessarily protected. The safety issue may arise due to exposures to the extinguishants themselves or products of combustion and/or extinguishant breakdown products. In addition, any hazards arising from the operation of the over/under pressurisation vents themselves should be considered.

7 System design — Pressure-relief venting

7.1 General

The basic design principle is to limit the pressure excursions imposed on the structure of the protected enclosure by the discharge of gaseous extinguishant to that within the limits the enclosure is able to withstand.

A room integrity test can be used to determine the equivalent leakage area, or simply "vent" area that exists at the time of evaluation. The methods of this document can use the known or estimated pressure-relief vent area to estimate the maximum pressure that will be developed on discharge of a clean agent system. In the event that the estimated maximum pressure exceeds a specified design threshold, the methods of this document may be used to estimate a pressure-relief vent area sufficient to limit development of pressure upon system discharge to an acceptable value.

<https://standards.iteh.ai/catalog/standards/iso/1d54089d-f16b-4a18-a320-f174ab52bf9c/iso-ts-21805-2018>

7.2 Extinguisher characteristics

Consideration should be given to positive pressurisation created by all extinguishants and additionally to negative pressurisation created by some extinguishants as defined in [Table 2](#).

Table 2 — Pressure effects of gaseous extinguishant

Extinguisher name	Positive pressure created	Negative pressure created
FK-5-1-12	Yes	Yes
HFC-125	Yes	Yes
HFC-227ea	Yes	Yes
HFC-23	Yes	No
IG 01	Yes	No
IG 100	Yes	No
IG 55	Yes	No
IG 541	Yes	No
CO ₂	Yes	No ¹

NOTE Negative pressure has been observed, with adverse effects. It can occur in certain cases where large quantities of CO₂ are released into a space having low leakage to ambient.

7.2.1 Pressure graphs

The graphs below illustrate the typical pressure excursions that would occur during discharge within the protected area.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO/TS 21805:2018](#)

<https://standards.iteh.ai/catalog/standards/iso/1d54089d-f16b-4a18-a320-f174ab52bf9c/iso-ts-21805-2018>