

SLOVENSKI STANDARD
kSIST-TS FprCEN ISO/TS 16486-7:2023
01-maj-2023

Cevni sistemi iz polimernih materialov za oskrbo s plinastimi gorivi - Cevni sistemi iz nemehčanega poliamida (PA-U) z zvari in mehanskimi spoji - 7. del: Ugotavljanje skladnosti (ISO/DTS 16486-7:2023)

Plastics piping systems for the supply of gaseous fuels - Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing - Part 7: Assessment of conformity (ISO/DTS 16486-7:2023)

Kunststoff-Rohrleitungssysteme für die Gasversorgung - Rohrleitungssysteme aus weichmacherfreiem Polyamid (PA-U) mit Schweißverbindungen und mechanischen Verbindungen - Teil 7: Beurteilung der Konformität (ISO/DTS 16486-7:2023)

Systèmes de canalisations en matières plastiques pour la distribution de combustibles gazeux - Systèmes de canalisations en polyamide non plastifié (PA-U) avec assemblages par soudage et assemblages mécaniques - Partie 7: Evaluation de la conformité (ISO/DTS 16486-7:2023)

Ta slovenski standard je istoveten z: FprCEN ISO/TS 16486-7

ICS:

03.120.20	Certificiranje proizvodov in podjetij. Ugotavljanje skladnosti	Product and company certification. Conformity assessment
75.200	Oprema za skladiščenje nafte, naftnih proizvodov in zemeljskega plina	Petroleum products and natural gas handling equipment
83.140.30	Polimerne cevi in fitingi za snovi, ki niso tekočine	Plastics pipes and fittings for non fluid use

kSIST-TS FprCEN ISO/TS 16486-7:2023 en,fr,de

FINAL
DRAFTTECHNICAL
SPECIFICATIONISO/DTS
16486-7

ISO/TC 138/SC 4

Secretariat: NEN

Voting begins on:
2023-03-13Voting terminates on:
2023-06-05

Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing —

Part 7: Assessment of conformity

Systèmes de canalisations en matières plastiques pour la distribution de combustibles gazeux — Systèmes de canalisations en polyamide non plastifié (PA-U) avec assemblages par soudage et assemblages mécaniques —

Partie 7: Evaluation de la conformité

[SIST-TS CEN ISO/TS 16486-7:2023](https://standards.iteh.ai/catalog/standards/sist/a98c4c1a-8367-47c5-82ce-7e6fe64d5ae3/sist-ts-cen-iso-ts-16486-7-2023)

<https://standards.iteh.ai/catalog/standards/sist/a98c4c1a-8367-47c5-82ce-7e6fe64d5ae3/sist-ts-cen-iso-ts-16486-7-2023>

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.



Reference number
ISO/DTS 16486-7:2023(E)

© ISO 2023

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[SIST-TS CEN ISO/TS 16486-7:2023](https://standards.iteh.ai/catalog/standards/sist/a98c4c1a-8367-47c5-82ce-7e6fe64d5ae3/sist-ts-cen-iso-ts-16486-7-2023)

<https://standards.iteh.ai/catalog/standards/sist/a98c4c1a-8367-47c5-82ce-7e6fe64d5ae3/sist-ts-cen-iso-ts-16486-7-2023>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2023

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword.....	iv
Introduction.....	v
1 Scope.....	1
2 Normative references.....	1
3 Terms and definitions.....	2
4 Abbreviated terms.....	5
5 General.....	5
6 Testing and inspection.....	5
6.1 Grouping.....	5
6.1.1 General.....	5
6.1.2 Size groups.....	5
6.1.3 Fitting groups.....	6
6.1.4 Fitting types.....	6
6.2 Type testing.....	6
6.3 Batch release testing.....	13
6.4 Process verification tests.....	17
6.5 Audit tests.....	21
6.6 One-off products and products produced in very low quantity.....	23
6.6.1 Type test results.....	23
6.6.2 Test records.....	24
6.6.3 Technical file for certification purposes.....	24
Annex A (normative) Change of compound.....	25
Annex B (informative) Basic test matrix for PA-U compounds and piping products.....	27
Bibliography.....	33

SIST-TS CEN ISO/TS 16486-7:2023

<https://standards.iteh.ai/catalog/standards/sist/a98c4c1a-8367-47c5-82ce-7e6fe64d5ae3/sist-ts-cen-iso-ts-16486-7-2023>

ISO/DTS 16486-7:2023(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Subcommittee SC 4, *Plastics pipes and fittings for the supply of gaseous fuels*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 155, *Plastics piping systems and ducting systems*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

A list of all parts in the ISO 16486 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document specifies requirements and guidance for the assessment of conformity (AoC) for a piping system and its components made from unplasticized polyamide (PA-U), and which is intended to be used for the supply of gaseous fuels.

Requirements and test methods for material and components of the piping system are specified in ISO 16486-1, ISO 16486-2, ISO 16486-3 and ISO 16486-4.

Characteristics for fitness for purpose of the system and generic fusion parameters are covered in ISO 16486-5.

Recommended practice for installation is provided in ISO 16486-6, which will not be implemented as European Standard under the Vienna Agreement.

Recommended practice for installation is also provided in CEN/TS 12007-6,^[1] prepared by Technical Committee CEN/TC 234, *Gas infrastructure*.


Training and assessment of fusion operators is given in ISO/TS 16486-8.

NOTE While ISO 16486-1, ISO 16486-2, ISO 16486-3, ISO 16486-5, ISO 16486-6 and ISO/TS 16486-7 (this document) and ISO/TS 16486-8 have been prepared by ISO/TC 138, SC 4, ISO 16486-4 has been prepared by ISO/TC 138, SC 7.

This document details the applicable characteristics to be assessed for type testing (TT), batch release testing (BRT), process verification testing (PVT) and audit testing (AT), as well as the frequency and sampling for testing.

The concept of testing and organization of those tests used for the AoC is shown, without or with certification, in [Figures 1](#) and [2](#).


A typical scheme for the assessment of conformity of materials, compounds, pipes, fittings, valves, joints or assemblies by product manufacturers is given in [Figure 1](#).



SOURCE ISO/TS 15874-7, reproduced with the permission of the authors.

Figure 1 — Typical scheme for the AoC by a manufacturer, without certification

A typical scheme for the assessment of conformity of compounds, pipes, fittings, valves, joints or assemblies by manufacturers, including certification, is given in [Figure 2](#).



SOURCE ISO/TS 15874-7, reproduced with the permission of the authors.

Figure 2 — Typical scheme for the AoC by a manufacturer, including certification

iTeh Standards
 (https://standards.iteh.ai)
 Document Preview

SIST-TS CEN ISO/TS 16486-7:2023

<https://standards.iteh.ai/catalog/standards/sist/a98c4c1a-8367-47c5-82ce-7e6fe64d5ae3/sist-ts-cen-iso-ts-16486-7-2023>

Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing —

Part 7: Assessment of conformity

1 Scope

This document gives guidance and requirements for the assessment of conformity of compounds, products, joints and assemblies in accordance with the applicable part(s) of the ISO 16486 series which are intended to be included in the manufacturer's quality plan as part of the quality management system and for the establishment of certification procedures.

NOTE 1 A basic test matrix in [Annex B](#) provides an overview of the testing scheme.

It is recommended that the manufacturer have a management system such as ISO 9001^[4] or equivalent.

NOTE 2 If certification is involved, certification bodies and inspection bodies operating according to ISO/IEC 17065 and ISO/IEC 17020 are considered to be competent.

In conjunction with the other parts of the ISO 16486 series (see [Clause 2](#)), this document is applicable to unplasticized polyamide (PA-U) piping systems intended to be buried and used for the supply of gaseous fuels. It is applicable to PA-U pipes, fittings and valves, as well as to their joints and to joints with components of other materials intended to be used under the following conditions:

- a) a maximum operating pressure (MOP) up to and including 18 bar¹⁾ (the MOP is limited to 16 bar for CEN member countries, where ISO 16486-6 is replaced by CEN/TS 12007-6^[1]);
- b) an operating temperature of 20 °C as the reference temperature.

NOTE 3 For operating temperatures different to 20 °C, derating coefficients can be used (see ISO 16486-6). CEN member countries use CEN/TS 12007-6^[1] and ISO/TS 16486-7 (this document) as a basis, but they can also request additional requirements. For non-CEN member countries, information for dealing with special cases for PA-U can be found in ISO/TS 16486-7 (this document) and PPI TR-3.^[7]

For mechanical fittings conforming to ISO 17885, guidance for assessment of conformity is not given in this document. When requested, a quality plan based on the tests mentioned can be set up in agreement between user and manufacturer.

The ISO 16486 series covers a range of maximum operating pressures and gives requirements concerning colours.

NOTE 4 It is the responsibility of the purchaser or specifier to make the appropriate selections from these aspects, taking into account their particular requirements and any relevant national regulations and installation practices or codes.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

1) 1 bar = 0,1 MPa = 10⁵ Pa; 1 MPa = 1 N/mm².

ISO/DTS 16486-7:2023(E)

ISO 12162, *Thermoplastics materials for pipes and fittings for pressure applications — Classification, designation and design coefficient*

ISO 13477, *Thermoplastics pipes for the conveyance of fluids — Determination of resistance to rapid crack propagation (RCP) — Small-scale steady-state test (S4 test)*

ISO 16486-1:2020, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 1: General*

ISO 16486-2:2020, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 2: Pipes*

ISO 16486-3:2020, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 3: Fittings*

ISO 16486-4:2022, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 4: Valves*

ISO 16486-5:2021, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 5: Fitness for purpose of the system*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 16486-1, ISO 16486-2, ISO 16486-3, ISO 16486-4 and ISO 16486-5 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 certification body

third-party conformity assessment body operating certification schemes

Note 1 to entry: A certification body can be non-governmental or governmental (with or without regulatory authority).

3.2 laboratory

body that performs one or more of the following activities:

- testing;
- calibration;
- sampling, associated with subsequent testing or calibration

Note 1 to entry: Within the context of this document, the materials and products can be subjected to type testing, batch release testing, process verification testing and audit testing, as applicable.

3.3 quality management system

part of a management system with regard to quality

Note 1 to entry: Requirements for quality management systems are given in ISO 9001.

[SOURCE: ISO 9000:2015, 3.5.4, modified — Note 1 to entry added.]

3.4**quality plan**

document setting out the specific quality practices, responsibilities, resources and sequence of activities relevant to a particular product or range of products

3.5**type testing****TT**

test performed to prove that the material, component, product, joint or assembly is capable of conforming to the requirement(s) given in the relevant standard

3.6**batch release test****BRT**

test performed on a batch of material, components, products, joints or assemblies which has to be satisfactorily completed before the batch can be released

Note 1 to entry: A batch release test can be performed by the manufacturer or outsourced on behalf of the manufacturer.

3.7**process verification test****PVT**

test performed on material, component, product, joint or assembly at specific intervals to confirm that the process continues to be capable of producing components, products which conform to the requirements given in the relevant standard

Note 1 to entry: Process verification tests can be performed by the manufacturer or outsourced on behalf of the manufacturer.

Note 2 to entry: Process verification tests are regularly performed to demonstrate that the product remains compliant with the type test results.

Note 3 to entry: ISO/AWI 8149:²⁾ presents the stress rupture curves for PA-U and PPI TR-4^[2] lists the long-term hydrostatic strength at different temperatures for a number of different PA-U piping materials.

3.8**audit test****AT**

test performed on behalf of a certification body

Note 1 to entry: Audit tests are generally required to confirm that the compound, components, product, joint or assembly continues to conform to the requirements given in the relevant standard and to provide information to assess the effectiveness of the quality management system.

3.9**indirect test****IT**

batch release test performed which differs from that specified test for that particular characteristic, having previously verified its correlation with the specified test

Note 1 to entry: Indirect tests can be performed by the manufacturer or outsourced on behalf of the manufacturer.

3.10**witness test****WT**

type test or audit test which is performed in the presence of a representative of the certification body

2) Under preparation. Stage and the time of publication: ISO/AWI 8149:2023.

ISO/DTS 16486-7:2023(E)**3.11
material**

generic term for compounds grouped by families, expressed by generic names

Note 1 to entry: Examples of generic names are PA-U 11, PA-U 12.

**3.12
compound**

homogenous mixture of substances used for the manufacture of the product as defined in the referring product standard

Note 1 to entry: [Annex A](#) gives testing requirements for changes made to the compound.

**3.13
material batch
batch of material**

quantity of a given homogeneous compound manufactured under uniform conditions defined and identified by the compound manufacturer

**3.14
product**

item as defined in the scope of this document, e.g. pipe, fitting, valve

**3.15
product batch
batch of products**

clearly identified collection of products, manufactured consecutively or continuously under the same conditions, using the same compound conforming to the same specification

Note 1 to entry: The production batch is defined and identified by the product manufacturer.

**3.16
lot**

clearly identifiable sub-division of a batch for inspection purposes

**3.17
sample**

one or more units or products drawn from the same production batch or a lot, selected at random without regard to their quality

**3.18
group**

collection of similar components or products from which samples are selected for testing purposes

**3.19
component**

item manufactured out of a specific compound, supplied as part of a product or as a spare part for that product

Note 1 to entry: Depending on the context, components can potentially be considered as products and be individually approved (e.g. o-ring, gasket) or they are tested as an integral part of a finished product (e.g. in a valve).

**3.20
joint**

connection between two or more products

**3.21
assembly**

set of components that forms a product or a test piece