

---

**Jedrske elektrarne - Merilna in nadzorna oprema za zagotavljanje varnosti - Razvoj HDL-programiranih integriranih vezij - 2. del: HDL-programirana integrirana vezja za sisteme, ki izvajajo funkcije kategorije B ali C (IEC 62566-2:2020)**

Nuclear power plants - Instrumentation and control systems important to safety - Development of HDL-programmed integrated circuits - Part 2: HDL-programmed integrated circuits for systems performing category B or C functions (IEC 62566-2:2020)

Kernkraftwerke – Leittechnik für Systeme mit sicherheitstechnischer Bedeutung – Entwicklung HDL-programmierter integrierter Schaltkreise - Teil 2: HDL-programmierte integrierte Schaltkreise für Systeme, die Funktionen der Kategorie B oder C ausführen (IEC 62566-2:2020)

[SIST EN IEC 62566-2:2021](https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-5c904d5add76/sist-en-iec-62566-2-2021)

[https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-](https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-5c904d5add76/sist-en-iec-62566-2-2021)

[5c904d5add76/sist-en-iec-62566-2-2021](https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-5c904d5add76/sist-en-iec-62566-2-2021)

Centrales nucléaires de puissance – Instrumentation et contrôle-commande importants pour la sûreté – Développement des circuits intégrés programmés en HDL – Partie 2: Circuits intégrés programmés en HDL pour les systèmes réalisant des fonctions de catégorie B ou C (IEC 62566-2:2020)

**Ta slovenski standard je istoveten z: EN IEC 62566-2:2020**

---

**ICS:**

27.120.20	Jedrske elektrarne. Varnost	Nuclear power plants. Safety
31.200	Integrirana vezja, mikroelektronika	Integrated circuits. Microelectronics

**SIST EN IEC 62566-2:2021**

**en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN IEC 62566-2:2021](#)

<https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-5c904d5add76/sist-en-iec-62566-2-2021>

EUROPEAN STANDARD

EN IEC 62566-2

NORME EUROPÉENNE

EUROPÄISCHE NORM

November 2020

ICS 27.120.20

English Version

**Nuclear power plants - Instrumentation and control systems  
important to safety - Development of HDL-programmed  
integrated circuits - Part 2: HDL-programmed integrated circuits  
for systems performing category B or C functions  
(IEC 62566-2:2020)**

Centrales nucléaires de puissance - Instrumentation et  
contrôle-commande importants pour la sûreté -  
Développement des circuits intégrés programmés en HDL -  
Partie 2: Circuits intégrés programmés en HDL pour les  
systèmes réalisant des fonctions de catégorie B ou C  
(IEC 62566-2:2020)

Kernkraftwerke - Leittechnik für Systeme mit  
sicherheitstechnischer Bedeutung - Entwicklung HDL-  
programmierter integrierter Schaltkreise - Teil 2: HDL-  
programmierte integrierte Schaltkreise für Systeme, die  
Funktionen der Kategorie B oder C ausführen  
(IEC 62566-2:2020)

**iTeh STANDARD PREVIEW**  
(standards.iteh.ai)

This European Standard was approved by CENELEC on 2020-11-16. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

<https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-619994c09b21/iec-62566-2-2021>

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

**EN IEC 62566-2:2020 (E)****European foreword**

This document (EN IEC 62566-2:2020) consists of the text of document IEC 62566-2:2020, prepared by IEC/SC 45A "Instrumentation and control of nuclear facilities" of IEC/TC 45 "Nuclear instrumentation".

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2021-11-16
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2023-11-16

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

As stated in the nuclear safety directive 2009/71/EURATOM, Chapter 1, Article 2, item 2, Member States are not prevented from taking more stringent safety measures in the subject-matter covered by the Directive, in compliance with Community law.

In a similar manner, this European standard does not prevent Member States from taking more stringent nuclear safety and/or security measures in the subject-matter covered by this standard.

ITEH STANDARD PREVIEW

(standards.iteh.ai)

**Endorsement notice**

[SIST EN IEC 62566-2:2021](https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-5c904d5add76/sist-en-iec-62566-2-2021)

[https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-](https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-5c904d5add76/sist-en-iec-62566-2-2021)

[5c904d5add76/sist-en-iec-62566-2-2021](https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-5c904d5add76/sist-en-iec-62566-2-2021)

The text of the International Standard IEC 62566-2:2020 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC/IEEE 60780-323:2016	NOTE	Harmonized as EN 60780-323:2017 (not modified)
IEC 61508-1:2010	NOTE	Harmonized as EN 61508-1:2010 (not modified)
IEC 61508-2:2010	NOTE	Harmonized as EN 61508-2:2010 (not modified)
IEC 61508-3:2010	NOTE	Harmonized as EN 61508-3:2010 (not modified)
IEC 61508-4:2010	NOTE	Harmonized as EN 61508-4:2010 (not modified)
IEC 62645	NOTE	Harmonized as EN IEC 62645

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cenelec.eu](http://www.cenelec.eu).

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60880	2006	Nuclear power plants - Instrumentation and control systems important to safety - Software aspects for computer-based systems performing category A functions	EN 60880	2009
IEC 60987	-	Nuclear power plants - Instrumentation and control important to safety - Hardware design requirements for computer-based systems	EN 60987	-
IEC 61226	-	Nuclear power plants - Instrumentation and control important to safety - Classification of instrumentation and control functions	EN 61226	-
IEC 61513	2011	Nuclear power plants - Instrumentation and control important to safety - General requirements for systems	EN 61513	2013
IEC 62138	2018	Nuclear power plants - Instrumentation and control systems important to safety - Software aspects for computer-based systems performing category B or C functions	EN IEC 62138	2019
IEC 62340	-	Nuclear power plants - Instrumentation and control systems important to safety - Requirements for coping with common cause failure (CCF)	EN 62340	-
IEC 62566	2012	Nuclear power plants - Instrumentation and control important to safety - Development of HDL-programmed integrated circuits for systems performing category A functions	EN 62566	2014

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN IEC 62566-2:2021](#)

<https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-5c904d5add76/sist-en-iec-62566-2-2021>



IEC 62566-2

Edition 1.0 2020-05

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

**Nuclear power plants – Instrumentation and control important to safety –  
Development of HDL-programmed integrated circuits –  
Part 2: HDL-programmed integrated circuits for systems performing  
category B or C functions**

[SIST EN IEC 62566-2:2021](https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-1c551c1b641c/iec-62566-2-2021)

[https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-](https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-1c551c1b641c/iec-62566-2-2021)

**Centrales nucléaires de puissance – Instrumentation et contrôle-commande  
importants pour la sûreté – Développement des circuits intégrés programmés  
en HDL –  
Partie 2: Circuits intégrés programmés en HDL pour les systèmes réalisant  
des fonctions de catégorie B ou C**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

ICS 27.120.20

ISBN 978-2-8322-8032-4

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	10
2 Normative references .....	11
3 Terms and definitions .....	11
4 Symbols and abbreviated terms.....	18
5 General requirements for HPD projects .....	19
5.1 General.....	19
5.2 Life-cycle .....	19
5.3 Gradation principals.....	21
5.4 HPD quality assurance.....	22
5.4.1 General .....	22
5.5 Configuration management .....	23
5.5.1 General .....	23
5.6 HPD Verification .....	23
6 HPD requirements specification.....	24
6.1 General.....	24
6.1.1 Overview.....	24
6.2 Functional aspects of the requirements specification .....	25
6.2.1 General .....	25
6.3 Fault detection and fault tolerance .....	26
6.4 Requirements capture using Electronic System Level tools.....	26
6.4.1 General .....	26
6.4.2 Requirements on the formalism of tools used at ESL level.....	27
6.4.3 Interface with design tools .....	27
7 Acceptance process for programmable integrated circuits, native blocks and Pre-Developed Blocks .....	27
7.1 General.....	27
7.2 Acceptance process for programmable integrated circuits and included native blocks.....	27
7.2.1 General .....	27
7.2.2 Integrated Circuit acceptance .....	28
7.3 Acceptance process for PDBs .....	29
7.3.1 General .....	29
7.3.2 PDB functional suitability .....	29
7.3.3 Documentation for safety of PDBs .....	30
7.3.4 Generation of supporting documentation for safety .....	30
7.3.5 Complementary means .....	32
7.3.6 Rules of use .....	32
7.3.7 Modification for acceptance .....	33
8 HPD design and implementation.....	33
8.1 General.....	33
8.2 Hardware Description Languages (HDL) and related tools .....	33
8.2.1 General .....	33
8.3 Design .....	33
8.3.1 General .....	33



8.3.2	Fault detection.....	35
8.3.3	Language and coding rules.....	35
8.3.4	Synchronous vs. asynchronous design.....	36
8.3.5	Power Management.....	37
8.3.6	Design documentation.....	37
8.4	Implementation.....	37
8.4.1	Products.....	37
8.4.2	Files of parameters and constraints.....	37
8.4.3	Post-route analyses.....	37
8.4.4	Redundancies introduced or removed by the tools.....	38
8.4.5	Finite state machines.....	38
8.4.6	Static Timing Analysis.....	38
8.4.7	Implementation documentation.....	38
8.5	System level tools and automated code generation.....	39
8.5.1	General.....	39
9	HPD integration and testing.....	39
9.1	General.....	39
9.2	Test-benches for HPD functional simulation.....	40
9.3	Test coverage.....	40
9.4	Test execution.....	41
10	HPD aspects of system integration.....	41
10.1	General.....	41
10.2	Requirements.....	41
11	HPD aspects of system validation.....	42
11.1	General.....	42
11.2	Requirements.....	42
12	Modification.....	43
12.1	Modification of the requirements, design or implementation.....	43
12.1.1	General.....	43
12.2	Modification of the micro-electronic technology.....	45
13	HPD production.....	45
13.1	General.....	45
13.2	Production tests.....	45
13.3	Programming files and programming activities.....	45
14	HPD aspects of installation, commissioning and operation.....	46
14.1	General.....	46
14.1.1	Overview.....	46
14.2	Anomaly reports.....	46
15	Software tools for the development of HPDs.....	46
15.1	General.....	46
15.1.1	Overview.....	46
15.2	Additional requirements for design, implementation and simulation tools.....	47
16	Design segmentation or partitioning.....	48
16.1	Background.....	48
16.2	Auxiliary or support functions.....	48
16.2.1	General.....	48
16.2.2	Partitioning of auxiliary or support functions or functions of an inferior safety category.....	48

17 Defences against HPD Common Cause Failure .....	49
Annex A (informative) Documentation .....	50
A.1 General.....	50
A.2 Project.....	50
A.3 HPD requirement specification.....	50
A.4 Acceptance of blank integrated circuits, Native Blocks and PDBs .....	50
A.5 HPD design and implementation .....	50
A.6 HPD integration and testing .....	51
A.7 HPD aspects of system integration.....	51
A.8 HPD aspects of system validation .....	51
A.9 Modification .....	51
A.10 HPD production .....	51
A.11 Software tools for the development of HPDs .....	51
Annex B (informative) Development of HPDs .....	52
B.1 General.....	52
B.2 Optional capture of requirements at Electronic System Level .....	52
B.3 HPD and system life-cycle .....	52
B.4 Design .....	53
B.5 Acceptance process for programmable integrated circuits, native blocks and Pre-Developed Blocks.....	54
B.6 Implementation .....	54
B.7 HPD integration and testing .....	55
B.8 Types of specific integrated circuits .....	55
B.8.1 General .....	55
B.8.2 PAL (Programmable Array Logic).....	56
B.8.3 PLD, CPLD (Programmable Logic Device, Complex PLD).....	56
B.8.4 FPGA .....	56
B.8.5 Gate Array, or pre-diffused integrated circuit .....	57
B.8.6 Standard Cells.....	57
B.8.7 “Full custom ASIC”, or “raw ASIC” .....	57
Bibliography.....	58
Figure 1 – System life-cycle (informative, as defined by IEC 61513) .....	20
Figure 2 – HPD life-cycle .....	21
Figure 3 – Overview of selection and acceptance process for blank Integrated Circuits and native blocks.....	28
Figure 4 – Overview of selection and acceptance process for PDBs .....	29

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**NUCLEAR POWER PLANTS –  
INSTRUMENTATION AND CONTROL IMPORTANT TO SAFETY –  
DEVELOPMENT OF HDL-PROGRAMMED INTEGRATED CIRCUITS –**

**Part 2: HDL-programmed integrated circuits  
for systems performing category B or C functions**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62566-2 has been prepared by subcommittee 45A: Instrumentation, control and electrical power systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
45A/1304/FDIS	45A/1314/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62566 series, published under the general title *Nuclear power plants – Instrumentation and control important to safety – Development of HDL-programmed integrated circuits*, can be found on the IEC website.

In this document, the following print types are used:

- *Requirements and recommendations applicable specifically to class 3 or to class 2 systems appear in italics.*

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN IEC 62566-2:2021](https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-5c904d5add76/sist-en-iec-62566-2-2021)

<https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-5c904d5add76/sist-en-iec-62566-2-2021>

## INTRODUCTION

### a) Technical background, main issues and organisation of the Standard

Electronic systems performing category B and C functions (according to IEC 61226) used in Nuclear Power Plants (NPPs) need to be fully validated and qualified according to their safety class. This International Standard provides requirements for the development of class 2 or 3 HDL (Hardware Description Language) Programmed Devices (HPDs) performing category B or C functions as defined by IEC 61226. It complements IEC 62566 which provides requirements for the development of HPDs performing category A functions.

In computer-based systems, a separation can be drawn between the hardware and software portions. The hardware is mainly designed with standardised components having pre-defined electronic functions such as microprocessors, timers or network controllers, whereas software is used to coordinate the different parts of the hardware and to implement the application functions.

I&C designers might build application functions using integrated circuits such as FPGAs or similar technologies. The function of such an integrated circuit is not defined by the supplier of the physical component or micro-electronic technology but by the I&C designer.

The specific integrated circuits addressed by this Standard are:

- a) based on pre-developed micro-electronic technologies,
- b) developed within an I&C project,
- c) developed in Hardware Description Languages (HDL) by using appropriate and compatible development tools.

Therefore these circuits are named "HDL-Programmed Devices" (HPD). The HDL statements which describe a HPD can include the instantiation of Pre-Developed Blocks (PDB) which are typically provided as libraries, macros, or intellectual property cores.

HPDs can be effective solutions to implement functions required by an I&C project. However, the verification and validation might be limited by issues such as high number of internal paths and limited observability, if the HPD has not been developed with verifiability in mind.

In order to achieve the reliability required for safety I&C systems, the development of HPDs shall comply with strict process and technical requirements such as those provided by this Standard, including the specification of requirements, the selection of blank integrated circuits and PDBs, the design and implementation, the verification, and the procedures for operation and maintenance.

It is intended that this Standard be used by HPD designers, operators of NPPs (utilities), and by regulators. Regulatory bodies will find guidance to assess important aspects such as design, implementation, verification and validation of HPDs.

### b) Situation of the current Standard in the structure of the IEC SC 45A standard series

IEC 61513 is a first level IEC SC 45A document and gives guidance applicable to I&C at the system level. It is supplemented by guidance at the hardware level (IEC 60987), software level (IEC 60880 and IEC 62138) and HPD level (IEC 62566 and IEC 62566-2). IEC 62340 gives requirements in order to reduce and overcome the possibility of common cause failure of category A functions.

IEC 62566-2 is a second level IEC SC 45A document which focuses on the activities when HPDs performing category B or C functions are developed. For HPDs performing category B functions, it complements IEC 60987 which deals with the generic issues of hardware design of computer-based systems.

### c) Recommendations and limitations regarding the application of the Standard

It is important to note that this Standard establishes no additional functional requirements for safety systems.

Aspects for which special requirements and recommendations have been produced are:

- a) an approach to specify the requirements of, to design, to implement and to verify “HDL-Programmed Devices” (HPD, 3.20), and to handle the corresponding aspects of system integration and validation;
- b) an approach to analyse and select the blank integrated circuits, micro-electronic technologies and Pre-Developed Blocks (PDB, 3.29) used to develop HPDs;
- c) procedures for the modification and configuration control of HPDs;
- d) requirements for selection and use of software tools used to develop HPDs.

It is recognized that digital technology is continuing to develop at a rapid pace and that it is not possible for a Standard such as this one to include references to all modern design technologies and techniques.

## iTeh STANDARD PREVIEW

To ensure that the Standard will continue to be relevant in future years the emphasis has been placed on issues of principle, rather than specific technologies. If new techniques are developed then it should be possible to assess the suitability of such techniques by applying the safety principles contained within this Standard.

<https://standards.iteh.ai/catalog/standards/sist/7aa32e5d-c543-4aa8-a8c0-c90d158d1c01/iec-62566-2:2020>

### d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

The top-level documents of the IEC SC 45A standard series are IEC 61513 and IEC 63046. IEC 61513 provides general requirements for I&C systems and equipment that are used to perform functions important to safety in NPPs. IEC 63046 provides general requirements for electrical power systems of NPPs; it covers power supply systems including the supply systems of the I&C systems. IEC 61513 and IEC 63046 are to be considered in conjunction and at the same level. IEC 61513 and IEC 63046 structure the IEC SC 45A standard series and shape a complete framework establishing general requirements for instrumentation, control and electrical systems for nuclear power plants.

IEC 61513 and IEC 63046 refer directly to other IEC SC 45A standards for general topics related to categorization of functions and classification of systems, qualification, separation, defence against common cause failure, control room design, electromagnetic compatibility, cybersecurity, software and hardware aspects for programmable digital systems, coordination of safety and security requirements and management of ageing. The standards referenced directly at this second level should be considered together with IEC 61513 and IEC 63046 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 or by IEC 63046 are standards related to specific equipment, technical methods, or specific activities. Usually these documents, which make reference to second-level documents for general topics, can be used on their own.

A fourth level extending the IEC SC 45 standard series, corresponds to the Technical Reports which are not normative.

The IEC SC 45A standards series consistently implements and details the safety and security principles and basic aspects provided in the relevant IAEA safety standards and in the relevant documents of the IAEA Nuclear Security Series (NSS). In particular this includes the IAEA requirements SSR-2/1, establishing safety requirements related to the design of Nuclear Power Plants (NPPs), the IAEA safety guide SSG-30 dealing with the safety classification of structures, systems and components in NPPs, the IAEA safety guide SSG-39 dealing with the design of instrumentation and control systems for NPPs, the IAEA safety guide SSG-34 dealing with the design of electrical power systems for NPPs and the implementing guide NSS17 for computer security at nuclear facilities. The safety and security terminology and definitions used by SC 45A standards are consistent with those used by the IAEA.

IEC 61513 and IEC 63046 have adopted a presentation format similar to the basic safety publication IEC 61508 with an overall life-cycle framework and a system life-cycle framework. Regarding nuclear safety, IEC 61513 and IEC 63046 provide the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector. In this framework IEC 60880, IEC 62138 and IEC 62566 correspond to IEC 61508-3 for the nuclear application sector. IEC 61513 and IEC 63046 refer to ISO as well as to IAEA GS-R part 2 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA). At level 2, regarding nuclear security, IEC 62645 is the entry document for the IEC/SC 45A security standards. It builds upon the valid high level principles and main concepts of the generic security standards, in particular ISO/IEC 27001 and ISO/IEC 27002; it adapts them and completes them to fit the nuclear context and coordinates with the IEC 62443 series. At level 2, IEC 60964 is the entry document for the IEC/SC 45A control rooms standards and IEC 62342 is the entry document for the ageing management standards.

NOTE 1 It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, process energy hazards) international or national standards would be applied.

NOTE 2 IEC/SC 45A domain was extended in 2013 to cover electrical systems. In 2014 and 2015 discussions were held in IEC/SC 45A to decide how and where general requirement for the design of electrical systems were to be considered. IEC/SC 45A experts recommended that an independent standard be developed at the same level as IEC 61513 to establish general requirements for electrical systems. Project IEC 63046 is now launched to cover this objective. When IEC 63046 is published this NOTE 2 of the introduction of IEC/SC 45A standards will be suppressed.