

SLOVENSKI STANDARD

SIST EN 14459:2022

01-april-2022

Nadomešča:
SIST EN 14459:2016

**Varnostne in nadzorne naprave za gorilnike in aparate na plin ali tekoča goriva -
Regulacijske in nadzorne funkcije v elektronskih sistemih - Metode za razvrščanje
in ocenjevanje**

Safety and control devices for burners and appliances burning gaseous or liquid fuels -
Control functions in electronic systems - Methods for classification and assessment

Sicherheits- und Regeleinrichtungen für Brenner und Brennstoffgeräte für gasförmige
oder flüssige Brennstoffe - Regel- und Steuerfunktionen in elektronischen Systemen -
Verfahren für die Klassifizierung und Bewertung

Dispositifs de commande et de sécurité pour brûleurs et appareils utilisant des
combustibles gazeux ou liquides - Fonctions de commande des systèmes électroniques
- Méthodes de classification et dévaluation

Ta slovenski standard je istoveten z: EN 14459:2021

ICS:

27.060.01	Gorilniki in grelniki vode na splošno	Burners and boilers in general
91.140.40	Sistemi za oskrbo s plinom	Gas supply systems
97.100.01	Grelniki na splošno	Heating appliances in general

SIST EN 14459:2022

en,fr,de

**iTeh STANDARD
PREVIEW
(standards.iteh.ai)**

SIST EN 14459:2022

<https://standards.iteh.ai/catalog/standards/sist/93d433d9-50d3-4685-ba46-b9479c5e7869/sist-en-14459-2022>

EUROPEAN STANDARD

EN 14459

NORME EUROPÉENNE

EUROPÄISCHE NORM

November 2021

ICS 91.140.40; 97.100.20

Supersedes EN 14459:2015

English Version

Safety and control devices for burners and appliances burning gaseous or liquid fuels - Control functions in electronic systems - Methods for classification and assessment

Dispositifs de commande et de sécurité pour brûleurs
et appareils utilisant des combustibles gazeux ou
liquides - Fonctions de commande des systèmes
électroniques - Méthodes de classification et
d'évaluation

Sicherheits- und Regeleinrichtungen für Brenner und
Brennstoffgeräte für gasförmige oder flüssige
Brennstoffe - Regel- und Steuerfunktionen in
elektronischen Systemen - Verfahren für die
Klassifizierung und Bewertung

This European Standard was approved by CEN on 24 October 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	4
Introduction	5
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions	6
4 Classification.....	6
4.1 Classes of control	6
4.2 Groups of control	6
4.3 Classes of control functions.....	6
4.4 Types of <i>DC</i> supplied controls	6
5 Test conditions and uncertainty of measurements.....	6
6 Design and construction.....	7
6.1 General.....	7
6.2 Mechanical parts of the control.....	7
6.3 Materials	7
6.4 Gas connections.....	7
6.5 Electrical parts of the control.....	7
6.6 Protection against internal faults for the purpose of functional safety.....	7
6.101 Requirements for new control solutions	7
6.101.1 General	7
6.101.2 Assessment of the appliance	7
6.101.3 Translation into control requirements	8
7 Performance	8
7.1 General.....	8
7.2 Leak-tightness.....	8
7.3 Torsion and bending.....	8
7.4 Rated flow rate.....	9
7.5 Durability.....	9
7.6 Performance tests for electronic controls	9
7.7 Long-term performance for electronic controls.....	9
7.8 Data exchange	9
7.101 Combined apparatus.....	9
8 Electrical requirements.....	9
8.1 General.....	9
8.2 Protection by enclosure.....	9
9 Electromagnetic compatibility (EMC)	9
9.1 Protection against environmental influences	9
9.2 Supply voltage variations below 85 % of rated voltage.....	9
9.3 Voltage dips and interruptions.....	9
9.4 Supply frequency variations	10
9.5 Surge immunity tests.....	10
9.6 Electrical fast transient/burst.....	10
9.7 Immunity to conducted disturbances induced by radio frequency fields	10
9.8 Immunity to radiated disturbances induced by radio frequency fields	10

9.9	Electrostatic discharge test.....	10
9.10	Power frequency magnetic field immunity tests	10
9.11	Harmonics and interharmonics including mains signalling at a. c. power port, low frequency immunity tests.....	10
10	Marking, instructions.....	10
10.1	Marking	10
10.2	Instructions.....	10
10.3	Warning notice	10
	Annex A (informative) Abbreviations and symbols	11
	Annex B (informative) Leak-tightness tests for gas controls - volumetric method	12
	Annex C (informative) Leak-tightness tests for gas controls - pressure loss method.....	13
	Annex D (normative) Calculation of pressure loss into leakage rate	14
	Annex E (normative) Electrical/electronic component fault modes	15
	Annex F (normative) Additional requirements for safety accessories and pressure accessories as defined in EU Directive 2014/68/EU.....	16
	Annex G (normative) Materials for pressurized parts	17
	Annex H (normative) Additional materials for pressurized parts.....	18
	Annex I (normative) Requirements for controls used in <i>DC</i> supplied burners and appliances burning gaseous or liquid fuels.....	19
	Annex J (normative) Method for the determination of a Safety Integrity Level (SIL).....	20
	Annex K (normative) Method for the determination of a Performance Level (PL)	21
	Annex L (informative) Relationship between Safety Integrity Level (SIL) and Performance Level (PL).....	22
	Annex M (normative) Reset functions.....	23
	Annex N (informative) Guidance document on Environmental Aspects	24
	Annex O (normative) Seals of elastomer, cork and synthetic fibre mixtures	25
	Annex AA (informative) Example of a risk assessment method.....	26
	Annex BB (informative) Example of a risk assessment according to method described in Annex AA.....	28
BB.1	General	28
BB.2	Risks	28
BB.3	Risk assessment	28
	Annex CC (informative) Realization of a protective measure.....	31
	Annex DD (informative) Hazards in gas and oil appliances handled by control functions	33
	Annex EE (informative) Classification of control functions based on the determination of basic risks.....	37
	Bibliography	41

EN 14459:2021 (E)**European foreword**

This document (EN 14459:2021) has been prepared by Technical Committee CEN/TC 58 “Safety and control devices for burners and appliances burning gaseous or liquid fuels”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2022, and conflicting national standards shall be withdrawn at the latest by May 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 14459:2015.

The following significant changes compared to the previous edition have been incorporated in this document:

- a) Alignment with EN 13611:2019;
- b) Clause 2 “Normative references” has been updated;
- c) The Bibliography has been updated.

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

This document is intended to be used in conjunction with EN 13611:2019.

This document refers to clauses of EN 13611:2019 or adapts it by stating “with the following modification”, “with the following addition”, “is replaced by the following” or “is not applicable” in the corresponding clause.

This document adds clauses or subclauses to the structure of EN 13611:2019 which are particular to this document. Subclauses which are additional to those in EN 13611 are numbered starting from 101. Additional Annexes are designated as Annex AA, Annex BB, Annex CC, etc. It should be noted that these clauses, subclauses and Annexes are not indicated as an addition.

Control systems are designed to control and protect gas and/or oil appliances and the combustion process. All functions are performed depending on their safety relevance within a specific tolerance of measures and time with a specific certainty under external influences and internal failures.

It was concluded by CEN/TC 58 that it is not always necessary to protect against the consequences of hazardous events with uniform measures as hazards differ in severity and the probability of unwanted occurrences may differ. As there exist large differences of interpretation on what level of protection is necessary against certain hazards, there is a need for guidance to bring the safety philosophy for gas and oil appliances and controls in line. The discussions of CEN/TC 58 regarding safety related control functions and the use of control systems in the appliances show that it is worthwhile to refine the basic safety philosophy of gas and oil appliances into different risk levels.

For the evaluation of preventative measures concerning fault tolerance and avoidance of hazards, it is essential to classify control functions with regard to their fault behaviour. For the classification of control functions, their integration into the complete safety concept of the appliance should be taken into account.

In the appliance standards, only specific fault conditions are considered when controls conforming to CEN/TC 58 standards are used, e.g. flame simulation and air proving before each new start. In some cases (e.g. switch contacts) shorting is excluded, when certain tests have proven that the probability of a fault occurrence is low. For gas valves, a single shut-off valve is considered insufficient.

This document gives methods for the assessment of control functions in controls for burners and appliances burning one or more gaseous or liquid fuels for which no specific product standards are actually available. The assessment is described in three steps:

- assessment of the application,
- translation into control requirements,
- assessment of the control solution,

leading to defined classes for the specified control function(s) and a set of safety measures with additional/modified construction and test requirements for the application and/or the specified control function(s).

The assessment is focused on the controlled parameters (e.g. high/low temperature, pressure, flow, combustion quality) in the combustion process and in the functionality of the controls (e.g. open/closed; lock/unlock; start/stop). Each control function needs to be classified according to the required safety aspects (Class A, B, C).

To analyse the effect of fault conditions it is essential to know the specific application and to determine the related risks.

EN 14459:2021 (E)

1 Scope

EN 13611:2019, Clause 1 is replaced by the following:

This document specifies methods for the classification and assessment of function blocks for burners and appliances burning one or more gaseous or liquid fuels with particular regards to their fault behaviour and preventative measures.

This document is applicable to new control function blocks, not covered by dedicated control standards.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13611:2019, *Safety and control devices for burners and appliances burning gaseous and/or liquid fuels - General requirements*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 13611:2019 apply with the following modifications.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.101

function block

part of an electric or electronic system which realises at least one control function with one input and one output signal

4 Classification

4.1 Classes of control

EN 13611:2019, 4.1 is not applicable.

4.2 Groups of control

Shall be according to EN 13611:2019, 4.2.

4.3 Classes of control functions

Shall be according to EN 13611:2019, 4.3 with the following addition:

The class of the control function shall be determined from the results of the risk assessment in 6.101 and specified in the instructions.

4.4 Types of DC supplied controls

Shall be according to EN 13611:2019, 4.4.

5 Test conditions and uncertainty of measurements

Shall be according to EN 13611:2019, Clause 5.

6 Design and construction

6.1 General

Shall be according to EN 13611:2019, 6.1 with the following addition:

The specific assessment shall be performed according to 6.101. Its outcome shall be verified concerning its impact to the applicability of 6.1 to 6.6.

6.2 Mechanical parts of the control

Shall be according to EN 13611:2019, 6.2.

6.3 Materials

Shall be according to EN 13611:2019, 6.3.

6.4 Gas connections

Shall be according to EN 13611:2019, 6.4.

6.5 Electrical parts of the control

Shall be according to EN 13611:2019, 6.5.

6.6 Protection against internal faults for the purpose of functional safety

Shall be according to EN 13611:2019, 6.6.

6.101 Requirements for new control solutions

6.101.1 General

Appliance designs are based on safe operation avoiding any harm for persons, domestic animals or property when normally used. Possible hazards arising from the appliance can be expressed in inherent risks, being considered in relation to the combustion (use) of gas and oil and heating of water.

For known control and appliance solutions, risks are considered to be covered by the requirements in the dedicated control standards and appliance standards.

Appliances with new control solutions shall be subjected to a further risk assessment according to 6.101.2 depending on their design, either:

- well-known appliance designs, or
- new appliance solutions.

6.101.2 Assessment of the appliance

The required protective measures, resulting from a risk assessment on the new or well-known appliance design or solution are the basis for the assessment of new control solutions. The risk assessment shall be performed and documented in order to identify the risks and the required protective measures covering these risks.

At least the following information shall be specified:

- classification of basic hazards;
 - Annex AA gives examples of existing basic hazards in gas and/or oil appliances;
- risk assessment and the resulting protective measures;

EN 14459:2021 (E)

- Annex EE specifies a method for classification of control functions;
- classification of protective measures;
- fault tolerating time for specific faults;
- additional requirements for the application.

Based on this information the following measures may be taken:

- specification of controls according to known control standards; and/or
- additional appliance construction requirements; and/or
- specification of new type of control based on the required protective measure and/or the additional requirements.

In Annex AA, a risk assessment method on appliance level is given.

In Annex BB and Annex DD examples are given for the method described in Annex AA.

6.101.3 Translation into control requirements

If – based on the outcome of the risk assessment on the appliance – new types of controls are required, the protective measures and, where possible, the additional requirements from this risk assessment have to be translated into control requirements.

A further assessment on the foreseen control solution shall be performed and documented including the assumptions made and reasoning how the required safety level is achieved.

This outcome shall lead to a conclusion:

- on relevant class of control function(s) according to 4.3;
- on additional or modified construction(s), performance or EMC requirements;
- on further fault modes to be considered in the fault assessment of 6.6;
- on the need to extend the list of markings and the contents of the instructions.

For specific faults, a fault reaction time shall be specified for the control, taking into account the fault tolerating time of the application as a maximum.

Annex CC provides guidance for the realization of protective measures by controls.

7 Performance**7.1 General**

Shall be according to EN 13611:2019, 7.1 with the following addition:

The outcome of the specific assessment according to 6.101 shall be verified concerning its impact to the applicability of the requirements of Clause 7.

7.2 Leak-tightness

Shall be according to EN 13611:2019, 7.2.

7.3 Torsion and bending

Shall be according to EN 13611:2019, 7.3.

7.4 Rated flow rate

Shall be according to EN 13611:2019, 7.4.

7.5 Durability

Shall be according to EN 13611:2019, 7.5.

7.6 Performance tests for electronic controls

Shall be according to EN 13611:2019, 7.6.

7.7 Long-term performance for electronic controls

Shall be according to EN 13611:2019, 7.7.

7.8 Data exchange

Shall be according to EN 13611:2019, 7.8.

7.101 Combined apparatus

If a system consists of two or more combined apparatuses with different control functions, the interconnection and interference of the involved apparatus shall be considered during fault assessment.

Safety of a control function shall not be impaired by its integration in a gas or oil appliance or system.

Responsibilities and safety critical interface parameters shall be declared for incorporating the control in an over-all-system.

8 Electrical requirements

8.1 General

Shall be according to EN 13611:2019, 8.1 with the following addition:

The outcome of the specific assessment according to 6.101 shall be verified concerning its impact to the applicability of the requirements of Clause 8.

NOTE Depending on the outcome of the assessment according to 6.101, EN 60730-1 and specific part of EN 60730-2 can be applicable.

8.2 Protection by enclosure

Shall be according to EN 13611:2019, 8.2.

9 Electromagnetic compatibility (EMC)

9.1 Protection against environmental influences

Shall be according to EN 13611:2019, 9.1 with the following addition:

The outcome of the specific assessment according to 6.101 shall be verified concerning its impact to the applicability of the requirements of Clause 9.

9.2 Supply voltage variations below 85 % of rated voltage

Shall be according to EN 13611:2019, 9.2.

9.3 Voltage dips and interruptions

Shall be according to EN 13611:2019, 9.3.

EN 14459:2021 (E)**9.4 Supply frequency variations**

Shall be according to EN 13611:2019, 9.4.

9.5 Surge immunity tests

Shall be according to EN 13611:2019, 9.5.

9.6 Electrical fast transient/burst

Shall be according to EN 13611:2019, 9.6.

9.7 Immunity to conducted disturbances induced by radio frequency fields

Shall be according to EN 13611:2019, 9.7.

9.8 Immunity to radiated disturbances induced by radio frequency fields

Shall be according to EN 13611:2019, 9.8.

9.9 Electrostatic discharge test

Shall be according to EN 13611:2019, 9.9.

9.10 Power frequency magnetic field immunity tests

Shall be according to EN 13611:2019, 9.10.

9.11 Harmonics and interharmonics including mains signalling at a. c. power port, low frequency immunity tests

Shall be according to EN 13611:2019, 9.11.

10 Marking, instructions**10.1 Marking**

[SIST EN 14459:2022
https://standards.iteh.ai/catalog/standards/sist/93d433d9-50d3-4685-ba46-b9479c5e7869/sist-en-14459-2022](https://standards.iteh.ai/catalog/standards/sist/93d433d9-50d3-4685-ba46-b9479c5e7869/sist-en-14459-2022)

Shall be according to EN 13611:2019, 10.1 with the following addition:

Further requirements for marking shall be determined from the specific assessment according to 6.101.

10.2 Instructions

Shall be according to EN 13611:2019, 10.2 with the following addition:

Further requirements for information in instructions shall be determined from the specific assessment according to 6.101.

10.3 Warning notice

Shall be according to EN 13611:2019, 10.3.

Annex A
(informative)

Abbreviations and symbols

Shall be according to EN 13611:2019, Annex A.

**iTeh STANDARD
PREVIEW
(standards.iteh.ai)**

[SIST EN 14459:2022](https://standards.iteh.ai/catalog/standards/sist/93d433d9-50d3-4685-ba46-b9479c5e7869/sist-en-14459-2022)

<https://standards.iteh.ai/catalog/standards/sist/93d433d9-50d3-4685-ba46-b9479c5e7869/sist-en-14459-2022>