
**Petroleum, petrochemical and
natural gas industries — Prevention
of corrosion on pipeline systems
influenced by stray currents**

*Industries du pétrole, de la pétrochimie et du gaz naturel —
Prévention de la corrosion sur les systèmes de conduites soumis à
l'influence de courants vagabonds*

iteh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO 21857:2021

<https://standards.iteh.ai/catalog/standards/iso/c59efd22-a36c-4552-8862-19549d39f173/iso-21857-2021>



iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO 21857:2021

<https://standards.iteh.ai/catalog/standards/iso/c59efd22-a36c-4552-8862-19549d39f173/iso-21857-2021>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	v
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Abbreviations and symbols	3
4.1 Abbreviations	3
4.2 Symbols	4
5 Information exchange and co-operation	5
6 Common sources of interference that can affect corrosion	6
6.1 General	6
6.2 Direct current	7
6.2.1 General	7
6.2.2 Traction systems	7
6.2.3 Industrial systems	7
6.3 Alternating current	7
6.3.1 General	7
6.3.2 Overhead and buried power lines	8
6.4 High-voltage direct current transmission systems	8
6.5 Natural interference	8
6.5.1 General	8
6.5.2 Geomagnetic (telluric) interference	8
6.5.3 Tidal interference effects	9
7 Identification and measurement of stray current interference	9
7.1 Principle	9
7.2 Stray Current interference	10
7.2.1 Inductive and conductive coupling from remote sources	10
7.2.2 Conductive coupling from nearby sources	10
7.3 Measurement of electrical parameters	10
7.3.1 Data acquisition systems	10
7.3.2 Possible errors in AC measurements	11
7.3.3 Potential measurement	11
7.3.4 Current measurement on probes	11
7.3.5 IR-free potential measurement on coupons or probes	11
7.3.6 Duration of the measurement	11
7.3.7 Specific requirements for coupons or probes	12
7.4 Corrosion rate measurement	12
8 Acceptance criteria for DC interference	12
8.1 Overview of criteria	12
8.2 Corrosion rate	13
8.3 Criteria for steel and cast iron	14
8.3.1 Time constant interference	14
8.3.2 Time variant interference	15
8.4 Criteria for steel pipes in concrete based on potential measurements without cathodic protection	16
8.4.1 Time constant anodic interference	16
8.4.2 Time variant interference	16
9 Reduction of DC stray current interference	16
9.1 General	16
9.2 Modifications to the source of interference	17
9.2.1 Principles	17

9.2.2	Direct current systems at industrial sites	17
9.2.3	Direct current systems at ports.....	17
9.2.4	Direct current traction systems	17
9.2.5	Cathodic protection systems	18
9.2.6	Telluric interference.....	19
9.2.7	Direct current communication systems.....	19
10	Modifications to the interfered structure	19
10.1	General.....	19
10.2	Design prerequisites	20
10.2.1	Coatings	20
10.2.2	Isolation from other structures.....	20
10.2.3	Distance to be maximized.....	20
10.2.4	Installation of mitigation devices	20
10.2.5	Modifying the electrical continuity of the interfered structure	21
11	Inspection and maintenance.....	22
Annex A	(informative) Use of current probes to evaluate fluctuating stray current interference on cathodically protected structures	23
Annex B	(informative) Determining the relevant position for placing reference electrodes, coupons and probes in case of any conductive coupling caused by stray currents	26
Annex C	(informative) Operating principles of electrical resistance probes	33
Annex D	(informative) Geomagnetic interference	34
Annex E	(informative) High voltage direct current interference	43
Annex F	(informative) Alternating Current Interference	45
Annex G	(informative) Tidal Effects	50
Annex H	(informative) Photovoltaic interference	51
Annex I	(informative) Modelling the effects of stray current interference on cathodically protected pipelines	54
Annex J	(informative) Assessment of the corrosion risk for steel in concrete or for cathodically protected structures under time variant interference conditions	58
Annex K	(informative) Principles of anodic and cathodic interference	63
Bibliography	66

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 67, *Materials, equipment and offshore structures for petroleum, petrochemical and natural gas industries*, Subcommittee SC 2, *Pipeline transportation systems*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 219, *Cathodic protection*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document provides guidance for the prevention of external corrosion when a pipeline is influenced by electrical interference. Electrical interference can be from stray currents (defined in ISO 8044) and from naturally occurring interference caused by geomagnetic or tidal activity.

International Standards on cathodic protection (e.g. ISO 15589-1 and ISO 15589-2) refer to a structure-to-electrolyte potential value that is considered to indicate that cathodic protection is effective. When the potential is influenced by stray currents, however, it is not always possible to obtain a meaningful structure-to-electrolyte potential and other methods of assessment are needed. These other methods can include mathematical analysis of the potentials and/or direct assessment of the corrosion rate using electrical resistance probes.

An affected structure carrying stray currents, e.g. a pipeline or cable can itself affect other nearby structures.

This document is not intended to inhibit the use of alternative equipment or engineering solutions for individual applications. Where an alternative is offered, it is intended that any variations from this document be identified and documented.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[ISO 21857:2021](https://standards.iteh.ai/catalog/standards/iso/c59efd22-a36c-4552-8862-19549d39f173/iso-21857-2021)

<https://standards.iteh.ai/catalog/standards/iso/c59efd22-a36c-4552-8862-19549d39f173/iso-21857-2021>

Petroleum, petrochemical and natural gas industries — Prevention of corrosion on pipeline systems influenced by stray currents

1 Scope

This document establishes the general principles for the evaluation and minimization of the effects of stray current corrosion on external surfaces of buried or immersed pipeline systems caused by AC and DC electrical interference.

Other stray current effects such as overheating, and interference with welding operations are not covered in this document.

A brief description of AC effects, general principles and some guidelines, are provided.

NOTE 1 See ISO 18086 for the effects of alternating current on buried or immersed pipelines.

Systems that can also be affected by stray currents include buried or immersed metal structures such as the following:

- a) pipeline systems;
- b) metal sheathed cables;
- c) tanks and vessels;
- d) earthing systems;
- e) steel reinforcement in concrete;
- f) sheet steel piling.

This document gives guidelines for

- the design of cathodic protection systems that might produce stray currents,
- the design of pipeline systems, or elements of pipeline systems, which are buried or immersed, and which can be subject to stray current corrosion, and
- the selection of appropriate protection or mitigation measures.

Internal corrosion risks from stray currents are not dealt with in detail in this document but principles and measures described here can be applicable for minimizing the interference effects.

NOTE 2 The impact of electromagnetic interference on above-ground appurtenances of pipeline systems is covered in EN 50443, IEC 61140, IEC 60364-4-41, IEC 60479-1, IEC 60364-5-52, IEC/TS 61201 and IEC/TR 60479-5.

This document can also be used for pipeline systems outside of the petrochemical and natural gas industries and other buried or immersed structures.

NOTE 3 EN 50162 provides guidance for railway related structures.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62128-2:2013, *Railway applications - Fixed installations - Electrical safety, earthing and the return circuit - Part 2: Provisions against the effects of stray currents caused by d.c. traction systems*

ISO 15589-1, *Petroleum, petrochemical and natural gas industries — Cathodic protection of pipeline systems — Part 1: On-land pipelines*

ISO 8044, *Corrosion of metals and alloys — Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 15589-1, IEC 62128-2:2013, ISO 8044 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1 coating

electrically insulating covering bonded to a metal surface for protection against corrosion by preventing contact between the electrolyte and the metal surface

3.2 remote earth

theoretical concept that refers to a ground electrode of zero impedance placed an infinite distance away from the ground under test

Note 1 to entry: In practice, remote earth is approached when the mutual resistance between the ground under test and the test electrode becomes negligible. Remote earth is normally considered to be at zero potential.

[SOURCE: IEEE Std 81-2012^[1]]

3.3 conductive coupling

transfer of energy occurring when a part of the current belonging to the interfering system returns to the system earth via the interfered system

Note 1 to entry: Also, when the voltage to the reference earth of the ground in the vicinity of the influenced object rises because of a fault in the interfering system, and the results of which are conductive voltages and currents.

3.4 drainage electrical drainage

transfer of stray current from an affected structure to the current source by means of a deliberate bond

Note 1 to entry: For drainage devices see *direct drainage bond* (3.5), *unidirectional drainage bond* (3.7) and *forced drainage bond* (3.6).

3.5 direct drainage bond

device that provides *electrical drainage* (3.4) by means of a bi-directional, metallic bond between an affected structure and the stray current source

Note 1 to entry: The bond can include a series resistor to reduce the current.

3.6**forced drainage bond**

device that provides *electrical drainage* (3.4) by means of a bond between an affected structure and the stray current source

Note 1 to entry: The bond includes a separate source of DC power to augment the transfer of current.

3.7**unidirectional drainage bond**

device that provides *electrical drainage* (3.4) by means of a unidirectional bond between the affected structure and the stray current source

Note 1 to entry: The bond includes a device such as a diode to ensure that current can only flow in one direction.

3.8**telluric interference**

voltages generated by geomagnetic field variations that cause variations in the observed pipe-to-soil potentials

3.9**electrical resistance probe****ER probe**

device that measures metal loss by comparison of the calibrated resistance value of a piece of metal with known physical characteristics

3.10**sampling rate**

measuring interval set by the operator

3.11**alternating current interference****AC interference**

electrical disturbance generated by AC systems that affects buried or immersed pipelines by conduction and/or induction

ISO 21857:2021

Note 1 to entry: Powerlines, railway traction systems.

3.12**direct current interference****DC interference**

disturbance, generated by DC systems, that affects buried or immersed metallic structures primarily by conduction

4 Abbreviations and symbols**4.1 Abbreviations**

AC	Alternating current
ACVG	Alternating current voltage gradient
CP	Cathodic protection
DC	Direct current
DCVG	Direct current voltage gradient
emf	Electromotive force

GIC	Geomagnetically induced currents
HVAC	High voltage alternating current
HVDC	High Voltage Direct Current
IR	Product of the current and resistance (I and R) that indicates the voltage drop error in a potential measurement
PV	Photovoltaic
r.m.s.	Root mean square

4.2 Symbols

a^{-1}	Per annum
B	Magnetic field
E	Structure/soil potential for non cathodically protected structures
E_a	Anodic potential
E_c	Cathodic potential
ΔE	Potential difference due to operation / non-operation of the interfering source
ΔE_a	Anodic potential shift (IR drop included)
$\Delta E_{a,avg}$	Average anodic potential shift
$\Delta E_{a,IR\ free}$	Anodic potential shift (IR drop excluded)
ΔE_c	Cathodic potential shift
ΔE_m	Measured interference
$\Delta E_{c,avg}$	Average cathodic potential shift
E_{cor}	Structure potential of a metal in a given corrosion system (ISO 8044)
$E_{IR-free}$	Structure potential without measurement error due to current flowing in the circuit
E_{on}	ON potential
$E_{on,avg}$	Average ON potential
E_p	Protection potential according to ISO 15589-1
E_{ref}	On potential required to achieve effective cathodic protection
F	Electric field
I_{cpn}	Coupon current
J	Current density
J_a	Anodic current density
J_c	Cathodic current density

J_{cpn}	Coupon current density
J_{ref}	Reference value for current density (analogous to I_{ref})
ρ	Soil resistivity ($\Omega \cdot \text{m}$)
Q_{a}	Anodic charge during the period of anodic interference
Q_{c}	Cathodic charge during the period of cathodic interference
R_{c}	Coupon element resistance
R_{iso}	Isolation resistance, usually of a cable insulation
s	Seconds
$\text{S} \cdot \text{km}^{-1}$	Siemens per unit length
t	Time
T_{a}	Interval when the structure is anodic with respect to the selected value of E_{ref} or J_{ref}
$T_{\text{a,max}}$	Maximum duration of the anodic period
T_{c}	Interval when the structure is cathodic with respect to the selected value of E_{ref} or J_{ref}
v_{cor}	Corrosion rate
V_{CSE}	Voltage with respect to a copper/copper sulfate reference electrode

5 Information exchange and co-operation

Common sources of interference that can cause stray current corrosion are given in [Clause 6](#). During the design stage of buried or immersed metallic pipeline systems, the possibility of both causing and suffering from stray current interference shall be taken into consideration and documented. The pipeline system should achieve the acceptance criteria identified in [Clause 8](#). Construction work, major changes on existing structures, regenerative braking, etc. can require a detailed consideration of the interference situation.

Electrical interference problems on buried or immersed metallic pipeline systems shall be considered, and documented, with the following points in mind:

- The operator of the pipeline system can protect a structure against corrosion with the method that the operator considers to be the most suitable. However, levels of electrical interference on neighbouring structures shall be maintained within the defined limits given in [Clause 8](#)
- Stray currents, especially from DC traction systems, are directly related to the design of the traction return circuits. This means that it is possible to limit the stray current by traction circuit design, but not to eliminate it.
- Where other structures that might be affected are present, the requirement to maintain interference within the defined limits applies to all affected structures.
- Utility-scale photovoltaic (PV) installations can develop a steady state DC interference to adjacent buried pipelines. It is expected that the operator of the PV installation will maintain constant monitoring of the R_{ISO} value to verify the isolation resistance between the PV panels and the earth. The pipeline operator should be informed of any changes in the R_{ISO} values outside the threshold value.
- The operating characteristics of HVDC systems can change under fault and maintenance conditions. These changes can affect the corrosion risk to buried pipelines and such changes should be communicated in a timely manner to the pipeline operator.

These goals are best achieved by agreement, co-operation and information exchange between the parties involved. Information exchange and co-operation are important and shall be carried out both at the design stage and during operation of the systems. In this way possible effects, suitable precautions and remedies can be assessed.

The following information is required to make a sound engineering judgement:

- details of buried metallic structures;
- cathodic protection installations or significant modifications to existing installations;
- DC traction system installations or significant modifications to existing installations;
- HVDC transmission line installation or modification to existing installations or modes of operation;
- details of any sources of DC installations that can cause interferences to buried pipelines;
- utility scale photovoltaic systems.

Agreement and co-operation is more effectively achieved and maintained by periodic meetings between interested parties, committees or other associations who can establish information exchange procedures and protocols.

6 Common sources of interference that can affect corrosion

6.1 General

DC systems that can cause currents to flow in the earth or any other electrolyte, whether intentional or unintentional, include the following:

- a) traction systems;
- b) overhead lines for vehicles;
- c) trolley bus systems;
- d) power systems;
- e) equipment at industrial sites, e.g. welding;
- f) communication systems;
- g) instrumentation systems;
- h) cathodic protection systems;
- i) high voltage transmission systems. See [Annex E](#);
- j) track circuit signalling systems. (For stray currents from traction systems, IEC 62128-2 gives requirements for minimizing their production and for the effects within the railway system);
- k) photovoltaic power systems. See [Annex H](#);
- l) offshore wind farm power systems;
- m) geomagnetic interference (telluric currents). See [Annex D](#);
- n) tidal fluctuations. See [Annex G](#).

AC systems (see [Annex F](#)) that can induce voltages into buried structures include

- three phase power transmission overhead cables,

- buried three phase power cables, and
- AC operated railways.

6.2 Direct current

6.2.1 General

Sources of DC that can affect the structure-to-electrolyte potentials on pipelines can either originate from industrial or natural sources.

6.2.2 Traction systems

There are various configurations of DC traction systems that are in common use. They generally differ in respect of the way that the current is returned to the substation(s). Whichever system configuration is used there will be some current that returns via the earth. IEC 62128-2 gives guidance on permissible limits.

6.2.3 Industrial systems

6.2.3.1 General

Industrial systems that use, or generate, DC should be provided with earthing systems that neither rely on long earth return paths nor deliberately utilize third-party structures for earthing purposes.

6.2.3.2 Welding

Welding return circuits should be configured to ensure that the return paths are as short as possible and do not exacerbate the risk of currents returning via third-party structures.

6.2.3.3 Photovoltaic interference on buried pipelines

Leakage currents in photovoltaic systems originate from a fault or from the systematic and inevitable flow of DC where there is cable insulation damage to PV modules and other array components. Under certain conditions, the DC leakage currents, if left unattended, or not detected at all, can cause accelerated stray current corrosion on metallic underground infrastructure, such as pipelines, buried near large, utility-scale PV systems.

6.3 Alternating current

6.3.1 General

AC powered systems can cause interference on pipelines due to inductive, conductive and capacitive coupling mechanisms, which are described in References [3] and [6].

It is possible that the voltage resulting from interference on the pipe can exceed acceptable levels of touch-potential and/or current densities that will lead to corrosion damage of exposed steel surfaces.

The potentials and current densities that are used to determine the risk of corrosion from AC interference are detailed in References [3] and [6].

[Annex F](#) provides additional information and one method to calculate the induced voltage in a section of pipe.

6.3.2 Overhead and buried power lines

6.3.2.1 General

Overhead power lines can generate unacceptable voltages onto buried pipelines, primarily by induction. The induction is a result of magnetic coupling. The magnitude of the induced voltage depends on the distance, length of parallelism, inducing current magnitude, frequency and phase relationship.

6.3.2.2 Buried power cables

Buried power lines can generate unacceptable voltages onto buried pipelines, primarily by induction, in the same way as overhead power lines. It is preferable if buried cables are laid with the phase cables close to each other and formed in a trefoil configuration. Trefoil formation refers to a method of arranging the individual phase cables to reduce the net inductance because the phases are in anti-phase and cancel each other.

6.3.2.3 Railway systems

AC railway systems can be a source of interference. Where the pipeline is parallel to the railway, the coupling is primarily inductive. The rails of AC powered railways are earthed, and this can also result in conductive coupling to adjacent buried structures. AC railways can operate at 60 Hz, 50 Hz and 16,67 Hz. When evaluating the risks resulting from the effects of electromagnetic interference on buried pipelines running near AC electrified traction systems, the harmonic distortion in railway systems should be considered. The presence of harmonics can exacerbate voltages induced on buried pipelines^[5].

6.4 High-voltage direct current transmission systems

There are two main configurations for high voltage direct current transmission systems, monopolar and bipolar. Bipolar HVDC systems should be given preference to avoid stray current interference. The earthing of HVDC systems shall be designed in such a way as to avoid current flowing through the earth during normal operation and to minimize earth current during faulty or unbalanced load conditions.

The entire system design shall consider the possible high-level of stray currents to which buried or immersed metal structures can be exposed, even at a substantial distance from the electrode station.

Buried HVAC and HVDC cables are joined together in joint bays installed along the cable route. The separation distance between joint bays is dependent on the cable operating voltage, conductor size and construction. Not all joint bays will have an earth local to the joint bay, but the cable screens will be bonded in each joint bay. The location of all earths should be advised by the cable system operator. Where an operator decides to install an earth at a joint bay the earth should be installed at a distance from buried pipelines that will ensure that the touch voltage created on a pipeline during fault conditions is within safe limits. AC and DC leakage currents through earth systems can also result in interference on buried utilities and should be minimized.

Additional information is given in [Annex E](#).

6.5 Natural interference

6.5.1 General

Natural low frequency interference is caused by geomagnetic field variations and by tidal water movements.

6.5.2 Geomagnetic (telluric) interference

Geomagnetic field variations are variations in the earth's magnetic field. The geomagnetic field variations induce electric currents in the Earth and in long conductors such as pipelines and power