

SLOVENSKI STANDARD
SIST EN IEC 61084-2-3:2024/A11:2024

01-november-2024

**Sistemi kabelskih korit in sistemi kabelskih cevi za električne inštalacije - 2-3. del:
Posebne zahteve - Utorski sistemi kabelskih korit za inštalacije v priključnih
omaricah - Dopolnilo A11**

Cable trunking systems and cable ducting systems for electrical installations - Part 2-3:
Particular requirements - Slotted cable trunking systems intended for installation in
cabinets

Elektroinstallationskanalsysteme für elektrische Installationen - Teil 2-3: Besondere
Anforderungen an Verdrahtungskanäle zum Einbau in Schaltschränke
(<https://standards.iteh.ai>)

Systèmes de goulottes et systèmes de conduits-profilés pour installations électriques -
Partie 2-3: Exigences particulières - Systèmes de goulottes de câblage pour installation
dans les armoires

SIST EN IEC 61084-2-3:2024/A11:2024

<https://standards.iteh.ai/catalog/standards/sist/9f93e36d-c0c3-42ef-8adf-c7d2a141595b/sist-en-iec-61084-2-3-2024-a11-2024>

Ta slovenski standard je istoveten z: EN IEC 61084-2-3:2024/A11:2024

ICS:

| | | |
|-----------|--|-------------------------------------|
| 29.120.10 | Inštalacijske cevi za električne namene | Conduits for electrical purposes |
|-----------|--|-------------------------------------|

SIST EN IEC 61084-2-3:2024/A11:2024 en

**EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM**

EN IEC 61084-2-3:2024/A11

September 2024

ICS 29.060.01; 29.120.10

English Version

Cable trunking systems and cable ducting systems for electrical installations - Part 2-3: Particular requirements - Slotted cable trunking systems intended for installation in cabinets

Systèmes de goulottes et systèmes de conduits-profilés pour installations électriques - Partie 2-3: Exigences particulières - Systèmes de goulottes de câblage pour installation dans les armoires

Installationskanalsysteme für elektrische Installationen - Teil 2-3: Besondere Anforderungen - Verdrahtungskanäle zum Einbau in Schaltschränke

This amendment A11 modifies the European Standard EN IEC 61084-2-3:2024; it was approved by CENELEC on 2024-08-05. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

https://standards.sist-en-iec-61084-2-3-2024-a11-2024



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

EN IEC 61084-2-3:2024/A11:2024 (E)

| | Page |
|---|----------|
| 1 Modification to Clause 2, “Normative references” | 4 |
| 2 Modification to Clause 10, “Mechanical properties” | 4 |
| 3 Modification to Clause 13, “Fire hazard” | 4 |
| 4 Modification to Figure 103, “Fixing distances for cable support test” | 4 |
| 5 Modification to Annex B, “CTS/CDS IK code” | 4 |
| 6 Addition of Annex C, “Compliance checks to be carried out for cable trunking systems and cable ducting systems currently complying with EN 50085-2-3:2010 in order to comply with EN IEC 61084-2-3:2024” | 5 |
| 7 Addition of Annex ZA, “Normative references to international publications with their corresponding European publications” | 7 |
| 8 Addition of Annex ZZ, “Relationship between this European standard and the safety objectives of Directive 2014/35/EU [2014 OJ L96] aimed to be covered” | 8 |

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[SIST EN IEC 61084-2-3:2024/A11:2024](https://standards.iteh.ai/catalog/standards/sist/9f93e36d-c0c3-42ef-8adf-c7d2a141595b/sist-en-iec-61084-2-3-2024-a11-2024)

<https://standards.iteh.ai/catalog/standards/sist/9f93e36d-c0c3-42ef-8adf-c7d2a141595b/sist-en-iec-61084-2-3-2024-a11-2024>

European foreword

This document (EN IEC 61084-2-3:2024/A11:2024) has been prepared by CLC/TC 213 “Cable management systems”.

The following dates are fixed:

- latest date by which this document has (dop) 2025-08-05
to be implemented at national level by publication of an identical national standard or by endorsement
- latest date by which the national (dow) 2029-08-05 standards conflicting with this document have to be withdrawn

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document is used in conjunction with EN IEC 61084-1:2024 and EN IEC 61084-1:2024/A11:2024.

This document has been prepared under a standardization request addressed to CENELEC by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

For the relationship with EU Legislation, see informative Annex ZZ, which is an integral part of this document.

Any feedback and questions on this document should be directed to the users' national committee. A complete listing of these bodies can be found on the CENELEC website.

[SIST EN IEC 61084-2-3:2024/A11:2024](https://standards.iteh.ai/catalog/standards/sist/9f93e36d-c0c3-42ef-8adf-c7d2a141595b/sist-en-iec-61084-2-3-2024-a11-2024)

<https://standards.iteh.ai/catalog/standards/sist/9f93e36d-c0c3-42ef-8adf-c7d2a141595b/sist-en-iec-61084-2-3-2024-a11-2024>

EN IEC 61084-2-3:2024/A11:2024 (E)

1 Modification to Clause 2, “Normative references”***Replace***

“IEC 60695-11-5:2004, *Fire hazard testing - Part 11-5: Test flames - Needle-flame test method - Apparatus, confirmatory test arrangement and guidance*”

with

“IEC 60695-11-5:2016, *Fire hazard testing - Part 11-5: Test flames - Needle-flame test method - Apparatus, confirmatory test arrangement and guidance*”

2 Modification to Clause 10, “Mechanical properties”

In 10.2.101 replace the fourth paragraph with

“Within the width of the sample:

- for trunking with a width less than 62,5 mm, one fixing is used as shown in Figure 103 a)
- for trunking with a width equal or greater than 62,5 mm, two fixings are used as shown in Figure 103 b).”

and replace in the sixth paragraph “class 5, Table 3” with “Table 3 - class 5”.

3 Modification to Clause 13, “Fire hazard”

In 13.1.3, last paragraph, replace “IEC 60695-11-5:2004” with “IEC 60695-11-5:2016”.

4 Modification to Figure 103, “Fixing distances for cable support test”

In “Figure 103 – Fixing distances for cable support test”

replace the title of Figure 103 a) with

“**a) Fixing distances for cable support test for trunking with a width less than 62,5 mm**”

replace the title of Figure 103 b) with

“**b) Fixing distances for cable support test for trunking with a width equal or greater than 62,5 mm**”

5 Modification to Annex B, “CTS/CDS IK code”

Annex B of EN IEC 61084-1:2024¹ is not applicable.

¹ As amended by EN IEC 61084-1:2024/A11:2024.