



SLOVENSKI STANDARD

SIST EN 13215:2017+A1:2020

01-oktober-2020

Nadomešča:
SIST EN 13215:2017

Kondenzacijske enote za hladilne naprave - Ocenjevalni pogoji za razvrščanje, odstopanja in predstavitev podatkov o lastnostih, ki jih navede proizvajalec (vključuje dopolnilo A1)

Condensing units for refrigeration - Rating conditions, tolerances and presentation of manufacturer's performance data

Verflüssigungssätze für die Kälteanwendung - Nennbedingungen, Toleranzen und Darstellung von Leistungsdaten (des Herstellers)

Unités de condensation pour la réfrigération - Détermination des caractéristiques, tolérances et présentation des performances du fabricant

Ta slovenski standard je istoveten z: EN 13215:2016+A1:2020

ICS:

27.200 Hladilna tehnologija Refrigerating technology

SIST EN 13215:2017+A1:2020 en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 13215:2017+A1:2020

<https://standards.iteh.ai/catalog/standards/sist/abcadcb0-2582-44a1-b28f-3a9f80ebb761/sist-en-13215-2017a1-2020>

EUROPEAN STANDARD

EN 13215:2016+A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

August 2020

ICS 27.200

Supersedes EN 13215:2016

English Version

Condensing units for refrigeration - Rating conditions, tolerances and presentation of manufacturer's performance data

Unités de condensation pour la réfrigération -
Détermination des caractéristiques, tolérances et
présentation des performances du fabricant

Verflüssigungssätze für die Kälteanwendung -
Nennbedingungen, Toleranzen und Darstellung von
Leistungsdaten des Herstellers

This European Standard was approved by CEN on 24 September 2016 and includes Amendment 1 approved by CEN on 5 July 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Symbols and abbreviations	6
5 Parameters for the presentation of performance data	7
6 General requirements	7
7 Performance data	8
7.1 General	8
7.2 Part load performance data	8
7.3 Tabular or graphical form	8
7.4 Determination of the power absorbed by the condensing unit	8
7.4.1 Condensing units including the compressor motor	8
7.4.2 Motors with a specific factory assembled or factory specified means for variable speed	9
7.4.3 Externally driven compressors without motor	9
8 Rating conditions	9
8.1 General	9
8.2 Standard reference points	9
8.3 Air cooled condensing units	10
8.3.1 General	10
8.3.2 Data for SEPR calculation	10
8.4 Water cooled condensing units	11
9 Tolerances	11
10 Correction factors	11
10.1 Superheat	11
10.2 Compressors speed	12
Annex A (normative) Calculation of SEPR	13
A.1 General	13
A.2 Condensing unit without capacity control	13
A.3 Condensing unit with stepwise capacity control	13
A.4 Calculation of SEPR	14
Annex B (normative) Determination of evaporating temperature with refrigerant mixtures	18
Annex ZA (informative) Relationship between this European Standard and the eco-design requirements of Commission Regulation (EU) No 2015/1095	20
Bibliography	21

Tables

Table 1 — Symbols and abbreviations.....	6
Table 2 — Indices	7
Table 3 — Parameters for the presentation of performance data	7
Table 4 — Standard reference points.....	9
Table 5 — Actual performance in relation to published data	11
Table A.1 — Required input for <i>SEPR</i> calculation.....	14
Table A.2 — Ambient temperatures and duration for <i>SEPR</i> determination	15
Table ZA.1 — Correspondence between this European Standard and Commission Regulation (EU) No 2015/1095 of 5 May 2015 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for professional refrigerated storage cabinets, blast cabinets, condensing units and process chillers and Commission’s standardization request M/495 (Ecodesign).....	20

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 13215:2017+A1:2020](https://standards.iteh.ai/catalog/standards/sist/abcadcb0-2582-44a1-b28f-3a9f80ebb761/sist-en-13215-2017a1-2020)

<https://standards.iteh.ai/catalog/standards/sist/abcadcb0-2582-44a1-b28f-3a9f80ebb761/sist-en-13215-2017a1-2020>

EN 13215:2016+A1:2020 (E)**European foreword**

This document (EN 13215:2016+A1:2020) has been prepared by Technical Committee CEN/TC 113 “Heat pumps and air conditioning units”, the secretariat of which is held by AENOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2021, and conflicting national standards shall be withdrawn at the latest by February 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1 approved by CEN on 5 July 2020.

This document supersedes A1 EN 13215:2016 A1.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA which is an integral part of this document.

The main changes with respect to the previous edition are listed below:

- a) part load conditions according to M/495 “Standardisation mandate to CEN, CENELEC and ETSI under Directive 2009/125/EC relating to harmonised standards in the field of Ecodesign” are taken into account;
- b) inclusion of the calculation of seasonal energy performance ratio (*SEPR*).

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This European Standard specifies the rating conditions, tolerances and presentation of manufacturer's performance data for condensing units for refrigeration with compressors of the positive-displacement type. These include single stage compressors and single and two stage compressors having an integrated means of fluid sub cooling. This is required so that a comparison of different condensing units can be made. The data relate to the refrigerating capacity and power absorbed and include requirements for part-load performance where applicable.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

Ⓐ EN 378-1:2016, *Refrigerating systems and heat pumps - Safety and environmental requirements - Part 1: Basic requirements, definitions, classification and selection criteria*

EN 13771-2:2017, *Compressors and condensing units for refrigeration - Performance testing and test methods - Part 2: Condensing units* Ⓐ

ISO 817, *Refrigerants — Designation and safety classification*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in Ⓐ EN 378-1:2016 Ⓐ and the following apply.

3.1

condensing unit

combination of one or more compressors, condensers/gas coolers and, where applicable, liquid receivers and the regularly furnished accessories

Ⓐ 3.2

evaporating temperature

t_0

temperature between the evaporating dew point and the evaporator inlet temperature of the refrigerant at the pressure of the condensing unit inlet, as calculated according to Annex B

Note 1 to entry: For refrigerants without glide the evaporating temperature is equal to the dew point temperature at the condensing unit inlet pressure. Ⓐ

Ⓐ 3.3 Ⓐ

refrigerating capacity

Q

product of the mass flow of refrigerant through the condensing unit and the difference between the specific enthalpy of the refrigerant at the condensing unit inlet, the refrigerant being superheated above the suction dew point temperature to the appropriate value (see Table 3), and the specific enthalpy of the liquid refrigerant at the condensing unit outlet

Ⓐ 3.4 Ⓐ

subcooling Ⓐ

difference between the bubble point temperature of the refrigerant corresponding to the pressure at the condensing unit outlet and the temperature of the liquid refrigerant at the condensing unit outlet

EN 13215:2016+A1:2020 (E)

A1 3.5 A1

superheat

difference between the dew point temperature of the refrigerant corresponding to the pressure at the condensing unit inlet and the temperature of the refrigerant vapour at the condensing unit inlet

A1 3.6 A1

power absorbed***P***

power demand to drive the condensing unit

A1 3.7 A1

coefficient of performance***COP***

refrigerating capacity to the power absorbed

A1 3.8 A1

seasonal energy performance ratio***SEPR***

reference annual refrigeration demand divided by the annual electrical energy demand

A1 3.9

glide

difference between dew point temperature and bubble point temperature at a given pressure

[SOURCE: EN 14511-1:2018, 3.46]

3.10**condensing temperature**

arithmetic mean temperature between the condensing dew point and bubble point at the compressor discharge pressure A1

STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 13215:2017+A1:2020

https://standards.iteh.ai/en/standards/SIST-EN-13215-2017+A1-2020

3a9f80ebb761/sist-en-13215-2017a1-2020

4 Symbols and abbreviations**Table 1 — Symbols and abbreviations**

Symbol	Designation	Unit
LT	Low evaporating temperature	-
MT	Medium evaporating temperature	-
HT	High evaporating temperature	-
<i>COP</i>	Coefficient of performance	-
<i>CR</i>	Capacity ratio	-
<i>d</i>	Duration	h
<i>E</i>	Annual electrical energy demand	kWh
<i>P</i>	Power	W
<i>q</i>	Refrigeration demand ratio	-
<i>Q</i>	Refrigerating capacity	W
<i>SEPR</i>	Seasonal energy performance ratio	-
<i>t</i>	Temperature	°C

Table 2 — Indices

Index	Designation
LT	Low evaporating temperature
MT	Medium evaporating temperature
amb	ambient
cor	corrected
dm	demand
low	low
A, B, C and D	Rating conditions
j	bin-number
R	rated

5 Parameters for the presentation of performance data

The parameters as shown in Table 3 shall be used for the presentation of the performance data.

Table 3 — Parameters for the presentation of performance data

Parameters refrigerant	Suction temperature (°C) or superheat (K) at the condensing unit inlet	Condensing unit application
Halocarbons and hydrocarbons including refrigerant blends	32 °C	Household and similar refrigerators/freezers
	20 °C or 10 K	Other applications
R717	5 K	Any application using ammonia
R744	32 °C	Household and similar
	10 K	Other application using CO ₂

6 General requirements

The performance data of a condensing unit for refrigeration shall be presented in either tabular or graphical form as shown in 7.3. Data outside the allowable working range of the condensing unit shall not be included.

The performance of the condensing unit at the standard reference points in Table 4 shall also be reported.

To calculate the performance at other suction temperatures/superheat and at other compressor speeds, correction factors shall be given as shown in Clause 10.

Refrigerants shall be designated in accordance with ISO 817. The source from which the thermodynamic properties are taken shall be stated.

EN 13215:2016+A1:2020 (E)

It is recommended that an example illustrating the use of the performance data and the correction factors should be given.

Other data such as the swept volume, number of cylinders and speed range may also be shown.

7 Performance data**7.1 General**

Published performance shall be based on data obtained from tests performed in accordance with A1 EN 13771-2:2017 A1 .

A1 It shall be declared whether arithmetic mean temperature, thermodynamic mean temperature or dew point evaporating temperature is used, see also Annex B.

The manufacturer can choose to rate the condensing unit at dew point evaporating temperature even for refrigerant with a glide. A1

The performance data shall be presented as stated in Clause 8 and for:

- open compressors at the rated speed;
- motor compressors at the rated voltage and frequency.

7.2 Part load performance data

The performance data with capacity control shall be presented for:

- all capacity control steps for condensing units with 2 to 4 control steps, e.g. blocked suction, condensing units with more than one compressor or multi-speed compressor motors;
- condensing units with more than 4 steps or other variable capacity (e.g. variable speed or quasi stepless) at maximum, minimum and at least one additional control step inside the control range.

In the case of nonlinear performance behaviour between published values, the interpolation method, necessary to keep within the tolerances, is to be stated.

Part load data for *SEPR* calculation according to Annex A shall be declared in addition.

7.3 Tabular or graphical form

The performance data to be given, in either tabular or graphical form, shall comprise:

- a) the refrigerating capacity, in values able to be read to an accuracy of $\pm 2\%$;
- b) the power absorbed, in values able to be read to an accuracy of $\pm 2\%$;
- c) A1 the evaporating temperature, at intervals not greater than 5 K. A1

7.4 Determination of the power absorbed by the condensing unit**7.4.1 Condensing units including the compressor motor**

Power absorbed consists of the electrical power input to the compressor motor and the power of the fan(s) and other electrical auxiliaries.

7.4.2 Motors with a specific factory assembled or factory specified means for variable speed

The motor power is the electrical power input at the terminals of the frequency inverter or other means for variable speed.

7.4.3 Externally driven compressors without motor

Power absorbed consists of the power at the compressor shaft and the power of the fan(s) and other electrical auxiliaries.

8 Rating conditions

8.1 General

A rating condition consists of a reference point of Table 4 and an ambient temperature from 8.3 for air cooled condensing unit respectively a condensing temperature from 8.4 for water cooled condensing units.

The following data shall be given:

- refrigerating capacity;
- value of subcooling at the condensing unit outlet;
- power absorbed, including fan motors and factory supplied accessories;
- *COP*.

The following further information shall be available upon request:

- application limits related to air or water temperature (minimum-maximum);
- for air cooled condensing units: air flow;
- for water cooled condensing units: water flow and pressure drop.

8.2 Standard reference points

The standard reference points shall be in accordance with Table 4.

Table 4 — Standard reference points

Condensing unit applications Reference points	Low evaporating temperature (LT)	Medium evaporating temperature (MT)	High evaporating temperature (HT)	Household and similar
Evaporating temperature (°C) [A1] deleted text [A1]	-35	-10	+5	-25
Suction temperature (°C) or superheat (K)	+20 10 or 5 ^a	+20 10 or 5 ^a	+20 10 or 5 ^a	+32
Applicable for	≤ -20	-20 < t < -5	≥ -5	n.a.