



SLOVENSKI STANDARD
SIST EN 16750:2017+A1:2020

01-november-2020

Nadomešča:
SIST EN 16750:2017

Vgrajeni gasilni sistemi - Sistemi z zmanjšano koncentracijo kisika - Projektiranje, vgradnja, načrtovanje in vzdrževanje

Fixed firefighting systems - Oxygen reduction systems - Design, installation, planning and maintenance

Ortsfeste Löschanlagen - Sauerstoffreduktionsanlagen - Auslegung, Einbau, Planung und Instandhaltung

Installations fixes de lutte contre l'incendie - Systèmes d'appauvrissement en oxygène - Conception, installation, planification et maintenance

IFAI STANDARD PREVIEW
(standards.iteh.ai)
SIST EN 16750:2017+A1:2020
<https://standards.iteh.ai/catalog/standards/sist/072d8757-fb3e-4910-b2fa-813532810eaa/sist-en-16750-2017a1-2020>

Ta slovenski standard je istoveten z: EN 16750:2017+A1:2020

ICS:

13.220.10 Gašenje požara Fire-fighting

SIST EN 16750:2017+A1:2020 en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 16750:2017+A1:2020](#)

<https://standards.iteh.ai/catalog/standards/sist/b72d8757-fb3e-4910-b2fa-813532810eaa/sist-en-16750-2017a1-2020>

EUROPEAN STANDARD

EN 16750:2017+A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

August 2020

ICS 13.220.20

Supersedes EN 16750:2017

English Version

Fixed firefighting systems - Oxygen reduction systems - Design, installation, planning and maintenance

Installations fixes de lutte contre l'incendie - Systèmes
d'appauvrissement en oxygène - Conception,
installation, planification et maintenance

Ortsfeste Löschanlagen - Sauerstoffreduktionsanlagen -
Auslegung, Einbau, Planung und Instandhaltung

This European Standard was approved by CEN on 9 July 2017 and includes Amendment 1 approved by CEN on 12 July 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	4
Introduction	5
1 Scope.....	6
2 Normative references.....	7
3 Terms and definitions	7
4 System requirements.....	9
4.1 General.....	9
4.2 Personnel safety	9
4.3 Effectiveness and application	10
4.4 Alarm organization and emergency plan	10
5 Design.....	10
5.1 Qualification of the designer.....	10
5.2 Fire protection concept.....	10
5.3 Structural specifications for the protected area.....	11
5.4 Oxygen concentration.....	11
5.5 Oxygen reduction to prevent fire	12
5.6 Safety margins.....	12
5.7 Oxygen reduced air quantity.....	16
5.7.1 Continuous oxygen reduction.....	16
5.7.2 Emergency plan	16
5.7.3 Oxygen reduced air.....	16
5.7.4 Gaseous supply.....	17
5.7.5 Fault signals	17
5.8 Technical areas	18
5.8.1 Technical area for control panel	18
5.8.2 Technical area for reduced oxygen air generation.....	18
6 Distribution pipework	19
6.1 Pipework.....	19
6.2 Pipe supports.....	19
6.3 Components in the pipework.....	19
7 Monitoring the oxygen concentration	20
8 Alarms and notifications	21
9 Control equipment.....	22
9.1 Function.....	22
9.2 Requirements.....	22
9.3 Electrical power supply	22
9.4 Electrical installations.....	22
9.5 Data recording.....	22
10 System operation	23
10.1 Instruction and training of personnel	23
10.2 Inspections	23
10.3 Operations log	23
10.4 Further obligations.....	23

11	Maintenance	24
12	Documentation	24
13	Installation	25
13.1	Qualification of the installer	25
13.2	General specifications, installation	25
Annex A (normative) Ignition thresholds for oxygen reduction using nitrogen in fire prevention		
		26
A.1	Ignition thresholds	26
A.2	Tests to ascertain ignition thresholds of unfamiliar materials	27
A.2.1	Cup burner tests	27
A.2.2	Ignition threshold tests	28
A.2.2.1	General	28
A.2.2.2	Test criteria	29
A.2.2.3	Test documentation	29
Annex B (informative) Information for health and safety – Working in oxygen-reduction atmospheres for reasons of fire prevention		
		31
B.1	General	31
B.2	Principles of occupational health	31
B.3	Risk classes	31
B.4	Basic requirements, planning and installation	32
B.5	Protective measures for all areas with oxygen-reduced atmospheres	33
B.5.1	Structural and technical measures	33
B.5.2	Organizational measures	34
B.6	Risk classes and safety measures	35
Annex C (informative) Existing national regulations for access and working in areas with lower oxygen concentration		
		36
Bibliography		37

EN 16750:2017+A1:2020 (E)**European foreword**

This document (EN 16750:2017+A1:2020) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by February 2021, and conflicting national standards shall be withdrawn at the latest by February 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes A1 EN 16750:2017 A1.

This document includes Amendment 1 approved by CEN on 12 July 2020.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

(standards.iteh.ai)

[SIST EN 16750:2017+A1:2020](https://standards.iteh.ai/catalog/standards/sist/b72d8757-fb3e-4910-b2fa-813532810eaa/sist-en-16750-2017a1-2020)

<https://standards.iteh.ai/catalog/standards/sist/b72d8757-fb3e-4910-b2fa-813532810eaa/sist-en-16750-2017a1-2020>

Introduction

Oxygen reduction systems are designed to prevent fires from starting or spreading, by means of the introduction of oxygen reduced air. Oxygen reduction systems are not designed to extinguish fires. The design and installation shall be based on detailed knowledge of the protected area, its occupancy and the materials in question. It is important to suit the fire protection measures to the hazard as a whole.

It is important to emphasize that across the European Union there are several regulatory and legislative limitations for access and working in areas with lower oxygen concentration, so it is important to take these limitations into account. Use of this European Standard can vary based on the national legislation in each country of the European Union.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 16750:2017+A1:2020](https://standards.iteh.ai/catalog/standards/sist/b72d8757-fb3e-4910-b2fa-813532810eaa/sist-en-16750-2017a1-2020)

<https://standards.iteh.ai/catalog/standards/sist/b72d8757-fb3e-4910-b2fa-813532810eaa/sist-en-16750-2017a1-2020>

EN 16750:2017+A1:2020 (E)**1 Scope**

This European standard specifies oxygen reduction systems that are used as fire prevention systems by creating an atmosphere in an area which is having a lower permanent oxygen concentration as in ambient conditions. The level of oxygen reduction is defined by the individual risks of these areas (see Annex A). Oxygen reduction is achieved by technical systems which are providing a flux of air containing a reduced concentration of oxygen.

This European standard specifies minimum requirements and defines the specifications governing the design, installation and maintenance of fixed oxygen reduction systems with oxygen reduced air in buildings and industrial production plants. The standard also applies to the extension and modification of existing systems.

This European standard applies to oxygen reduction systems using nitrogen which are designed for continual oxygen reduction in enclosed spaces.

NOTE Nitrogen is today the most suitable gas to be used for oxygen reduction. For other gases this European standard can be used as basis.

This European standard does not apply to oxygen reduction systems that use water mist or combustion gases.

The European standard does not apply to:

- explosion suppression systems;
- explosion prevention systems;
- fire extinguishing systems using gaseous extinguishing agents;
- inertization of portable containers;
- systems in which oxygen levels are reduced for reasons other than fire prevention (e.g. steel processing in the presence of inert gas to avoid the formation of oxide film);
- inerting required during repair work on systems or equipment (e.g. welding) in order to eliminate the risk of fire or explosion.

In addition to the conditions for the actual oxygen reduction system and its individual components this European standard also covers certain structural specifications for the protected area.

The space protected by an oxygen reduction system is a controlled and continuously monitored indoor climate for extended occupation. This standard does not cover unventilated confined spaces that may contain hazardous gases.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 16750:2017+A1:2020](#)

[iteh.ai/catalog/standards/sist/b72d8757-fb3e-4910-b2fa-813532810eaa/sist-en-16750-2017a1-2020](#)

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54 (all parts), *Fire detection and fire alarm systems*

EN 12094-1, *Fixed firefighting systems — Components for gas extinguishing systems — Part 1: Requirements and test methods for electrical automatic control and delay devices*

EN 50104, *Electrical apparatus for the detection and measurement of oxygen — Performance requirements and test methods*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1 Alarms

3.1.1

external alarm

alarm to emergency services such as fire brigade or permanently attended location

3.1.2

local alarm

acoustic and possibly additional visual alarm in protected areas or their immediate surroundings

3.1.3

internal alarm

acoustic and visual displays at the detection panel, possibly with additional displays at other signalling equipment

3.1.4

alarm threshold

value of a process parameter which, when reached, triggers an alarm and, where necessary, initiates automatic protection measures

3.1.5

alarm signal

signal to warn people at risk and/or to summon help from the emergency services and/or to provide information about automatic response measures

3.2

design concentration

ignition threshold including a safety margin

Note 1 to entry: See also Figure 1.

Note 2 to entry: The design concentration represents the maximum oxygen concentration which cannot be exceeded in any time.

3.3

emergency situation

deviation from normal operation

EXAMPLE For example a significant deviation from the threshold value (scale of risk).

EN 16750:2017+A1:2020 (E)**3.4
operating pressure**

pressure of a system under normal operating conditions

**3.5
combustible material**

A material capable of combustion or being ignited

Note 1 to entry: For the purposes of this standard, whether the quantity of a combustible material is to be regarded as significant or not can be determined by means of a risk analysis as part of the fire protection design.

**3.6
ignition threshold**

maximum oxygen concentration in a mixture of a combustible material with air and inert gas, in which there can be no ignition, determined under established test conditions

Note 1 to entry: This is a specific characteristic of combustible material and inert gas (see A.1).

**3.7
detection and alarm installation**

remote detection system for the reliable detection of risk to people and property

Note 1 to entry: It creates alarm reports from automatic or manually input information, issues these and detects any faults. The transmission channels for information and alarms are monitored. Special measures are in place to prevent any malfunction as far as possible, which may be powered electrically or otherwise. Detection and alarm systems cover facilities for the input, transmission (through wires or wirelessly), processing and issuing of alarms, including the necessary power supply. This standard applies to detection and alarm systems which detect and report the scale of the risk at an early stage. (standards.iteh.ai)

**3.8
measuring zones**

<oxygen reduction system> virtual separation of the protected volume for oxygen measuring

SIST EN 16750:2017+A1:2020

<https://standards.iteh.ai/catalog/standards/sist/b72d8757-fb3e-4910-b2fa->

**3.9
normal operation**

situation in which the equipment, protection systems and components are able to carry out their designated functions within their design parameters

**3.10
oxygen reduced air**

ambient air with an oxygen concentration lower than natural air

**3.11
oxygen reduced air supply**

nitrogen enriched air stream with an oxygen concentration of less than natural air ready to be introduced into a protected volume

**3.12
oxygen reduction**

reduction of oxygen which increases the nitrogen concentration to prevent the ignition or spread of fire

**3.13
protected volume**

effective volume of the space to be protected

3.14 system

combination of components whose function and compatibility guarantees the safety of the installation

3.15 technical areas

areas where either or the control panel, nitrogen production unit and other relevant system components are placed

3.16 control panel

electrical device for monitoring, controlling and alarm of the oxygen reduction system

4 System requirements

4.1 General

An oxygen reduction system shall consist basically of:

- a) a supply of oxygen reduced air;
- b) a fixed pipework system with fittings, valves, nozzles, outlets;
- c) oxygen sensors and control panel;
- d) alarms.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Oxygen reduced air is produced by air separation or by injecting inert gas or gas mixture into the protected area.

The oxygen concentration in the protected area shall be monitored by means of measuring equipment. During operation, the supply of nitrogen shall be controlled automatically according to demand. Where necessary as a result of a risk analysis additional means shall be provided to operate the supply manually or an additional supply operated manually or automatically.

The oxygen reduction system can be equipped with automatic equipment designed to shut down machinery and to close fire doors and other equipment, with the aim of creating and maintaining the required oxygen concentration.

4.2 Personnel safety

Oxygen reduced air can be dangerous for personnel.

Adherence to this European Standard does not remove the user's statutory responsibility to comply with the relevant national bodies and laws. In case no national laws exist, further information can be found in Annex B.

Code requirements for unventilated confined spaces do not apply to space protected by oxygen reduction system that control and continuously monitor indoor climate for extended occupation.

Personnel safety measures shall be made for the fact that neighbouring volumes can have a reduced oxygen concentration. These areas may also need to be monitored and/or personnel safety measures may need to be taken.

Technical or organizational measures shall be taken to prevent unauthorized people from entering protected areas with permanently reduced oxygen levels.

The measurement system shall be designed in such a way that a loss of function or a measurement error can in no event lead to the minimum oxygen threshold not being detected.

The spreading of the oxygen-reduced atmosphere to other areas not intended for this (e.g. through wall openings, cable ducts, floor drainages, leaking doors, conveyor belts, etc.) shall be prevented.

EN 16750:2017+A1:2020 (E)**4.3 Effectiveness and application**

A fire risk assessment detailing the key fire protection factors shall be done. The important aspects are:

- the type and quantity of material/materials requiring protection;
- the area(s) requiring protection;
- the right dimension of the oxygen reduced air supply to maintain the reduced oxygen concentration on its design value;
- a back-up oxygen reduced air supply, if provided;
- alarm equipment.

Oxygen reduction systems provide preventive fire protection. The introduction of nitrogen reduces the oxygen concentration of the air, thereby preventing the ignition or spread of fire except for the following:

- chemicals containing their own supply of oxygen, such as cellulose nitrate;
- mixtures containing oxidizing materials, such as sodium chlorate or sodium nitrate;
- chemicals capable of undergoing auto-thermal decomposition, such as some organic peroxides;
- reactive metals (such as sodium, potassium, magnesium, titanium and zirconium), reactive hydrides or metal amides, some of which may react violently.

4.4 Alarm organization and emergency plan

An alarm organization is required for the following purposes:

- to alert affected and responsible persons;
- to alert the permanently attended location;
- to initiate other necessary protective measures.

The responsibilities for the alarm organization shall be defined.

The emergency plan should cover keywords to designate the basic measures that need to be taken in case of emergency, too low oxygen level or fire signal.

5 Design**5.1 Qualification of the designer**

The designer shall be sufficiently technically qualified to ensure effective protection.

5.2 Fire protection concept

The system design shall be part of the fire safety concept of the building.

As part of the system design a fire risk assessment might lead to further fire protection measures.

EXAMPLE Since the oxygen reduction system cannot prevent or detect smouldering or pyrolyzing processes (e.g. overheated cables) suitable smoke detection systems for the protected volume e.g. high sensitive smoke detection systems according to EN 54-20 class A, are recommended and should be part of the main fire alarm system of the facility.