



Designation: ~~C56-05~~ Designation: C56 – 09

Standard Specification for Structural Clay Nonloadbearing Tile¹

This standard is issued under the fixed designation C56; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

~~Note—Changes were made throughout and the year date changed on April 14, 2005.~~

This standard has been approved for use by agencies of the Department of Defense.

1. Scope*

1.1 This specification covers structural clay nonloadbearing tile (partition, fireproofing, and furring). One grade of tile is covered, designated Grade NB.

1.2 The property requirements of this standard apply at the time of purchase. The use of results from testing of tile extracted from masonry structures for determining conformance or non-conformance to the property requirements (Section 3) of this standard is beyond the scope of this standard.

1.3 Tile covered by this standard are manufactured from clay, shale, or similar naturally occurring substances and subjected to a heat treatment at elevated temperatures (firing). The heat treatment must develop sufficient fired bond between the particulate constituents to provide the strength and durability requirements of this specification. (See *firing* and *fired bond* in Terminology C43 in Terminology C1232.)

1.4 Fireproofing tile intended for use in load-bearing masonry shall conform to Specification C34.

1.5 If tile having a particular color (Note 1), texture, or finish are desired, these features shall be specified separately by the purchaser.

NOTE 1—Color of tile varies with the type of clay used and degree of burning; hence, it cannot be taken as indicative of classification until after it has been related to absorption by actual tests.

1.6 The text of this specification references notes and footnotes that provide explanatory material. These notes and footnotes (excluding those in tables and figures) shall not be considered as requirements of this specification.

1.7 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

2. Referenced Documents

2.1 *ASTM Standards:*²

C34 [Specification for Structural Clay Load-Bearing Wall Tile](#) ~~C43 Terminology of Structural Clay Products~~

C67 ~~Test Methods for Sampling and Testing Brick and Structural Clay Tile~~ [Test Methods for Sampling and Testing Brick and Structural Clay Tile](#)

C1232 [Terminology of Masonry](#)

3. Absorption

3.1 Structural clay non-load-bearing tile shall conform to the following requirements for absorption:

Absorption by 1-h Boiling,^A %

Grade	Individual Maximum
NB	28

¹ This specification is under the jurisdiction of ASTM Committee C15 on Manufactured Masonry Units and is the direct responsibility of Subcommittee C15.02 on Brick and Structural Clay Tile.

Current edition approved April 14, 2005. Published April 2005. Originally approved in 1924. Last previous edition approved in 2004 as C56-04. DOI: 10.1520/C0056-05.

Current edition approved Dec. 1, 2009. Published December 2009. Originally approved in 1924. Last previous edition approved in 2005 as C56-05. DOI: 10.1520/C0056-09.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

*A Summary of Changes section appears at the end of this standard.