
**Information technology — Data
centres — Key performance
indicators —**

**Part 3:
Renewable energy factor (REF)**

AMENDMENT 1

(standards.iteh.ai)

*Technologies de l'information — Centres de données — Indicateurs de
performance clés —*

ISO/IEC 30134-3:2016/Amd 1:2018

Partie 3: Facteur d'énergie renouvelable (REF)

<https://standards.iteh.ai/catalog/standards/sist/1213170c-4311-45cc-a23e-512e3ac6a1e1/iso-30134-3-2016-amd-1-2018>

AMENDEMENT 1



iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO/IEC 30134-3:2016/Amd 1:2018
<https://standards.iteh.ai/catalog/standards/sist/f23f70c-43f1-45cc-a23e-512e3ac66e87/iso-iec-30134-3-2016-amd-1-2018>



COPYRIGHT PROTECTED DOCUMENT

© ISO/IEC 2018

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) and IEC (the International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards through technical committees established by the respective organization to deal with particular fields of technical activity. ISO and IEC technical committees collaborate in fields of mutual interest. Other international organizations, governmental and non-governmental, in liaison with ISO and IEC, also take part in the work. In the field of information technology, ISO and IEC have established a joint technical committee, ISO/IEC JTC 1.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO and IEC shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by ISO/IEC JTC 1, *Information technology*, SC 39, *Sustainability for and by Information Technology*.

A list of all the parts in the ISO 30134 series can be found on the ISO website.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO/IEC 30134-3:2016/Amd 1:2018](https://standards.iteh.ai/catalog/standards/sist/23f70c-43f1-45cc-a23e-512e3ac66e87/iso-iec-30134-3-2016-amd-1-2018)

<https://standards.iteh.ai/catalog/standards/sist/23f70c-43f1-45cc-a23e-512e3ac66e87/iso-iec-30134-3-2016-amd-1-2018>

Information technology — Data centres — Key performance indicators —

Part 3: Renewable energy factor (REF)

AMENDMENT 1

Page 1, Clause 2 Normative references

Add to Clause 2:

ISO 8601, *Data elements and interchange formats — Information interchange — Representation of dates and times*

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Page 3, Clause 5

In Clause 5, insert a new subclause **5.1 General** which contains the whole of existing Clause 5.
ISO/IEC 30134-3:2016/Amd.1:2018
<https://standards.iteh.ai/catalog/standards/sis/251700-4511-45cc-a25c-512e3ac66e87/iso-iec-30134-3-2016-amd-1-2018>

Insert two new subclauses 5.2 and 5.3 as follows:

5.2 Total data centre energy consumption

The data centre under consideration shall be viewed at as a system defined by interfaces through which energy flows.

The following forms of energy shall be metered at the interfaces:

- a) electricity;
- b) gaseous fuel;
- c) fluid fuel;
- d) fluids for cooling (comprising water usage when returned fluid and not evaporated).

The following forms of energy are not required be metered at these interfaces:

- 1) air for cooling;
- 2) water from natural sources (i.e. requiring no energy consumption in its provision).

All forms of electrical energy at interfaces shall be metered to kWh. If any of the required forms of energy are not accounted for at the interfaces then E_{DC} is not determined and REF cannot be calculated.

Gaseous or liquid fuels shall be metered in kWh or converted into kWh using the heat of combustion values for the fuel used. Where information on combustion values is not available and no local regulation applies, the following values shall be applied:

- diesel: 9,9 kWh/l;
- gas: 10,5 kWh/m³;
- hydrogen: 38,9 kWh/kg;
- bioethanol: 6 kWh/l.

The energy contribution of fluids for cooling shall be measured using heat meters (providing information on flow rate and differential temperature) and multiplied by the relevant conversion factor of the system used to provide the fluid used.

For the conversion of thermal energy to its electrical equivalent, the conversion factor X shall be obtained from the supplier; in case there is no equivalent available, a conversion factor $X = 0,4$ shall be used.

Technical subsystems, e.g. on-site co-generation of heat and electricity, shall have meters at their output and are considered external to the system.

5.3 Total data centre energy consumption in mixed-use buildings

The total data centre energy consumption for data centres in mixed-used buildings shall be calculated on the energy use of the data centre as system only if metering of all shared technical subsystems allows separation of energy usage.

If energy use of shared technical subsystems cannot be separated, total data centre energy usage shall comprise the building in total. The impact on REF should be counteracted by implementing the necessary meters for separation.

<https://standards.iteh.ai/catalog/standards/sist/f23f70c-43f1-45cc-a23e-512e3ac66e87/iso-iec-30134-3-2016-amd-1-2018>


Page 4, Clause 6

Replace the last paragraph of Clause 6 as follows:

REF shall be determined as an annualized value. The calculation of REF requires the recording and documenting of E_{DC} and E_{ren} over a coincident period of twelve months. This standard does not specify the frequency of measurements of E_{DC} and E_{ren} , since REF is calculated on an annual timeframe. However, the frequency of measurement employed will define the timing of subsequent REF calculations on a rolling annual basis.

Page 8

Replace Figures B.3 and B.4 with the following ones:



iTeh STANDARD PREVIEW

Figure B.3 — RE certificates for locally generated RE are retired by the data centre
(standards.itih.ai)




Figure B.4 — Locally generated energy sold to the utility with RE certificates retired by the data centre

Page 11, Bibliography

Delete Bibliography reference [1] ISO 8601.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO/IEC 30134-3:2016/Amd 1:2018](https://standards.iteh.ai/catalog/standards/sist/123170c-43f1-45cc-a23e-512e3ac66e87/iso-iec-30134-3-2016-amd-1-2018)
<https://standards.iteh.ai/catalog/standards/sist/123170c-43f1-45cc-a23e-512e3ac66e87/iso-iec-30134-3-2016-amd-1-2018>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO/IEC 30134-3:2016/Amd 1:2018](https://standards.iteh.ai/catalog/standards/sist/23f70c-43f1-45cc-a23e-512e3ac66e87/iso-iec-30134-3-2016-amd-1-2018)

<https://standards.iteh.ai/catalog/standards/sist/23f70c-43f1-45cc-a23e-512e3ac66e87/iso-iec-30134-3-2016-amd-1-2018>