
**Guidelines for treated wastewater use
for irrigation projects —**

**Part 5:
Treated wastewater disinfection and
equivalent treatments**

*Lignes directrices pour l'utilisation des eaux usées traitées dans les
projets d'irrigation —*

*Partie 5: Désinfection des eaux usées traitées et traitements
équivalents*

Document Preview

ISO 16075-5:2021

<https://standards.iteh.ai/catalog/standards/iso/5460c1dd-4219-4800-9285-8cc28dc19f93/iso-16075-5-2021>



iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

ISO 16075-5:2021

<https://standards.iteh.ai/catalog/standards/iso/5460c1dd-4219-4800-9285-8cc28dc19f93/iso-16075-5-2021>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	v
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms, definitions, and abbreviated terms	1
3.1 Terms and definitions	1
3.2 Abbreviated terms	3
4 Wastewater pathogenic contaminants and their inactivation or removal	4
4.1 General	4
4.2 Type and occurrence of pathogens in wastewater	4
4.3 Reduction of pathogenic microorganisms in various stages of wastewater treatment	5
4.4 Reduction of pathogenic microorganisms by different disinfection methods	6
5 Disinfection	7
6 Chemical disinfection	8
6.1 General	8
6.2 Disinfection by chlorine/bromine compounds	8
6.2.1 General	8
6.2.2 Reactions of chlorine/bromine with ammonia	9
6.2.3 Definition of the halogenated disinfection residuals	10
6.2.4 Breakpoint reaction	10
6.2.5 CT values of chlorine/bromide and their compounds	12
6.2.6 Chlorinated compounds for TWW disinfection	12
6.2.7 Advantages, disadvantages and technical considerations of chlorine biocides-based disinfection method	13
6.2.8 Chlorination process	15
6.2.9 Brominated compounds for TWW disinfection	15
6.2.10 Advantages, disadvantages and technical considerations of brominated biocides-based disinfection method	17
6.3 Ozone	18
6.3.1 Chemistry of ozone disinfection	18
6.3.2 Direct ozone reaction	18
6.3.3 Indirect ozone reaction	19
6.3.4 Advantages, disadvantages and technical considerations of Ozone disinfection method	20
6.3.5 System configuration	20
6.3.6 Monitoring of ozonation	21
6.4 Environmental impacts of chemical disinfection	21
6.4.1 Environmental impacts of chlorination/bromination disinfection	21
6.4.2 Environmental impacts of ozonation disinfection	22
7 UV disinfection	22
7.1 General	22
7.2 UV light technologies and how they work	23
7.2.1 General	23
7.2.2 UV disinfection system components	23
7.3 UV source	24
7.3.1 General	24
7.3.2 UV source protector	25
7.4 Disinfection chamber	25
7.5 Sensors	25
7.5.1 UV intensity sensors	25
7.5.2 UV transmittance sensors	26
7.6 Ballasts	27

7.7	UV validation	27
7.8	The effectiveness of a UV disinfection system	29
7.9	Cleaning.....	29
7.10	Environmental impacts of UV disinfection.....	29
7.11	Advantages, disadvantages and technical considerations of UV disinfection method.....	30
8	Removal of pathogens by membrane methods.....	30
8.1	General.....	30
8.2	Membrane system.....	30
8.3	Pathogen removal by membrane filtration.....	31
8.4	Considerations for operation and maintenance.....	31
8.5	Monitoring.....	31
8.6	Environmental impacts of membrane systems.....	32
8.7	Advantages, disadvantages and technical considerations of pathogens removal by membrane systems disinfection method	32
Annex A (informative) Infection agents potentially present in untreated (raw) wastewater		33
Annex B (Informative) Microbial removal performance by various membrane filtration		35
Annex C (Informative) Bromine further compounds		36
Annex D (informative) Factors in operation, maintenance and monitoring of membrane system.....		37
Bibliography		40

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

ISO 16075-5:2021

<https://standards.itih.ai/catalog/standards/iso/5460c1dd-4219-4800-9285-8cc28dc19f93/iso-16075-5-2021>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 282, *Water reuse*, Subcommittee SC 1, *Treated wastewater reuse for irrigation*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

<https://standards.iteh.ai/catalog/standards/iso/5460c1dd-4219-4800-9285-8cc28dc19f93/iso-16075-5-2021>

Introduction

Disinfection of treated wastewater (TWW) is a critical phase in the process of TWW use. Its purpose is to reduce or eliminate major health risks to the wastewater treatment plant's operators and to anybody who may come in contact with TWW or with crops that were irrigated with TWW.

This document provides a guideline for the available methods of disinfection, their effectiveness and the factors impacting those methods, along with their advantages and disadvantages, regarding technical and environmental aspects and effective inactivation or removal of various pathogens in wastewater and TWW for use in irrigation.

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

[ISO 16075-5:2021](https://standards.itih.ai/catalog/standards/iso/5460c1dd-4219-4800-9285-8cc28dc19f93/iso-16075-5-2021)

<https://standards.itih.ai/catalog/standards/iso/5460c1dd-4219-4800-9285-8cc28dc19f93/iso-16075-5-2021>

Guidelines for treated wastewater use for irrigation projects —

Part 5: Treated wastewater disinfection and equivalent treatments

1 Scope

This document provides a guideline for the application of various available methods of treated wastewater (TWW) disinfection for an effective inactivation or removal of pathogens from TWW, which is intended for irrigation purposes.

This document deals with:

- chemical and physical technologies, principles of operation, and establishment of effective doses to be applied, possible interferences, and technical guidance for design and monitoring;
- comparison of the advantages and disadvantages of various disinfection methods suitable for TWW;
- potential environmental effects of the disinfection methodologies and ways to minimize those impacts;
- disinfection at different locations in the TWW use system, including in the wastewater treatment plant, within the distribution system and at the point of use.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 20670, *Water reuse — Vocabulary*

3 Terms, definitions, and abbreviated terms

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 20670 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1.1

advanced oxidation process

AOP

process that generates hydroxyl radicals in sufficient quantity to remove organics by oxidation

3.1.2

ballast

unit inserted between the supply and one or more discharge lamps, which by means of inductance, capacitance, or a combination of inductance and capacitance, serves mainly to limit the current of the lamp(s) to the required value so as to convert and regulate incoming power to UV lamps to produce UV light

Note 1 to entry: The ballast provides the proper voltage and current required to initiate and generate UV photons.

3.1.3

fouling

process leading to deterioration of membrane flux due to surface or internal blockage of the membrane

Note 1 to entry: See AWWA B130-13^[1].

3.1.4

pore size

size of the opening in a porous membrane

Note 1 to entry: Pore sizes are expressed either as nominal (average) or absolute (maximum), typically in terms of μm .

Note 2 to entry: See in AWWA B130-13^[1].

3.1.5

reduction equivalent dose

RED

dose of UV in a given device which is determined by biodosimetry

Note 1 to entry: See *UV dose* (3.1.9) and “biodosimetry”

Note 2 to entry: This *UV dose* (3.1.9) is determined by measuring the inactivation of a challenge microorganism after exposure to UV light in a UV unit and comparing the results to the known UV dose response curve of the same challenge organism determined via Bench scale collimated beam testing.

3.1.6

ultrafiltration

UF

Note 1 to entry: pressure driven process employing semipermeable membrane under hydraulic pressure gradient for the separation components in a solution

Note 2 to entry: The pores of the membrane are of a size smaller than $0.1\mu\text{m}$, which allows passage of the solvent(s) but will retain non-ionic solutes based primarily on physical size, not chemical potential.

Note 3 to entry: See in ASTM D6161-10.

3.1.7

UV disinfection system

combination of *UV disinfection units* (3.1.8) with associated controls and instrumentation

3.1.8

UV disinfection unit

independent combination of single or multiple bank(s) in series with a common mode of failure (e.g., electrical, cooling, cleaning system, etc.)

3.1.9

UV dose

UV fluence

amount of UV energy given as the time integral of the fluence rate or irradiance (W/m^2)

Note 1 to entry: This is given in units of mJ/cm^2 or J/m^2

3.1.10**UV intensity sensor**

UV irradiance meter or radiometer instrument to measure UV irradiance

3.1.11**UV transmittance**

fraction of photons in the UV spectrum transmitted through a material such as water or quartz

Note 1 to entry: It is preferable that an online UVT sensor be installed and used to verify UVT.

Note 2 to entry: The wavelength of the UVT (%) should be specified, often using a path length of 1 cm. The measurement is calibrated compared to ultra pure water (ISO 3696 grade 1 or equivalent).

Note 3 to entry: UVT is related to the UV absorbance (A) by the following formula (for a 1 cm path length): % UVT = 100×10^{-A} .

3.2 Abbreviated terms

A254	absorbance at 254
CT	product of the total residual chlorine and contact time
DBP	disinfection by-products
EPA	Environmental protection agency
DOC	dissolved organic carbon
DVGM	German Technical and Scientific Association for Gas and Water (deutscher verein des gas- und wasserfaches e.v.)
LP	low pressure
LPHO	low pressure high output
LRV	log removal value
MF	microfiltration
MP	medium pressure
MWCO	molecular weight cut off
NOM	natural organic matter
ONORM	Austrian Standard (<i>Österreichisches Normungsinstitut</i>)
QA/QC	quality assurance/quality control
RED	reduction equivalent dose
RO	reverse osmosis
TDS	total dissolved solids
THM	trihalomethanes
TMP	trans membrane pressure
TOC	total organic carbon

TWW	treated wastewater
UF	ultra-filtration
UV	ultraviolet
UVT	ultraviolet transmittance
WW	wastewater

4 Wastewater pathogenic contaminants and their inactivation or removal

4.1 General

The most critical objective in a TWW reuse programme should be public health.

To achieve the main objective, other equally important objectives should be considered, including:

- environmental protection,
- aesthetics (odour and colour); and
- ability to meet irrigation requirements.

To protect public health and prevent environmental degradation, the TWW quality characteristics and pathogenic microorganisms contained in the wastewater should be assessed and consideration given to appropriate treatment to reduce the risk of negative impacts.

There are a wide range of technology options available to meet the water quality goals and to reduce the risk of disease transmission from pathogenic microorganisms that can be present in TWW and to meet the water quality goals.

In regular wastewater treatment plants, the two main processes that reduce the concentrations of pathogenic microorganisms in the water should be:

- the wastewater treatment process itself, which is intended mainly to reduce concentrations of suspended and dissolved organic matter;
- the process of disinfection of the TWW.

4.2 Type and occurrence of pathogens in wastewater

Urban wastewater intended for agricultural irrigation or for other purposes contains a variety of pathogenic microbial contaminants that can pose a risk to public health.

The type and number of pathogenic microorganisms in urban wastewater varies between countries and cities and with time/season (wet and dry), epidemics etc. When selecting disinfection method(s) the range of microorganisms that can be present should be considered, including parasites eggs, bacteria, amoebas and other protozoa, *Giardia* and viruses. Common infectious agents, associated diseases, and potential numbers of microorganisms found in domestic wastewater are shown in [Table 1](#)^[2] (for the complete table see [Table A.1](#)).

Table 1 — Infectious agents potentially present in untreated (raw) wastewater^[2]

Pathogen	Disease	Numbers in raw wastewater (per litre)
<i>Shigella</i>	Shigellosis (bacillary dysentery)	Up to 10 ⁴

Table 1 (continued)

Pathogen	Disease	Numbers in raw wastewater (per litre)
<i>Salmonella</i>	Salmonellosis, gastroenteritis (diarrhoea, vomiting, fever), reactive arthritis, typhoid fever	Up to 10^5
<i>Vibrio cholera</i>	Cholera	Up to 10^5
<i>Campylobacter</i>	Gastroenteritis, reactive arthritis, Guillain-Barré syndrome	Up to 10^4
<i>Enteroviruses</i> (polio, echo, coxsackie, new enteroviruses, sero-type 68 to 71)	Gastroenteritis, heart anomalies, meningitis, respiratory illness, nervous disorders, others	Up to 10^6
<i>Adenovirus</i>	Respiratory disease, eye infections, gastroenteritis (serotype 40 and 41)	Up to 10^6
<i>Rotavirus</i>	Gastroenteritis	Up to 10^5
<i>Entamoeba</i>	Amebiasis (amebic dysentery)	Up to 10^2
<i>Giardia</i>	Giardiasis (gastroenteritis)	Up to 10^5
<i>Cryptosporidium</i>	Cryptosporidiosis, diarrhoea, fever	Up to 10^4
<i>Ascaris</i>	Ascariasis (roundworm infection)	Up to 10^3
<i>Ancylostoma</i>	Ancylostomiasis (hookworm infection)	Up to 10^3
<i>Trichuris</i>	Trichuriasis (whipworm infection)	Up to 10^2

The practical measurement of all pathogenic pollutants in TWW is almost impossible.

The main reasons are:

- low concentrations of the pathogenic contaminants in the TWW;
- limitation of present technology, to detect pathogens when they are present in low numbers;
- testing for pathogenic contaminants in the laboratory is lengthy and expensive.

Consequently, the control and monitoring of pathogenic microorganisms should be done by testing for indicator microorganisms, which are feasible and simple to measure as a result of their much larger numbers, and based on the premise that factors and treatment affecting their removal similarly affect the pathogens of interest.

[4.3](#) covers the effect of the first process (WW treatment and the reduction of the concentration of contaminants). [4.4](#) covers the effects of the disinfection of the TWW.

4.3 Reduction of pathogenic microorganisms in various stages of wastewater treatment

Although wastewater treatment is mainly intended to eliminate suspended and dissolved organic matter, independent of disinfection, the treatment process can reduce the number of pathogenic and indicator microorganisms present in the wastewater. The degree of removal can depend (in part) on the type of treatment process, as illustrated in [Table 2](#)^[2].

Table 2 — Indicative log removals of indicator microorganisms and enteric pathogens during various stages of wastewater treatment^[2]

	Indicator microorganisms			Pathogenic microorganisms				
	<i>Escherichia coli</i> (indicator bacteria)	<i>Clostridium perfringens</i>	Phage (indicator virus)	Enteric bacteria (e.g., <i>Campylobacter</i>)	Enteric viruses	<i>Giardia lamblia</i>	<i>Cryptosporidium parvum</i>	Helminths
Bacteria	X	X		X				
Protozoa and helminths						X	X	X
Viruses			X		X			
Indicative log reductions in various stages of wastewater treatment								
Secondary treatment	1 to 3	0,5 to 1	0,5 to 2,5	1 to 3	0,5 to 2	0,5 to 1,5	0,5 to 1	0 to 2
Dual media filtration ^a	0 to 1	0 to 1	1 to 4	0 to 1	0,5 to 3	1 to 3	1,5 to 2,5	2 to 3
Reservoir storage	1 to 5	N/A	1 to 4	1 to 5	1 to 4	3 to 4	1 to 3,5	1,5 to >3
Key N/A not available NOTE 1 Reduction rates depend on specific operating conditions, such as retention time, contact time and concentrations of chemicals used, pore size, filter depths, pretreatment, and other factors. Ranges given should not be used as design or regulatory bases—they are meant to show relative comparisons only. NOTE 2 See Table 3 . ^a Including coagulation.								

As the reduction presented in the table for each type of treatment is only indicative, the exact values of pathogen reduction should be determined for each situation taking into account both the type of treatment and the environmental and operating conditions such as temperature, organic matter, turbidity, pH, ammonia, alkalinity, of each system.

4.4 Reduction of pathogenic microorganisms by different disinfection methods

The purpose of disinfecting TWW should be to remove or inactivate pathogenic microorganisms that remain in the TWW at the end of the standard treatment process. As complete inactivation is not always feasible or involves investment in methods which could make the required treatment unpractical, pathogenic microorganisms should be brought to low levels that will not cause significant health damage when the wastewater is used for irrigation. Reduction of pathogenic microorganism concentrations may be integrated with additional control strategies that can prevent health impact such as setting limitations to irrigation with TWW based on the quality achieved.

The practical measurement of all pathogenic microorganisms in TWW is almost impossible for reasons, and indicator microorganisms are used (see [4.2](#)).

The reduction of indicator and pathogenic microorganisms in TWW by different disinfection methods is indicated in [Table 3](#)^[2].