

SLOVENSKI STANDARD
oSIST prEN ISO 14644-8:2022
01-april-2022

Čiste sobe in podobna nadzorovana okolja - 8. del: Klasifikacija čistosti zraka na osnovi koncentracije onesnaževal v zraku (ACC) (ISO/FDIS 14644-8:2022)

Cleanrooms and associated controlled environments - Part 8: Classification of air cleanliness by chemical concentration (ACC) (ISO/FDIS 14644-8:2022)

Reinräume und zugehörige Reinraumbereiche - Teil 8: Klassifizierung der Luftreinheit anhand der Chemikalienkonzentration (ACC) (ISO/FDIS 14644-8:2022)

Salles propres et environnements maîtrisés apparentés - Partie 8: Classification de la propreté chimique de l'air (ISO/FDIS 14644-8:2022)

Ta slovenski standard je istoveten z: prEN ISO 14644-8

oSIST prEN ISO 14644-8:2022
<https://standards.itec.ai/catalog/standards/sist/02cc9148-4dad-46ed-860c-5b53144b0d0e/osist-pren-iso-14644-8-2022>

ICS:

13.040.35	Brezprašni prostori in povezana nadzorovana okolja	Cleanrooms and associated controlled environments
-----------	----------------------------------------------------	---------------------------------------------------

oSIST prEN ISO 14644-8:2022

en,fr,de

**iTeh STANDARD
PREVIEW
(standards.iteh.ai)**

oSIST prEN ISO 14644-8:2022

<https://standards.iteh.ai/catalog/standards/sist/62cc9148-4dad-46ed-860c-5b53144b0d0e/osist-pren-iso-14644-8-2022>

FINAL
DRAFT

INTERNATIONAL
STANDARD

ISO/FDIS
14644-8

ISO/TC 209

Secretariat: ANSI

Voting begins on:
2022-02-08

Voting terminates on:
2022-05-03

Cleanrooms and associated controlled environments —

Part 8: Classification of air cleanliness by chemical concentration (ACC)

*Salles propres et environnements maîtrisés apparentés —
Partie 8: Classification de la propreté chimique de l'air*

(standards.iteh.ai)

[oSIST prEN ISO 14644-8:2022](https://standards.iteh.ai/catalog/standards/sist/62cc9148-4dad-46ed-860c-5b53144b0d0e/osist-pren-iso-14644-8-2022)

<https://standards.iteh.ai/catalog/standards/sist/62cc9148-4dad-46ed-860c-5b53144b0d0e/osist-pren-iso-14644-8-2022>

ISO/CEN PARALLEL PROCESSING

RECIPIENTS OF THIS DRAFT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

IN ADDITION TO THEIR EVALUATION AS BEING ACCEPTABLE FOR INDUSTRIAL, TECHNOLOGICAL, COMMERCIAL AND USER PURPOSES, DRAFT INTERNATIONAL STANDARDS MAY ON OCCASION HAVE TO BE CONSIDERED IN THE LIGHT OF THEIR POTENTIAL TO BECOME STANDARDS TO WHICH REFERENCE MAY BE MADE IN NATIONAL REGULATIONS.



Reference number
ISO/FDIS 14644-8:2022(E)

© ISO 2022

**iTeh STANDARD
PREVIEW
(standards.iteh.ai)**

oSIST prEN ISO 14644-8:2022
<https://standards.iteh.ai/catalog/standards/sist/62cc9148-4dad-46ed-860c-5b53144b0d0e/osist-pren-iso-14644-8-2022>



COPYRIGHT PROTECTED DOCUMENT

© ISO 2022

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword.....	iv
Introduction.....	v
1 Scope.....	1
2 Normative references.....	1
3 Terms and definitions.....	1
3.1 General.....	1
3.2 Contaminant categories.....	2
4 Testing and monitoring using grading levels.....	3
4.1 General.....	3
4.2 ISO-ACC descriptor format.....	3
5 Demonstration of compliance with an ISO-ACC level.....	5
5.1 Principle.....	5
5.2 Testing.....	5
5.3 Test report.....	6
Annex A (informative) Parameters for consideration.....	7
Annex B (informative) Typical contaminants.....	11
Annex C (informative) Typical methods of measurement.....	15
Annex D (informative) Consideration of specific requirements for separative devices.....	19
Bibliography.....	21

(standards.iteh.ai)

[oSIST prEN ISO 14644-8:2022](https://standards.iteh.ai/catalog/standards/sist/62cc9148-4dad-46ed-860c-5b53144b0d0e/osist-pren-iso-14644-8-2022)
<https://standards.iteh.ai/catalog/standards/sist/62cc9148-4dad-46ed-860c-5b53144b0d0e/osist-pren-iso-14644-8-2022>

ISO/FDIS 14644-8:2022(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 209, *Cleanrooms and associated controlled environments*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 243, *Cleanroom technology*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This third edition cancels and replaces the second edition (ISO 14644-8:2013), of which it constitutes a minor revision. The changes are as follows:

- the term class (classification, classified) changed to grade or assessment where appropriate;
- [3.1.2](#), definition revised;
- Bibliography updated;
- minor editorial changes.

A list of all parts in the ISO 14644 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Cleanrooms and associated controlled environments provide for the control of airborne particulate contamination to levels of cleanliness appropriate for accomplishing process activities sensitive to a range of contaminants. Products and processes that benefit from the control of airborne contamination include those in such industries as aerospace, microelectronics, pharmaceuticals, medical devices, food, healthcare, optics, instrumentation, vacuum technology, coatings, photovoltaics, displays, LEDs, coatings, automotive and surface analysis.

In some of these industries, the product or process can be sensitive to, or can be destroyed by, chemical contamination resulting from chemicals that are present due to external, process or other generated sources.

Within this document, the presence of chemicals is expressed as air chemical contamination. Chemical contamination is a three-step event. The first step is *generation* due to external sources such as process leakage, construction material, personnel or material outgassing. The second step is *transport* as airborne chemical contamination. The third step is *sorption* on the sensitive surface, which can be quantified as a surface chemical contamination.

The generating materials and the surfaces where sorption takes place will have a large influence on the steps of generation and sorption in addition to the actual air contamination. Thus, for these two steps, not only the contaminants but also the involved bulk and surfaces need to be defined. In order to make a standard generally applicable to any type of cleanroom or associated controlled environment, air chemical cleanliness (ACC) has been chosen for the level assessment.

This document assigns ISO grading levels to be used to specify the level of ACC within a cleanroom and associated controlled environment, where the product or process is deemed to be at risk from air chemical contamination.

For level assessment purposes, this document provides guidance for a range of ACC levels and provides standard protocols for specifying such levels with regard to chemical compounds, methods of test and analysis, and time weighted factors.

[Annexes A to D](#) contain the following information:

- parameters for consideration: [Annex A](#);
- typical contaminating chemicals and substances: [Annex B](#);
- typical methods of measurement and analysis: [Annex C](#);
- considerations of specific requirements for separative devices: [Annex D](#).

This document is one of a series of standards concerned with cleanrooms and contamination control. Many factors besides ACC need to be considered in the design, specification, operation and control of cleanrooms and other controlled environments. These features are recognized in this document and covered in some detail in other parts of the International Standards prepared by ISO/TC 209, including the ISO 14698 series. In some circumstances, relevant regulatory agencies can impose supplementary policies or restrictions. In such situations, appropriate adaptations of this document can be required.

NOTE When assessment of ACC at critical control point(s) is used as an additional cleanliness attribute to classification of air cleanliness by airborne particle concentration in accordance with ISO 14644-1, then the space can be described as a *cleanroom* or *clean-zone*. If ACC is used alone, then the space must be described as a *controlled zone*.

**iTeh STANDARD
PREVIEW
(standards.iteh.ai)**

oSIST prEN ISO 14644-8:2022

<https://standards.iteh.ai/catalog/standards/sist/62cc9148-4dad-46ed-860c-5b53144b0d0e/osist-pren-iso-14644-8-2022>

Cleanrooms and associated controlled environments —

Part 8:

Classification of air cleanliness by chemical concentration (ACC)

1 Scope

This document establishes typical assessment processes to determine grading levels of air chemical cleanliness (ACC) in cleanrooms and associated controlled environments, in terms of airborne concentrations of specific chemical substances (individual, group or category), and provides a protocol to include test methods, analysis and time-weighted factors for their determination. This document currently considers only concentrations of air chemical contaminants between 10^0 g/m³ and 10^{-12} g/m³ under cleanroom operational conditions.

This document is not relevant for application in those industries, processes or productions where the presence of airborne chemical substances is not considered a risk to the product or process.

It is not the intention of this document to describe the nature of air chemical contaminants.

This document does not give a classification of surface chemical contamination.

2 Normative references

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 General

3.1.1

chemical contamination

non-particulate substances that can have a deleterious effect on the product, process or equipment

3.1.2

air cleanliness by chemical concentration

ACC

quantity of chemical detected in the air, expressed in terms of an ISO-ACC level N, which represents the maximum allowable concentration of a given chemical species or a group of chemical species, expressed in grams per cubic metre

Note 1 to entry: This definition does not include macromolecules of biological origin, which are judged to be particles.

ISO/FDIS 14644-8:2022(E)**3.1.3****air chemical contamination**

any substance in the air that can, by its chemical nature, adversely affect the product, process or equipment

3.1.4**surface cleanliness by chemical concentration****SCC**

condition of the surface cleanliness with respect to its chemical concentration

3.1.5**surface chemical contamination**

any substance on the surface that can, by its chemical nature, adversely affect the product, process or equipment

3.1.6**contaminant category**

common name for a group of compounds with a specific and similar deleterious effect when deposited on the surface of interest

3.1.7**outgassing**

release of chemical substances in the gaseous or vapour state from a material

3.1.8**air cleanliness by chemical concentration (ACC) level**

grading number stating the maximum allowable concentration of a given chemical species or a group of chemical species in grams per cubic metre

Note 1 to entry: The range of concentrations are defined in [Table 1](#) or determined by the formula for N in [4.2](#).

Note 2 to entry: Testing and monitoring in accordance with this document is limited to the range from 0 (the grade with the lowest cleanliness) to -12 (the cleanest level).

Note 3 to entry: The ACC grading number is only valid in connection with the ACC descriptor that specifies to which chemical species or group of chemical species it is related.

Note 4 to entry: The negative sign of the air chemical cleanliness levels (-1 to -12) is an integral part of the ACC level number N and shall always be used.

Note 5 to entry: Intermediate ISO grade numbers may be specified, with 0,1 being the smallest practical increment.

3.2 Contaminant categories**3.2.1****acid**

substance whose chemical reaction characteristic is to establish new bonds by the acceptance of electron pairs

3.2.2**base**

substance whose chemical reaction characteristic is to establish new bonds by the donation of electron pairs

3.2.3**biotoxic**

contaminant substance that is obnoxious to the development and preservation of the life of organisms, microorganisms, tissues or individual cells

3.2.4**condensable**

substance capable of depositing on a surface by condensation under cleanroom operating conditions

3.2.5**corrosive**

substance that causes destructive chemical change of a surface

3.2.6**dopant**

substance that, after sorption and/or diffusion, is incorporated in the bulk of a product and is capable of changing the properties of materials, even in trace amounts

3.2.7**organic**

species based on carbon-containing compounds

Note 1 to entry: Inorganic carbon-containing compounds are excluded.

3.2.8**oxidant**

substance that, upon deposition onto a surface or product of interest, results in the formation of an oxide or participates in a redox reaction

4 Testing and monitoring using grading levels**4.1 General**

Testing or monitoring shall be specified by use of a descriptor as described in 4.2. This descriptor is designated "ISO-ACC" and indicates the maximum total chemical concentration for a contaminant category, an individual substance or a group of substances.

4.2 ISO-ACC descriptor format

An ACC grading number is only valid in connection with the ACC descriptor that specifies the chemical substance or group of substances for which this level number is valid. The ISO-ACC descriptor is expressed in the format:

ISO-ACC Level N (X)

where

ISO/FDIS 14644-8:2022(E)

X is a chemical substance or a group of chemical substances which includes, but is not limited to:

- acid (ac);
- base (ba);
- biotoxic (bt);
- condensable (cd);
- corrosive (cr);
- dopant (dp);
- organic, total (or);
- oxidant (ox); or
- a group of substances or an individual substance;

N is the ISO-ACC level, which is the logarithmic index of concentration, c_x , expressed in grams per cubic metre, and falls within a limiting range of 0 to -12. Intermediate concentrations may be specified, with 0,1 being the smallest practical increment of N ;

$$N = \log_{10}[c_x].$$

EXAMPLE 1 With an N-Methyl Pyrrolidone (NMP) sample, the measured value of air contamination was $8E-7 \text{ g/m}^3$; $N = -6,097$. This is within the level limit of $1E-6 \text{ g/m}^3$ for grade -6. The designation would be: "ISO-ACC Level -6 (NMP)".

EXAMPLE 2 With an organic compound sample, the measured value was $6E-5 \text{ g/m}^3$ of total organic compounds (TOC). This is within the level limit of $1E-4 \text{ g/m}^3$ for grade -4. The designation would be: "ISO-ACC Level -4 (TOC)."

Table 1 and Figure 1 further illustrate the suggested ISO-ACC concentration levels as a function of contaminant concentration for the specified species.

Table 1 — ISO-ACC grades

ISO-ACC level	Concentration g/m^3	Concentration $\mu\text{g/m}^3$	Concentration ng/m^3
0	10^0	10^6 (1 000 000)	10^9 (1 000 000 000)
-1	10^{-1}	10^5 (100 000)	10^8 (100 000 000)
-2	10^{-2}	10^4 (10 000)	10^7 (10 000 000)
-3	10^{-3}	10^3 (1 000)	10^6 (1 000 000)
-4	10^{-4}	10^2 (100)	10^5 (100 000)
-5	10^{-5}	10^1 (10)	10^4 (10 000)
-6	10^{-6}	10^0 (1)	10^3 (1 000)
-7	10^{-7}	10^{-1} (0,1)	10^2 (100)
-8	10^{-8}	10^{-2} (0,01)	10^1 (10)
-9	10^{-9}	10^{-3} (0,001)	10^0 (1)
-10	10^{-10}	10^{-4} (0,000 1)	10^{-1} (0,1)
-11	10^{-11}	10^{-5} (0,000 01)	10^{-2} (0,01)
-12	10^{-12}	10^{-6} (0,000 001)	10^{-3} (0,001)