
Sistemi za gašenje požara v komercialnih kuhinjah - Načrtovanje sistema, dokumentacija in preskusne zahteve - Postopki preizkusa odziva komor in kanalov na ogenj

Fire extinguishing systems in commercial kitchens - System design, documentation, and test requirements – Fire test procedures for plenum and ducts

Feuerlöschanlagen in Großküchen - Anforderungen an die Planung, Dokumentation und Prüfung von Anlagen - Brandprüfverfahren für Absaugung und Kanäle

Systèmes d'extinction d'incendie dans les cuisines professionnelles - Conception du système, documentation et exigences d'essai - Modes opératoires d'essais au feu pour le plénum et les conduits

Ta slovenski standard je istoveten z: FprCEN/TS 17749

ICS:

13.220.20	Požarna zaščita	Fire protection
97.040.99	Druga kuhinjska oprema	Other kitchen equipment

kSIST-TS FprCEN/TS 17749:2021 **en,fr,de**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[kSIST-TS FprCEN/TS 17749:2021](https://standards.iteh.ai/catalog/standards/sist/9b0c54e7-0f44-487c-9247-d09d8c0059bf/ksist-ts-fprcen-ts-17749-2021)

<https://standards.iteh.ai/catalog/standards/sist/9b0c54e7-0f44-487c-9247-d09d8c0059bf/ksist-ts-fprcen-ts-17749-2021>

TECHNICAL SPECIFICATION
SPÉCIFICATION TECHNIQUE
TECHNISCHE SPEZIFIKATION

FINAL DRAFT
FprCEN/TS 17749

October 2021

ICS 13.220.20

English Version

Fire extinguishing systems in commercial kitchens -
System design, documentation, and test requirements -
Fire test procedures for plenum and ducts

Feuerlöschanlagen in Großküchen - Anforderungen an
die Planung, Dokumentation und Prüfung von Anlagen
- Brandprüfverfahren für Absaugung und Kanäle

This draft Technical Specification is submitted to CEN members for Vote. It has been drawn up by the Technical Committee CEN/TC 191.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

(standards.iteh.ai)

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a Technical Specification. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a Technical Specification.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	3
Introduction	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Air extract duct test - actuation sequence	5
4.1 Adjustment of the exhaust conditions during the test	5
4.2 Test	5
5 Plenum test actuation sequence	6
5.1 Adjustment of the exhaust conditions during the test	6
5.2 Discharge coverage verification	6
5.3 Test	6

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[kSIST-TS FprCEN/TS 17749:2021](https://standards.iteh.ai/catalog/standards/sist/9b0c54e7-0f44-487c-9247-d09d8c0059bf/ksist-ts-fprcen-ts-17749-2021)
<https://standards.iteh.ai/catalog/standards/sist/9b0c54e7-0f44-487c-9247-d09d8c0059bf/ksist-ts-fprcen-ts-17749-2021>

European foreword

This document (FprCEN TS 17749:2021) has been prepared by Technical Committee CEN/TC 191 “Fixed Fire Fighting Systems”, the secretariat of which is held by BSI.

This document is currently submitted to the Vote on TS.

This document is intended to be used in conjunction with EN 17446.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[kSIST-TS FprCEN/TS 17749:2021](https://standards.iteh.ai/catalog/standards/sist/9b0c54e7-0f44-487c-9247-d09d8c0059bf/ksist-ts-fprcen-ts-17749-2021)

<https://standards.iteh.ai/catalog/standards/sist/9b0c54e7-0f44-487c-9247-d09d8c0059bf/ksist-ts-fprcen-ts-17749-2021>

FprCEN TS 17749:2021 (E)**Introduction**

The purpose of this document is to provide the user with a procedure for conducting the fire testing in the plenum and air extract ducts as specified in EN 17446:2021, Clause 7.4.

This document is intended to allow test authorities and specifiers to gain experience in the application of plenum and air extract ducts tests as specified in EN 17446 and allow a common understanding of the test methods and results obtained from the test.

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

[kSIST-TS FprCEN/TS 17749:2021](https://standards.iteh.ai/catalog/standards/sist/9b0c54e7-0f44-487c-9247-d09d8c0059bf/ksist-ts-fprcen-ts-17749-2021)

<https://standards.iteh.ai/catalog/standards/sist/9b0c54e7-0f44-487c-9247-d09d8c0059bf/ksist-ts-fprcen-ts-17749-2021>

1 Scope

This document establishes the detailed test procedures for conducting the test on the plenum and air extract ducts.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 17446:2021, *Fire extinguishing systems in commercial kitchens — System design, documentation, and test requirements*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 17446 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

4 Air extract duct test - actuation sequence

4.1 Adjustment of the exhaust conditions during the test

Before the start of the actual test, exhaust conditions shall be adjusted according to the type of test to perform:

- a) at the full scale test with natural air exhaustion, the damper is brought to its maximum opening position, so that the outlet of the air extract duct is fully open and is to be kept like this for the whole duration of the testing. Air flow by a blower is permitted and shall be turned off after ignition;
- b) at the full scale test without air exhaustion, proceed as in the previous point but close the air extract duct outlet immediately before system actuation. Air flow by a blower is permitted and shall be turned off after ignition;
- c) at the full scale test with forced air exhaustion by a blower, its position shall be determined so that the air velocity is between 150 m/min to 300 m/min inside the air extract duct. The air extract duct outlet shall be open and the blower shall be working during the whole duration of the test.

4.2 Test

In each test proceed in the same way after the adjustment of the exhaust conditions indicated in the previous Clause and the application of fuel:

The procedure described below is applicable for all three exhaust and damper conditions defined in 5.1. The requirement described there shall be implemented in the process as applicable.

- a) In the case forced air exhaustion is used, start the exhaustion;
- b) Start the deep fat fryer's heat source and wait until fire propagates to filters and plenum;