
Plinski kotli za centralno ogrevanje - 2-1. del: Poseben standard za tip kotlov C in tipe kotlov B2, B3 in B5 z nazivno močjo do vključno 1000 kW

Gas-fired central heating boilers - Part 2-1: Specific standard for type C appliances and type B2, B3 and B5 appliances of a nominal heat input not exceeding 1 000 kW

Heizkessel für gasförmige Brennstoffe - Teil 2-1: Heizkessel der Bauart C und Heizkessel der Bauarten B2, B3 und B5 mit einer Nennwärmebelastung nicht größer als 1 000 kW

Chaudières de chauffage central utilisant les combustibles gazeux - Partie 2-1 : Norme spécifique pour les appareils de type C et les appareils de types B2, B3 et B5 dont le débit calorifique nominal est inférieur ou égal à 1 000 kW

<https://standards.iteh.ai/catalog/standards/sist/315772ab-cc70-4843-9945-5031a01e809e/osist-pren-15502-2-1-2021>

Ta slovenski standard je istoveten z: prEN 15502-2-1

ICS:

27.060.30	Grelniki vode in prenosniki toplote	Boilers and heat exchangers
91.140.10	Sistemi centralnega ogrevanja	Central heating systems
97.100.20	Plinski grelniki	Gas heaters

oSIST prEN 15502-2-1:2021**en,fr,de**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[oSIST prEN 15502-2-1:2021](https://standards.iteh.ai/catalog/standards/sist/3f5772ab-cc70-4843-9945-5031a01e809e/osist-pren-15502-2-1-2021)

<https://standards.iteh.ai/catalog/standards/sist/3f5772ab-cc70-4843-9945-5031a01e809e/osist-pren-15502-2-1-2021>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

DRAFT
prEN 15502-2-1

July 2021

ICS 27.060.30; 91.140.10

Will supersede EN 15502-2-1:2012+A1:2016

English Version

Gas-fired central heating boilers - Part 2-1: Specific standard for type C appliances and type B2, B3 and B5 appliances of a nominal heat input not exceeding 1 000 kW

Chaudières de chauffage central utilisant les combustibles gazeux - Partie 2-1 : Norme spécifique pour les appareils de type C et les appareils de types B2, B3 et B5 dont le débit calorifique nominal est inférieur ou égal à 1 000 kW

Heizkessel für gasförmige Brennstoffe - Teil 2-1: Heizkessel der Bauart C und Heizkessel der Bauarten B2, B3 und B5 mit einer Nennwärmebelastung nicht größer als 1 000 kW

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee CEN/TC 109.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	6
Introduction.....	10
1 Scope	11
2 Normative references	13
3 Terms, definitions and symbols	14
3.1 Terms and definitions.....	14
3.2 Symbols	15
4 Classification	15
5 Construction	15
5.1 General	15
5.2 Conversion to different gases.....	15
5.3 Materials	15
5.4 Method of construction	15
5.4.1 Design	15
5.4.2 Checking the state of operation.....	15
5.4.3 Use and servicing.....	15
5.4.4 Connections to the gas and water pipes.....	15
5.4.5 Soundness.....	15
5.4.6 Supply of combustion air and evacuation of the combustion products.....	15
5.4.7 Dampers.....	16
5.4.8 Air proving.....	16
5.4.9 Gas/air ratio controls.....	17
5.4.10 Fan.....	17
5.4.11 Drainage.....	17
5.4.12 Operational safety in the event of failure of the auxiliary energy	17
5.4.13 Special provision for Low Temperature Boilers and Condensing Boilers	17
5.5 Burners.....	17
5.6 Pressure test points	17
5.7 Requirements for the application of control and safety devices.....	17
5.8 Additional requirements for modular boilers	17
6 Electrical safety	17
7 Controls	17
8 Operational requirements	17
8.1 General	17
8.1.1 Characteristics of the reference and limit gases	18
8.1.2 General test conditions.....	18
8.1.2.1 Installation of the boiler	18
8.1.2.2 Gases used for testing	19
8.1.2.3 Conduct of test to obtain a heat input.....	19
8.1.2.4 Water circuit	19
8.1.2.5 Thermal equilibrium	19
8.1.2.6 General test conditions for combination boilers.....	19
8.1.2.7 Electrical supply	19
8.1.2.8 Tolerances of measurements.....	19

8.2	Soundness.....	21
8.2.1	Soundness of the gas circuit.....	21
8.2.2	Soundness of the combustion circuit.....	21
8.2.2.102.4	Requirements for the air supply circuit	24
8.2.2.103.4	Combustion products evacuation ducts of type B₅ boilers	25
8.2.3	Soundness of the water circuit	26
8.2.4	Soundness of the domestic water circuit	26
8.3	Hydraulic resistance.....	26
8.4	Heat inputs and heat output	26
8.5	Limiting temperatures.....	27
8.5.1	General	27
8.5.2	Limiting temperatures of the adjusting, control and safety devices.....	27
8.5.3	Limiting temperatures of the side walls, the front and the top	27
8.5.4	Limiting temperature of the test panels and the floor	28
8.6	Ignition, cross lighting, flame stability	28
8.6.1	General	28
8.6.2	Limit conditions	28
8.6.3	Special flue conditions	28
8.6.3.1	General test conditions	29
8.6.3.2	Test conditions for Type C₁, C₃ and C₉ boilers	29
8.6.3.3	Test conditions for type C₂ boilers	30
8.6.3.4	Test conditions for type C₄ boilers	30
8.6.3.5	Test conditions for type C₅ boilers	30
8.6.3.6	Test conditions for type C₆ boilers	30
8.6.3.7	Test conditions for type C₇ boilers	30
8.6.3.8	Test conditions for type C₈ boilers	30
8.6.3.9	Test conditions for type C₍₁₀₎ boilers	30
8.6.3.10	Test conditions for type C₍₁₁₎ boilers	31
8.6.3.11	Test conditions for type B₂, B₃ boilers	31
8.6.3.12	Test conditions for type B₅ boiler	31
8.6.4	Reduction of the gas rate of the ignition burner	31
8.6.4.1	Requirements	31
8.6.5	Test conditions	31
8.7	Reduction of the gas pressure.....	32
8.8	Defective closure of the gas valve immediately upstream of the main burner	32
8.9	Pre-purge.....	32
8.9.1.1	Determination of the pre-purge volume:	33
8.9.1.2	Determination of the pre-purge time:	34
8.9.1.3	Test for safely weaving pre-purge under safety of operation condition...34	34
8.9.2	Requirements for verification of the protected nature of a combustion chamber	34
8.9.3	Test conditions for verification of the protected nature of a combustion chamber	34
8.9.4	Requirements for verification of normal ignition in a combustible air/gas mixture for type C boilers incorporating a fan	34
8.9.5	Test conditions for verification of normal ignition in a combustible air/gas mixture for type C boilers incorporating a fan	34
8.10	Functioning of a permanent ignition burner when the fan stops during the standby time	35
8.11	Adjustment, control and safety devices.....	35
8.11.1	General	35
8.11.2	Boilers intended to be installed in a partially protected place.....	35

8.11.3	Combination boilers	35
8.11.4	Control devices	35
8.11.5	Ignition devices	35
8.11.6	Flame supervision device	35
8.11.6.1	Thermoelectric device.....	35
8.11.6.2	Automatic burner control system	35
8.11.6.2.1	Test conditions for ignition of Modular boilers	35
8.11.7	Gas pressure regulator	35
8.11.8	Thermostats and water temperature limiting devices.....	35
8.11.101.3.3	Adjustment of the gas/air ratio.....	38
8.12	Carbon monoxide	39
8.12.1	General	39
8.12.2	Limit conditions	39
8.12.2.1	Test description	39
8.12.2.2	Requirements	39
8.12.2.3	Test conditions.....	39
8.12.3	Special conditions.....	40
8.12.3.1	Incomplete combustion	40
8.12.3.1.1	Requirements	40
8.12.3.1.2	Test conditions.....	40
8.12.3.2	Supplementary test for fan assisted boilers.....	40
8.12.3.3	Flame lift.....	40
8.12.4	Sooting.....	42
8.12.5	Supplementary test for low temperature boilers and condensing boilers	42
8.13	NO _x	42
8.14	Special provisions for boilers intended to be installed in a partially protected place	43
8.15	Formation of condensate.....	43
8.16	Temperature of combustion products.....	43
8.17	Sound power level.....	44
All test are executed at nominal working combustion product temperature.		57
9	Useful efficiencies.....	60
10	Electric auxiliary energy	60
11	Risk assessment	60
12	Marking and instructions	60
12.1	Boiler marking.....	60
12.2	Instructions.....	61
12.2.1	Instructions for installation.....	61
12.2.1.1	General.....	61
12.2.1.2	For installation and adjustment of the gas circuit.....	61
12.2.1.3	For installation on the central heating circuit.....	61
12.2.1.4	For installation of the combustion circuit.....	61
12.2.1.5	For boilers intended to be installed in a partially protected place.....	67
12.2.2	Instructions for use and servicing.....	67
12.3	Presentation	67
Figures		67
Listing of tables and numbers		80
Annexes		80
Annex XA (normative) Test apparatus for type C ₂ boilers.....		81

Annex XB (normative) Test methods to determine the effects of long-term thermal load, long-term condensate exposure, condensing/ non- condensing cycling and resistance to UV radiation.....	82
Annex XC (informative) This annex is empty on purpose.....	83
XC.1 This clause is empty on purpose	83
Annex XD (informative) Example on calculation of common duct system for type C₍₁₁₎ boilers	84
Annex ZA (informative) Left empty on purpose	86
Annex ZB (informative) Clauses of this European Standard addressing the methods for the verification of the efficiency of the EU Directive 92/42/EEC, relating to the efficiency of new hot boilers with an output of (4 - 400) kW	87
Annex ZC (informative) Relationship between this European Standard and the ecodesign requirements of Commission Regulation (EU) No 813/2013 L 239/136 aimed to be covered.....	88
Annex ZD (informative) Relationship between this European Standard and the energy labelling requirements of Commission Delegated Regulation (EU) No 811/2013 L 239/1 aimed to be covered	91
Annex ZE (informative) Relationship between this European Standard and the essential requirements of Regulation (EU) 2016/426 of the European Parliament and of the Council of 9 March 2016 on appliances burning gaseous fuels and repealing Directive 2009/142/EC aimed to be covered	94
Bibliography	109

[oSIST prEN 15502-2-1:2021](https://standards.iteh.ai/catalog/standards/sist/3f5772ab-cc70-4843-9945-5031a01e809e/osist-pren-15502-2-1-2021)

<https://standards.iteh.ai/catalog/standards/sist/3f5772ab-cc70-4843-9945-5031a01e809e/osist-pren-15502-2-1-2021>

prEN 15502-2-1:2021 (E)**European foreword**

This document (prEN 15502-2-1:2021) has been prepared by Technical Committee CEN/TC 109 “Central heating boilers using gaseous fuels”, the secretariat of which is held by NEN.

This document is currently submitted to the CEN Enquiry.

This document supersedes EN 15502-2-1:2012+A1:2016.

The main technical changes compared to EN 15502-2-1:2012+A1:2016 are the following:

1) Resulting from the revision of EN 15502-1 into FprEN 15502-1:2020

- a) Technical changes related to eco-design and energy labelling for appliances ≤ 400 kW:
- 1) deletion of the requirements that can be found in the legislation itself;
 - 2) modification of the Annexes ZC and ZD.
- b) New or generally reworded requirements:
- 1) separation between requirements and test methods in to different clauses;
 - 2) moving additional common parts from EN 15502-2-1:2012+A1:2016 and/or EN 15502-2-2:2014 to FprEN 15502-1:2020 (for example all definitions used in the parts 2 are moved to part 1; Therefore most of the definitions in this part are now by reference to part 1);
 - 3) definitions added for **Instructions for installation, Instructions for use and servicing, and Technical documentation** and consequently applied throughout the document;
 - 4) improved wording of definitions related to the air supply and combustion products circuit;
 - 5) improved the references of the Annexes Z. The Annex Z referring to the GAD has been removed and an Annex Z referring to the GAR has been inserted;
 - 6) only “instructions for installation” and “instructions for use and servicing” are defined. Therefore these are the only instructions to be used in this document;
 - 7) improved definitions 'ducts / circuits';
 - 8) definition weighted value of the NO_x concentration added. With regard to Ecodesign, it is clarified that the emissions declared are the emissions when using the references gases.
- c) Limitation of the scope compared to the standards superseded by the EN 15502 series (that were cited in the OJEU under the GAD):
- 1) Types B₁₄ and B₄ appliances, as covered in EN 297:1994 /A4:2004 are not covered by this standard as there seems to be a limited market for these appliances due to the introduction of the Ecodesign Directive that only has an exemption for B₁₁ appliances.

NOTE B₁₄ and B₄ are non condensing appliances;

- 2) this document does not cover all the requirements for appliances designed and constructed to burn gas containing toxic components. In the past it was always considered that the gases were not toxic, however this was never clearly indicated in the scope. In fact this is not a change of scope, but a clarification of the scope;
- 3) this document is not intended to cover appliances intended for connection to gas grids where the quality of the distributed gas is likely to vary to a large extent over the lifetime of the appliance (see Annex AB). In the past no big variation in gas quality occurred. Due to the EASEE-gas CBP wide variations of gas quality are considered. As these were never covered in this document, the scope is modified to make clear that these variations are not covered. In fact this is not a change of scope, but a clarification of the scope;
- 4) this document does not cover all the requirements for appliances above 1 000 kW. In fact this is not a change of scope, but a clarification of the scope;
- 5) this document does not cover all the requirements for appliances having a supplementary heater. In fact this is not a change of scope, but a clarification of the scope as these appliances were never included in the past, however due to the Ecodesign Regulation it has become necessary to mention this more explicitly;

II) Additional changes, not resulting from the revision of EN 15502-1 into FprEN 15502-1:2020.

- a) Technical changes related to eco-design and energy labelling for appliances ≤ 400 kW:
 - 1) no changes.
- b) New or generally reworded requirements:
 - 1) Separation between requirements and test methods in to different clauses;
 - 2) changes resulting from moving additional common parts from EN 15502-2-1:2012+A1:2016 and/or EN 15502-2-2:2014 to FprEN 15502-1:2020 (for example all definitions used in the parts 2 are moved to part 1; Therefore most of the definitions in this part are now by reference to part 1);
 - 3) the definitions for Instructions for installation, Instructions for use and servicing, and Technical documentation are now consequently applied throughout the document;
 - 4) an Annex Z referring to the GAR has been inserted;
 - 5) Only “instructions for installation” and “instructions for use and servicing” are defined. Therefore these are the only instructions to be used in this document.
- c) Limitation of the scope compared to the standards superseded by the EN 15502 series (that were cited in the OJEU under the GAD):

This revision only covers the update from the EN 15502-1 and an addition of a Annex Z referring to the GAR. This revision aimed not to introduce any new technical content. As some specific requirements are not covered in the EN15502-2-1:2012+A1:2016. The scope has been modified to clarify this, stating that this standard does not include:

- 1) specific requirements on surface temperatures of external parts particular to children and elderly people where relevant to ensure that this .

prEN 15502-2-1:2021 (E)

- 2) specific requirements on appliances that are intended to burn natural gases of the second family where hydrogen is added to the natural gas;
- 3) specific requirements for appliances equipped with an adaptive combustion control function;

In fact these changes are not a change of scope, but a clarification of the scope;

EN 15502 consists of the following parts under the general title “Gas-fired heating boilers”:

- *Part 1: General requirements and tests;*
- *Part 2-1: Specific standard for type C appliances and type B2, B3 and B5 appliances of a nominal heat input not exceeding 1 000 kW (this document);*
- *Part 2-2: Specific standard for type B1 appliances.*

This document (*Part 2-1*) is to be used in conjunction with Part 1.

Relationship between this document and EN 15502-1, Gas-fired heating boilers — Part 1: General requirements and tests:

This document is to be used in conjunction with FprEN 15502-1:2020 and follows the numbering structure of FprEN 15502-1:2020.

Where this European Standard states: standards.iteh.ai

- shall be according to FprEN 15502-1:2020, (clause number) with the following modification;
- shall be according to FprEN 15502-1:2020, (clause number) with the following addition;
- FprEN 15502-1:2020 (clause number) is replaced by the following;
- FprEN 15502-1:2020, (clause number) is not applicable,

the relevant text of FprEN 15502-1:(2020) is to be adapted accordingly.

This document adds clauses or subclauses to the structure of FprEN 15502-1:2020 which are particular to this part 2 standard. It should be noted that these clauses and subclauses are not indicated as an addition. Clauses, subclauses and annexes which are additional to those in FprEN 15502-1:2020 are numbered starting from 101, or designated as Annex XA, XB, XC, etc.

This document has been prepared under mandates M89/6 and M066, given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements as meant in article 3 of EU Directive 2009/142/EC, relating to appliances burning gaseous fuels and the verification methods valid for production and measurements, as meant in article 5.2 of EU Directive 92/42/EEC, relating to the efficiency requirements for new hot water boilers fired with liquid or gaseous fuels, with an output of 4 – 400 kW.

This document has been prepared under the mandates M/534 and M/535, given to CEN by the European Commission and the European Free Trade Association to provide a means of conforming to:

- requirements of Commission Regulation (EC) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters;
- requirements of Commission Delegated Regulation (EC) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EC of the European Parliament and of the Council with regard to energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device.

For relationship with EU Directive(s) and Commission Regulations, see informative Annexes ZB, ZC and ZD, ZE which are integral parts of this document.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[oSIST prEN 15502-2-1:2021
https://standards.iteh.ai/catalog/standards/sist/3f5772ab-cc70-4843-9945-5031a01e809e/osist-pren-15502-2-1-2021](https://standards.iteh.ai/catalog/standards/sist/3f5772ab-cc70-4843-9945-5031a01e809e/osist-pren-15502-2-1-2021)

Introduction

The basic function of gas-fired heating boiler is to generate heat by direct heat transfer in a heat exchanger, from the combustion gasses to the water.

The boiler can include in one design more than one function. It can include for example:

- a sanitary hot water function;
- a function to supply the combustion air from the outside/open air;
- a function to dispose the combustion products to the outside/open air.

The boiler design can be supplied to the market in more than one part. If the boiler is supplied to the market in multiple parts, the boiler is the assembly of various parts according to the instructions for installation.

Boilers can be designed to be connected to specific parts of a building. Connection to a chimney and the means of combustion air supply is particularly relevant.

Matters related to quality assurance systems, tests during production, and certificates of conformity of auxiliary devices are not dealt with in this series of European Standards.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[oSIST prEN 15502-2-1:2021](https://standards.iteh.ai/catalog/standards/sist/3f5772ab-cc70-4843-9945-5031a01e809e/osist-pren-15502-2-1-2021)

<https://standards.iteh.ai/catalog/standards/sist/3f5772ab-cc70-4843-9945-5031a01e809e/osist-pren-15502-2-1-2021>

1 Scope

EN 15502-1:2020, Clause 1 is replaced by the following:

This document specifies, the requirements and test methods concerning, as well as the classification and marking of gas-fired central heating boilers that are fitted with atmospheric burners, fan assisted atmospheric burners or fully premixed burners, and are hereafter referred to as “boilers”.

This document is to be used in conjunction with FprEN 15502-1:2020.

This document covers certain gas-fired central heating boilers from the types C₁ up to C₍₁₁₎ and the types B₂, B₃ and B₅:

NOTE 1 For further background information on appliance types see EN 1749:2020.

- a) that have a nominal heat input (on the basis of net calorific value) not exceeding 1 000 kW;
- b) that use one or more combustible gases of the three gas families at the pressures stated in EN 437:2018;
- c) where the temperature of the heat transfer fluid does not exceed 105 °C during normal operation;
- d) where the maximum operating pressure in the water circuit does not exceed 6 bar;
- e) which can give rise to condensation under certain circumstances;
- f) which are declared in the instructions for installation to be either a “condensing” boiler or a “low temperature boiler” or a “standard boiler”; if no declaration is given the boiler is to be considered a “standard boiler”;
- g) which are intended to be installed inside a building or in a partially protected place;
- h) which are intended to produce also hot water either by the instantaneous or storage principle as a single unit;
- i) which are designed for either sealed water systems or for open water systems;
- j) which are either modular boilers, or non modular boilers.
- k) which are from the types C₍₁₀₎ that are equipped with a gas-air ratio control and that have a $\Delta p_{\max, \text{saf}(\min)}$ of 25 Pa, and C₍₁₁₎ that have condensing boiler modules that are equipped with a gas-air ratio control and that have a $\Delta p_{\max, \text{saf}(\min)}$ of 25 Pa.

NOTE 2 This document provides requirements for boilers with known constructions. For boilers with any alternative constructions, which might not fully be covered by this standard, the risk associated with this alternative construction needs to be assessed.

An example of an assessment methodology, based upon risk assessment, is given in Clause 11.

prEN 15502-2-1:2021 (E)

This document does not cover all the requirements for:

- aa) appliances above 1 000 kW;
- ab) appliances that are intended to be connected to gas grids where the quality of the distributed gas is likely to vary to a large extent over the lifetime of the appliance (see Annex AB);
- ac) appliances using flue dampers;
- ad) appliances of the types B₂₁, B₃₁, B₅₁, C₂₁, C₄₁, C₅₁, C₆₁, C₇₁, C₈₁, C₍₁₂₎ and C₍₁₃₎;
- ae) C₇ appliances that have a nominal heat input (on the basis of net calorific value) exceeding 70 kW;
- af) appliances incorporating flexible plastic flue liners;
- ag) C₍₁₀₎ boilers:
 - 1) without a gas-air ratio control, or
 - 2) which are non-condensing appliances, or
 - 3) which have a maximum safety pressure difference at minimum heat input not equal to 25 Pa ($\Delta p_{\max, \text{saf}(\min)}$);
- ah) C₍₁₁₎ boilers that have boiler modules:
 - 1) without a gas-air ratio control, or
 - 2) which are non-condensing appliances, or
 - 3) which have a maximum safety pressure difference at minimum heat input not equal to 25 Pa ($\Delta p_{\max, \text{saf}(\min)}$);
- ai) appliances intended to be connected to a flue having mechanical extraction;
- aj) surface temperatures of external parts particular to children and elderly people;
- ak) appliances that are intended to burn natural gases of the second family where hydrogen is added to the natural gas;
- al) appliances equipped with an adaptive combustion control function (ACCF);
- am) boilers intended to be installed in areas accessible to elderly people and children.

iTech STANDARD PREVIEW
(standards.iteh.ai)

oSIST prEN 15502-2-1:2021

<https://standards.iteh.ai/catalog/standards/sist/35772ab-cc70-4843-9945-5031a01e809e/osist-pren-15502-2-1-2021>

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

Note 1: For references listed in this clause the edition indicated in this clause prevails, even if other parts of the text indicate undated or earlier editions.

In this standard the normative references of Part 1 are valid. Furthermore the following normative references are valid:

EN 513:2018, *Unplasticized polyvinylchloride (PVC-U) profiles for the fabrication of windows and doors — Determination of the resistance to artificial weathering*

EN 1856-2:2009, *Chimneys — Requirements for metal chimneys — Part 2: Metal flue liners and connecting flue pipes*

EN 1749:2020, *Classification of gas appliances according to the method of supplying combustion air and of evacuation of the combustion products*

EN 13216-1:2019, *Chimneys — Test methods for system chimneys — Part 1: General test methods*

EN 13501-1:2018, *Fire classification of construction products and building elements — Part 1: Classification using data from reaction to fire tests*

EN 14241-1:2013, *Chimneys — Elastomeric seals and elastomeric sealants — Material requirements and test methods — Part 1: Seals in flue liners*

EN 14471:2013+A1:2015, *Chimneys — System chimneys with plastic flue liners — Requirements and test methods*

EN 14989-1:2007, *Chimneys — Requirements and test methods for metal chimneys and material independent air supply ducts for roomsealed heating applications — Part 1: Vertical air/flue terminals for C6-type appliances*

FprEN 15502-1:2020, *Gas-fired heating boilers — Part 1: General requirements and tests*

CEN/TS 16134:2011, *Chimney terminals — General requirements and material independent test methods*

EN ISO 178:2019, *Plastics — Determination of flexural properties (ISO 178:2019)*

EN ISO 179-1:2010, *Plastics — Determination of Charpy impact properties — Part 1: Non-instrumented impact test (ISO 179-1:2010)*

EN ISO 527-1:2019, *Plastics — Determination of tensile properties — Part 1: General principles (ISO 527-1:2019)*

EN ISO 527-2:2012, *Plastics — Determination of tensile properties — Part 2: Test conditions for moulding and extrusion plastics (ISO 527-2:2012)*

EN ISO 1183-1:2019, *Plastics — Methods for determining the density of non-cellular plastics — Part 1: Immersion method, liquid pycnometer method and titration method (ISO 1183-1:2019, Corrected version 2019-05)*